

TORREY 7 E, UT, USA

WMO: 755710

Lat: 38.3028N

Lon: 111.2935W

Elev: 1891

StdP: 80.58

Time Zone: -7.00 (NAM)

Period: 07-19

WBAN: 53149

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	-12.4	-10.4	-21.1	0.7	-4.4	-19.4	0.8	-1.5	5.8	-0.5	5.4	-0.5	2.2	N/A	0.463

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.3	32.8	12.7	31.7	12.6	30.6	12.4	16.2	23.4	15.6	23.7	15.1	23.9	2.9	N/A

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.2	12.7	18.7	13.0	11.8	18.7	11.8	10.8	19.4	53.0	23.2	50.8	23.6	48.9	23.9	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.7	4.0	DB	-15.8	34.8	2.1	0.8	-17.3	35.3	-18.6	35.8	-19.8	36.2	-21.3	36.8	(4)
(5)			WB	-17.1	17.9	2.1	0.5	-18.6	18.3	-19.8	18.6	-20.9	18.9	-22.4	19.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.7	-1.4	1.3	6.2	9.4	13.8	21.4	23.7	22.3	18.5	10.7	4.3	-1.8	(6)	
	DBStd	9.74	4.26	4.76	4.10	4.25	4.23	3.82	2.31	2.41	3.48	4.28	4.55	4.57	(7)	
	HDD10.0	1394	354	245	131	62	16	0	0	0	1	42	177	366	(8)	
	HDD18.3	3225	613	477	377	268	148	17	1	2	39	237	422	624	(9)	
	CDD10.0	1666	0	1	13	44	134	343	426	382	255	64	5	0	(10)	
	CDD18.3	455	0	0	0	0	8	109	168	126	43	1	0	0	(11)	
	CDH23.3	4899	0	0	0	7	112	1404	1718	1201	447	10	0	0	(12)	
	CDH26.7	1788	0	0	0	0	14	572	700	411	91	1	0	0	(13)	
(14) Wind	WSAvg	2.3	1.9	2.2	2.4	2.5	2.4	2.5	2.3	2.3	2.3	2.2	2.2	1.9	(14)	
(15) Precipitation	PrecAvg	205	13	13	12	16	13	13	19	32	21	28	11	10	(15)	
	PrecMax	303	49	50	33	54	50	47	46	69	80	115	47	23	(16)	
	PrecMin	103	0	0	0	1	0	1	1	8	0	2	0	3	(17)	
	PrecStd	57	15	14	11	14	12	10	13	16	21	28	12	6	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	10.9	15.3	21.2	24.6	28.6	34.4	34.0	32.9	31.1	24.7	17.8	11.3	(19)	
		MCWB	3.2	5.1	7.2	8.4	10.4	12.8	13.5	12.7	12.2	9.9	6.5	3.8	(20)	
	2%	DB	8.4	13.2	18.2	21.9	26.1	32.9	32.8	31.6	29.1	22.1	15.2	8.9	(21)	
		MCWB	1.9	4.2	6.2	7.5	9.5	12.4	13.1	12.4	11.9	9.0	5.8	2.5	(22)	
	5%	DB	6.2	10.8	16.1	19.9	24.4	31.7	31.8	30.4	27.5	20.0	13.6	6.8	(23)	
		MCWB	0.7	3.2	5.3	6.9	8.8	11.8	13.3	12.5	11.3	8.4	5.0	1.8	(24)	
	10%	DB	4.6	8.6	13.8	17.8	22.5	30.2	30.6	29.2	26.1	18.1	11.8	5.0	(25)	
		MCWB	-0.3	2.4	4.3	6.2	8.4	11.3	13.1	12.8	11.0	7.6	4.1	0.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.6	6.1	7.8	9.4	11.4	14.8	17.5	16.9	15.6	12.4	7.8	5.0	(27)	
		MCDB	10.3	13.7	20.3	21.1	24.4	28.8	23.3	22.9	21.4	19.4	15.5	9.4	(28)	
	2%	WB	2.3	5.0	6.7	8.5	10.2	13.8	16.5	16.1	14.6	10.6	6.3	4.0	(29)	
		MCDB	7.0	12.0	17.7	20.6	23.2	28.9	23.7	22.7	21.0	17.5	13.8	7.3	(30)	
	5%	WB	1.3	4.0	5.8	7.5	9.4	12.9	15.8	15.4	13.6	9.6	5.2	2.8	(31)	
		MCDB	5.5	10.4	15.6	18.7	22.1	28.8	24.2	22.9	21.5	17.2	12.8	6.4	(32)	
	10%	WB	0.3	2.9	4.8	6.6	8.7	12.1	15.4	14.8	12.8	8.8	4.1	1.3	(33)	
		MCDB	4.0	8.8	13.6	17.3	20.9	27.8	24.5	23.2	22.1	16.4	11.0	5.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	9.3	11.2	12.1	12.0	13.8	12.3	12.1	12.4	11.0	9.9	7.9	(35)	
		MCDBR	9.6	11.4	13.9	14.5	14.4	14.9	14.0	13.7	14.1	13.1	11.6	9.6	(36)	
	5% WB	MCWBR	5.8	5.8	6.3	6.2	5.4	5.3	4.4	4.4	5.2	5.7	6.0	5.8	(37)	
		MCWBR	8.7	10.3	12.9	13.6	13.1	13.1	10.5	10.7	10.9	10.3	11.1	8.8	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.240	0.252	0.264	0.291	0.304	0.298	0.346	0.344	0.299	0.278	0.248	0.241	(40)	
		taud	2.571	2.547	2.532	2.438	2.454	2.485	2.392	2.402	2.522	2.544	2.587	2.586	(41)	
	Edn at Noon	Edn at Noon	972	996	1008	988	974	975	926	922	954	949	953	947	(42)	
		Edh at Noon	71	84	94	111	111	108	118	114	95	83	69	65	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2.68	3.55	4.97	6.28	7.13	8.03	6.89	6.15	5.58	4.22	3.03	2.32	(44)	
	RadStd	RadStd	0.21	0.28	0.32	0.32	0.50	0.52	0.38	0.35	0.30	0.33	0.20	0.18	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)			
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page