

TIJUANA, Mexico

WMO: 760013

Lat: 32.541N

Lon: 116.970W

Elev: 489

StdP: 14.44

Time Zone: -8.00 (NAP)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 12	(b) 42.4	(c) 44.3	(d) 5.1	(e) 7.3	(f) 65.1	(g) 10.0	(h) 9.4	(i) 65.2	(j) 21.3	(k) 61.5	(l) 18.9	(m) 61.7	(n) 2.6	(o) 110	(p) 0.385

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 16.5	(c) 91.0	(d) 63.4	(e) 87.4	(f) 63.2	(g) 84.1	(h) 63.1	(i) 70.6	(j) 82.3	(k) 69.6	(l) 80.6	(m) 68.4	(n) 78.2	(o) 10.2	(p) 270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.6	99.7	73.1	66.2	98.2	72.9	64.7	93.3	72.4	34.8	82.7	33.9	80.9	33.1	78.6	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	14.9	13.6	DB	37.4	98.7	2.5	3.3	35.6	101.1	34.1	103.0	32.7	104.9	30.8	107.3
			WB	30.7	73.0	2.5	1.8	28.9	74.4	27.5	75.5	26.1	76.5	24.3	77.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	64.1	57.8	57.5	59.3	61.0	63.8	67.1	71.2	72.6	71.9	67.5	62.2	57.1
	DBStd	7.22	5.31	5.24	4.80	4.76	4.21	3.47	3.32	3.61	4.67	5.03	5.48	4.54
	HDD50	7	3	2	0	0	0	0	0	0	0	0	0	2
	HDD65	1258	232	220	188	140	72	13	1	0	1	24	117	250
	CDD50	5163	245	212	290	329	428	514	657	702	656	543	367	220
	CDD65	934	9	9	12	19	34	76	192	237	207	102	34	3
	CDH74	6107	123	119	158	246	273	357	964	1341	1310	787	374	55
	CDH80	1811	20	26	46	83	96	84	207	360	453	308	124	4
(14) Wind	WSAvg	5.2	4.5	5.1	5.1	5.7	5.7	5.7	5.8	5.6	5.0	4.6	4.4	4.7
(15) Precipitation	PrecAvg	9.4	1.7	1.6	1.9	0.6	0.1	0.0	0.0	0.0	0.2	0.2	1.3	1.6
	PrecMax	17.0	5.6	6.5	6.5	2.2	0.6	0.2	0.3	0.2	2.3	1.5	5.0	6.4
	PrecMin	4.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	3.7	1.5	1.7	1.6	0.7	0.2	0.0	0.1	0.0	0.6	0.4	1.2	1.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.6	83.9	86.0	88.1	89.7	89.5	89.4	91.8	95.3	94.9	89.3	79.2
		MCWB	53.7	54.9	57.2	56.1	57.6	63.9	66.6	69.6	66.5	60.4	57.9	52.1
	2%	DB	77.3	77.3	78.4	80.8	81.0	80.9	84.6	87.6	89.4	87.9	83.9	74.8
		MCWB	51.9	52.9	55.0	55.9	57.0	65.1	67.1	68.3	67.7	58.3	55.6	51.4
	5%	DB	73.2	71.8	73.0	75.1	75.3	77.3	82.1	84.1	84.6	82.4	77.3	71.0
		MCWB	51.6	52.8	55.7	55.4	58.6	64.1	67.0	68.1	66.4	59.2	53.8	51.6
	10%	DB	68.3	66.6	68.2	70.0	71.7	75.0	79.0	80.8	80.9	77.2	73.1	66.5
		MCWB	51.0	52.5	55.5	57.0	59.0	63.2	66.8	67.7	66.0	59.7	53.6	52.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.7	60.6	61.1	61.9	63.0	67.5	70.8	72.3	72.2	69.4	62.1	61.0
		MCDB	65.9	66.8	72.5	74.1	77.6	80.8	81.6	84.5	87.4	78.8	70.3	65.6
	2%	WB	57.9	57.7	59.4	60.2	61.6	66.1	69.5	70.7	70.6	66.6	60.5	59.2
		MCDB	64.3	67.6	69.3	70.4	73.4	78.7	80.7	81.0	83.8	75.0	68.5	64.4
	5%	WB	56.5	56.3	58.2	58.9	60.3	64.6	68.3	69.6	69.6	64.7	59.2	57.5
		MCDB	63.1	66.1	67.5	68.8	70.3	75.4	78.0	79.7	81.4	74.1	67.7	62.8
	10%	WB	55.0	55.2	57.0	57.7	59.1	63.3	67.3	68.3	68.3	63.2	57.9	55.9
		MCDB	62.2	64.5	65.8	66.5	68.0	72.8	76.1	77.7	77.8	72.5	67.2	61.0
(35) Mean Daily Temperature Range	5% DB	MDBR	19.3	18.0	17.5	17.0	15.0	15.3	16.1	16.5	17.2	18.2	19.8	19.2
		MCDBR	26.7	26.9	26.1	26.8	22.5	19.9	20.2	20.8	22.7	27.8	27.5	26.3
		MCWBR	12.1	12.2	12.0	11.8	9.3	7.6	6.5	6.8	7.8	11.5	12.8	13.1
	5% WB	MCDBR	17.6	21.4	19.5	18.7	16.8	18.4	16.5	17.1	18.2	18.4	20.6	15.6
		MCWBR	9.9	11.1	9.9	8.7	7.2	7.6	6.4	6.6	6.8	9.2	10.8	9.4
(40) Clear-Sky Solar Irradiance	taub		0.310	0.321	0.333	0.344	0.363	0.366	0.394	0.396	0.359	0.364	0.320	0.322
	taud		2.556	2.539	2.491	2.462	2.428	2.423	2.428	2.403	2.483	2.439	2.554	2.550
	Ebn at Noon		291	298	301	300	293	290	281	280	288	278	284	279
	Edh at Noon		26	29	33	35	37	37	36	37	33	32	26	25
(44) All-Sky Solar Radiation	RadAvg		1064	1335	1753	2117	2235	2338	2246	2159	1882	1480	1154	964
(45)	RadStd		66	111	97	109	163	134	148	100	101	105	72	66

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	+4	N/A	N/A	N/A
Regional (33 neighbors)	+1.19	N/A	-2.90	+1.39	N/A	N/A	N/A	-191	+419	+227

Nomenclature: See separate page