

MEXICALI INTL, Mexico

WMO: 760053

Lat: 32.631N

Lon: 115.242W

Elev: 74

StdP: 14.66

Time Zone: -8.00 (NAP)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	38.8	41.1	6.8	7.8	63.5	11.9	10.1	64.0	25.1	61.5	22.9	60.5	3.9	330	0.449

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	25.6	111.2	76.6	109.0	76.6	106.2	75.4	84.6	104.4	82.8	102.5	81.2	100.0	6.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.2	151.9	98.5	77.4	142.8	94.9	75.6	134.4	92.7	49.0	104.0	46.8	101.8	44.8	100.0	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.3	21.8	18.3	DB	33.3	115.3	2.3	1.9	31.6	116.7	30.3	117.8	29.1	118.9	27.4	120.3	
			WB	28.9	85.9	2.7	3.8	26.9	88.7	25.3	90.9	23.8	93.0	21.9	95.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	74.2	57.1	58.7	66.7	71.6	78.4	86.9	92.8	93.0	87.1	75.9	65.1	55.9
	DBStd	14.16	5.22	5.32	6.24	5.89	6.16	5.08	3.33	3.44	5.81	5.85	6.14	4.94
	HDD50	17	9	2	0	0	0	0	0	0	0	0	0	6
	HDD65	867	249	185	57	14	1	0	0	0	0	4	73	284
	CDD50	8849	228	245	519	649	881	1108	1326	1332	1114	802	455	190
	CDD65	4224	4	8	111	213	417	658	861	867	664	341	77	3
	CDH74	63069	86	185	1543	2832	5727	9988	13774	13866	9910	4120	975	63
	CDH80	39876	6	19	598	1334	3378	6676	9464	9529	6389	2157	324	2
Wind	WSAvg	6.8	5.5	6.6	7.4	8.8	8.2	7.6	8.2	7.4	6.1	5.9	5.1	5.2
Precipitation	PrecAvg	2.1	0.3	0.2	0.2	0.1	0.0	0.0	0.1	0.3	0.1	0.3	0.2	0.3
	PrecMax	5.2	1.7	1.8	1.3	1.1	0.2	0.1	0.8	3.0	0.7	3.6	1.6	1.9
	PrecMin	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	1.6	0.5	0.4	0.3	0.3	0.0	0.0	0.2	0.7	0.2	0.7	0.4	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.2	82.6	94.6	98.9	106.2	114.5	114.4	113.1	109.8	102.2	91.1	79.0
		MCWB	57.7	59.4	65.3	68.2	72.2	73.4	78.5	79.2	78.2	73.6	64.7	58.6
	2%	DB	76.6	79.0	90.0	95.3	102.2	109.5	111.1	110.9	107.5	97.2	87.5	75.3
		MCWB	56.9	59.0	64.3	65.5	69.7	73.4	78.9	76.7	76.2	69.6	61.8	56.6
	5%	DB	73.4	75.6	86.3	91.5	98.8	106.0	107.9	107.8	104.4	95.0	83.9	71.6
		MCWB	55.2	57.1	62.8	63.5	69.9	72.5	76.8	77.3	74.4	67.4	61.0	55.3
	10%	DB	69.9	71.9	82.7	87.9	95.4	103.7	105.8	105.6	102.2	91.6	79.7	67.8
		MCWB	54.0	55.8	60.9	63.1	67.5	71.5	76.2	76.4	74.2	65.7	60.0	53.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.8	63.5	70.1	72.8	77.1	81.9	87.4	87.1	85.6	77.9	70.3	62.8
		MCDB	74.8	78.5	90.9	95.3	100.6	106.9	108.5	106.0	102.9	95.2	86.7	73.5
	2%	WB	59.6	61.2	67.7	69.8	74.8	79.1	84.6	84.6	82.4	74.8	66.6	60.0
		MCDB	71.0	75.3	86.7	91.3	99.4	103.3	105.2	104.4	100.9	92.5	82.2	70.5
	5%	WB	57.4	59.3	64.9	67.4	72.1	76.8	82.9	83.0	80.3	72.0	64.2	58.1
		MCDB	68.1	71.7	83.0	87.1	96.0	100.2	103.0	102.5	98.2	89.4	78.7	67.8
	10%	WB	55.6	57.3	62.4	64.5	69.8	74.8	81.2	81.1	78.0	69.7	61.4	55.9
		MCDB	66.7	69.2	79.5	83.0	92.0	98.0	100.4	98.9	95.0	86.1	75.1	64.5
Mean Daily Temperature Range	5% DB	MDBR	24.2	24.5	27.5	28.2	29.9	31.5	26.0	25.6	27.4	28.4	26.4	23.2
		MCDBR	28.6	29.0	32.2	33.1	34.7	34.0	29.6	28.5	29.8	32.3	30.8	28.0
		MCWBR	15.4	14.5	14.8	13.8	14.6	13.0	11.8	11.3	12.3	14.0	14.5	15.1
	5% WB	MCDBR	25.3	26.2	30.9	31.6	33.7	32.3	25.9	25.9	26.2	28.6	27.7	24.4
		MCWBR	15.9	15.0	17.3	17.4	16.5	15.8	12.7	12.3	12.5	14.9	15.9	15.0
Clear-Sky Solar Irradiance	taub	0.288	0.290	0.310	0.322	0.339	0.341	0.386	0.381	0.347	0.317	0.293	0.289	
	taud	2.519	2.532	2.456	2.427	2.397	2.396	2.384	2.388	2.444	2.494	2.529	2.538	
	Ebn at Noon	298	309	308	306	300	298	284	285	292	294	294	292	
	Edh at Noon	27	29	34	36	38	38	38	37	34	30	26	25	
All-Sky Solar Radiation	RadAvg	1125	1435	1895	2316	2575	2673	2419	2253	1990	1612	1224	1016	
	RadStd	54	94	64	54	65	93	93	89	70	61	52	53	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (17 neighbors)	+0.95	N/A	-2.25	+1.10	N/A	N/A	N/A	-140	+337	+189	

Nomenclature: See separate page