

MONCLOVA, Mexico

WMO: 763420

Lat: 26.9003N

Lon: 101.4339W

Elev: 2018

StdP: 13.66

Time Zone: -6.00 (MEX)

Period: 95-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	34.2	38.0	13.2	11.6	59.2	19.0	15.4	60.2	22.6	72.5	19.2	60.8	4.5	60	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	22.6	104.1	74.5	102.0	74.6	100.1	74.1	82.6	97.3	80.1	95.0	78.1	93.5	7.8	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.8	161.3	94.2	76.0	146.3	91.0	73.7	135.1	86.5	48.4	97.0	45.5	95.3	43.2	93.5	94.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
20.5	17.0	13.4	DB	29.0	109.7	4.8	3.1	25.6	111.9	22.8	113.7	20.1	115.4	16.7	117.7
			WB	26.9	84.9	4.7	4.8	23.5	88.3	20.7	91.2	18.1	93.9	14.7	97.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.6	58.3	64.9	70.0	77.7	83.3	86.9	86.5	86.8	81.7	74.8	65.8	58.1
	DBStd	12.67	9.87	9.00	8.67	7.49	6.15	4.20	4.04	3.73	5.59	6.88	7.94	8.57
	HDD50	84	42	7	2	0	0	0	0	0	0	1	6	26
	HDD65	756	249	107	52	8	0	0	0	0	1	13	82	244
	CDD50	9065	298	423	622	832	1033	1107	1130	1142	950	771	480	277
	CDD65	4262	40	102	207	390	569	657	665	677	501	317	106	31
	CDH74	52395	523	1131	2244	4645	7260	8991	8731	9039	5666	2923	902	340
	CDH80	28413	168	467	1040	2503	4191	5305	5005	5203	2869	1267	301	94
(14) Wind	WSAvg	4.9	4.8	5.1	5.4	5.7	5.3	5.2	4.9	4.8	4.4	4.3	4.3	4.4
(15) Precipitation	PrecAvg	14.4	0.4	0.6	0.5	0.8	1.4	2.3	2.1	1.7	3.2	1.2	0.7	0.6
	PrecMax	29.1	1.6	2.9	2.5	3.5	5.2	13.7	11.3	6.7	10.1	3.1	4.8	3.5
	PrecMin	6.7	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.0	0.1	0.0	0.0	0.0
	PrecStd	5.3	0.4	0.6	0.7	0.9	1.2	3.0	2.4	1.7	2.8	1.0	0.9	0.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.6	95.3	98.1	104.4	107.8	107.2	104.4	103.8	102.3	98.2	93.0	88.2
		MCWB	65.0	68.0	64.7	70.3	74.4	73.4	75.9	74.8	75.0	71.8	68.8	66.5
	2%	DB	84.9	89.8	94.1	100.4	103.8	103.7	101.8	101.7	98.3	94.3	87.7	82.6
		MCWB	63.1	65.9	67.1	69.6	75.1	74.6	75.5	75.7	73.9	72.7	66.3	61.7
	5%	DB	80.2	86.1	90.3	96.8	100.3	100.7	99.8	99.5	95.3	91.0	83.5	77.4
		MCWB	60.7	64.1	65.7	69.2	74.1	74.3	74.6	75.2	73.3	71.4	65.9	60.5
	10%	DB	75.2	81.2	86.2	92.9	96.9	98.3	97.2	97.3	92.9	87.5	79.2	73.3
		MCWB	58.3	62.0	64.8	69.2	72.5	74.2	74.1	74.5	73.0	70.6	63.8	59.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.7	74.6	76.5	81.6	84.6	85.7	84.4	85.5	82.4	79.4	73.6	69.1
		MCDB	84.4	91.7	91.5	96.1	102.1	98.8	97.9	97.6	94.3	91.9	86.5	84.4
	2%	WB	65.8	69.0	71.4	76.4	80.2	80.1	81.0	81.6	78.9	76.1	69.7	65.2
		MCDB	81.7	85.1	87.7	93.9	97.9	95.4	95.6	96.1	92.2	88.4	81.9	77.7
	5%	WB	62.3	65.8	68.8	73.1	77.2	77.5	78.1	78.7	76.7	73.9	67.6	62.7
		MCDB	76.3	81.5	84.6	91.3	94.9	94.0	93.6	94.1	90.0	85.1	78.9	73.9
	10%	WB	59.2	63.4	66.7	70.5	75.0	75.7	76.0	76.4	74.9	72.3	65.5	60.3
		MCDB	72.3	77.2	81.3	87.8	91.3	92.7	92.5	92.0	87.9	83.1	77.0	70.3
(35) Mean Daily Temperature Range	5% DB	MDBR	24.1	25.2	24.8	25.6	24.1	22.6	21.2	21.2	20.1	21.5	22.4	21.9
		MCDBR	31.4	31.2	30.6	30.9	28.6	25.6	24.0	23.5	23.4	26.6	28.4	29.0
	5% WB	MCWBR	19.0	16.8	15.4	14.8	14.4	11.2	11.7	11.3	11.8	12.9	15.5	16.2
		MCWBR	29.9	28.5	27.7	27.3	25.9	23.1	22.2	21.9	20.9	21.3	25.0	26.8
(40) Clear-Sky Solar Irradiance	taub		0.298	0.314	0.326	0.371	0.409	0.407	0.404	0.388	0.396	0.347	0.326	0.305
		taud	2.542	2.478	2.455	2.333	2.273	2.336	2.384	2.434	2.385	2.516	2.496	2.527
	Ebn at Noon		305	306	307	294	281	279	280	285	281	291	291	297
		Edh at Noon	28	32	35	41	43	41	39	36	37	31	29	28
(44) All-Sky Solar Radiation	RadAvg		1210	1515	1841	2093	2132	2208	2100	2057	1689	1532	1291	1136
	RadStd		119	160	138	140	96	135	168	111	160	138	130	98

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	-1.78	-1.01	N/A	N/A	N/A

Nomenclature: See separate page