

TORREON, Mexico

WMO: 763820

Lat: 25.5200N

Lon: 103.4161W

Elev: 1123

StdP: 88.54

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 4.0	(c) 5.9	(d) -9.0	(e) 2.0	(f) 21.7	(g) -6.6	(h) 2.5	(i) 20.3	(j) 10.2	(k) 19.3	(l) 8.5	(m) 19.6	(n) 1.1	(o) 340	(p) 0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 6	(b) 12.8	(c) 38.0	(d) 20.4	(e) 37.0	(f) 20.2	(g) 36.0	(h) 20.1	(i) 24.4	(j) 33.6	(k) 23.5	(l) 32.9	(m) 22.8	(n) 32.0	(o) 2.7	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 21.8	(b) 19.0	(c) 29.8	(d) 20.9	(e) 17.9	(f) 28.4	(g) 20.1	(h) 17.0	(i) 27.2	(j) 80.4	(k) 33.5	(l) 76.6	(m) 32.9	(n) 73.6	(o) 32.0	(p) 29.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 8.7	(b) 6.7	(c) 5.5	(e) 0.5	(f) 39.9	(g) 2.2	(h) 0.9	(i) -1.1	(j) 40.5	(k) -2.4	(l) 41.0	(m) -3.7	(n) 41.4	(o) -5.3	(p) 42.1		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.3	15.3	18.5	21.2	25.2	28.1	29.3	28.8	28.4	26.3	23.4	19.1	15.5
	DBStd	5.79	3.64	3.72	3.58	2.98	2.51	1.95	1.64	1.81	2.13	2.86	3.33	4.00
	HDD10.0	12	4	1	0	0	0	0	0	0	0	0	1	7
	HDD18.3	301	106	41	17	1	0	0	0	0	0	3	30	103
	CDD10.0	4858	169	238	346	456	561	578	582	572	489	417	274	178
	CDD18.3	2107	13	45	104	207	303	328	323	313	239	162	54	16
	CDH23.3	25249	186	525	1169	2501	4022	4375	4055	3813	2430	1485	508	182
CDH26.7	12599	33	158	453	1255	2292	2488	2158	1957	1089	561	128	27	
Wind	WSAvg	1.9	1.5	1.8	2.1	2.3	2.2	2.3	2.3	2.1	1.7	1.5	1.5	1.5
Precipitation	PrecAvg	249	10	6	8	6	18	27	48	37	51	19	10	6
	PrecMax	513	57	68	94	20	82	91	174	167	135	59	67	56
	PrecMin	108	0	0	0	0	0	1	6	1	2	0	0	1
	PrecStd	102	15	13	20	6	18	27	44	38	34	16	14	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.8	32.5	34.2	37.3	39.7	39.5	37.8	37.2	35.9	34.1	31.8	29.2
		MCWB	14.4	15.4	15.7	17.9	19.5	20.7	21.4	21.7	20.5	20.1	17.3	14.8
	2%	DB	27.2	30.2	32.5	35.9	38.0	38.1	36.3	36.1	34.2	32.8	29.8	27.1
		MCWB	14.1	14.9	15.6	17.2	19.8	20.7	21.2	21.2	20.5	19.5	16.8	14.9
	5%	DB	25.2	28.8	31.0	34.4	36.8	37.0	35.6	35.1	33.2	31.2	28.1	25.8
		MCWB	13.4	14.5	15.1	16.8	19.2	20.5	21.0	20.9	20.5	18.8	16.8	14.2
	10%	DB	23.2	26.9	29.3	33.1	35.2	35.8	34.8	34.0	32.0	30.0	26.4	23.8
		MCWB	12.5	13.9	14.7	16.5	18.7	20.4	20.7	20.6	20.3	18.5	16.0	13.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.1	19.0	19.2	21.8	24.3	25.7	25.0	25.3	24.5	23.0	20.9	18.2
		MCDB	25.8	28.3	29.7	32.9	36.2	35.1	34.4	33.5	32.0	30.8	28.2	25.4
	2%	WB	15.4	17.0	17.6	20.2	22.7	24.1	23.6	24.2	23.3	21.7	19.1	16.6
		MCDB	24.1	26.3	28.4	31.0	34.3	34.1	33.5	32.8	30.8	29.5	26.1	23.9
	5%	WB	14.3	15.9	16.7	19.0	21.6	23.1	22.7	23.2	22.3	20.8	18.0	15.4
		MCDB	22.6	25.4	27.2	30.1	33.0	33.3	32.5	31.6	29.5	28.3	25.6	23.0
	10%	WB	13.2	14.8	15.8	18.0	20.6	22.1	22.0	22.3	21.6	20.0	17.0	14.2
		MCDB	21.4	24.1	26.2	29.1	31.3	31.9	31.5	30.3	28.4	27.3	24.3	21.6
Mean Daily Temperature Range	5% DB	MDBR	14.4	15.0	15.0	15.2	14.6	12.8	12.1	11.6	11.2	12.6	13.8	13.9
		MCDBR	16.8	16.9	16.7	16.5	15.6	14.2	12.8	12.5	12.8	13.8	15.3	16.0
		MCWBR	9.2	8.3	7.6	7.2	7.3	6.9	6.1	6.1	6.0	6.6	8.1	8.9
	5% WB	MCDBR	15.1	15.3	15.3	15.3	14.5	12.8	12.1	11.6	11.3	12.4	13.9	14.2
		MCWBR	9.2	8.7	8.1	7.8	7.7	6.7	6.0	6.2	5.7	6.4	8.2	8.9
Clear-Sky Solar Irradiance	taub	0.266	0.271	0.281	0.320	0.373	0.369	0.384	0.366	0.369	0.311	0.281	0.267	
	taud	2.653	2.579	2.537	2.411	2.295	2.395	2.384	2.443	2.425	2.599	2.635	2.648	
	Ebn at Noon	1009	1020	1019	977	918	915	901	920	914	963	982	994	
	Edh at Noon	80	93	102	119	134	121	122	114	114	90	81	78	
All-Sky Solar Radiation	RadAvg	4.26	5.27	6.39	7.25	7.62	7.43	6.96	6.72	5.76	5.45	4.62	4.01	
	RadStd	0.31	0.41	0.32	0.42	0.24	0.40	0.36	0.31	0.34	0.31	0.30	0.24	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page