

SALTILLO, Mexico

WMO: 763900

Lat: 25.3514N

Lon: 101.0239W

Elev: 1790

StdP: 81.59

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.2	0.8	-9.3	2.1	9.7	-6.9	2.6	8.8	9.8	20.0	8.4	16.9	1.8	210	0.429

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.9	34.0	19.8	32.8	19.8	31.2	19.5	22.6	30.6	21.9	30.0	21.0	29.2	4.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.1	18.5	28.1	19.2	17.4	27.0	18.2	16.4	25.6	77.0	31.0	73.7	30.1	70.1	29.2	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
9.3	8.2	7.4	-4.9	37.1	2.6	1.7	-6.8	38.3	-8.3	39.3	-9.8	40.2	-11.7	41.5		
			-5.8	24.2	2.2	1.5	-7.4	25.3	-8.7	26.1	-9.9	27.0	-11.5	28.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.5	12.4	14.6	16.7	20.2	22.6	22.9	22.8	22.5	20.3	18.5	15.4	13.1
	DBStd	5.32	4.91	4.88	4.55	4.15	3.47	2.15	1.84	1.91	2.36	3.44	4.00	4.93
	HDD10.0	94	34	16	7	1	0	0	0	0	0	1	6	29
	HDD18.3	746	188	118	82	29	7	0	0	1	9	39	103	169
	CDD10.0	3204	109	145	215	306	392	388	398	386	309	264	168	124
	CDD18.3	813	4	13	32	84	141	138	139	128	69	44	14	6
	CDH23.3	8158	89	218	432	954	1460	1362	1199	1137	573	426	193	114
CDH26.7	2873	13	52	119	391	644	525	413	392	152	118	39	16	
Wind	WSAvg	3.2	2.8	3.1	3.5	3.8	3.9	3.7	3.5	3.3	2.9	2.8	2.8	2.7
Precipitation	PrecAvg	467	15	12	15	12	40	58	99	80	80	31	13	13
	PrecMax	792	109	46	118	37	74	106	305	183	209	110	81	65
	PrecMin	220	0	0	0	0	0	3	26	21	5	0	0	0
	PrecStd	157	21	14	23	11	22	31	67	41	52	31	19	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.1	30.9	31.8	35.1	36.9	35.2	33.8	33.2	32.0	31.9	30.1	28.2
		MCWB	15.7	16.6	17.2	19.2	20.4	20.7	21.6	21.2	21.1	20.2	18.0	16.1
	2%	DB	25.9	28.1	29.9	32.9	34.1	33.0	32.0	31.9	30.0	29.9	27.8	26.2
		MCWB	14.6	15.8	16.7	18.3	19.2	20.4	20.9	21.0	19.8	19.5	17.0	15.3
	5%	DB	23.8	26.0	27.9	30.9	32.1	31.2	30.2	30.2	28.2	27.8	25.6	24.2
		MCWB	13.7	14.7	15.7	17.7	19.0	19.7	20.1	20.4	19.3	18.2	15.7	14.1
	10%	DB	21.2	23.9	25.9	29.0	30.2	29.9	29.1	29.0	26.9	25.8	23.3	22.0
		MCWB	12.4	13.7	14.7	16.8	18.4	19.7	19.4	19.7	18.9	17.1	14.8	13.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.3	18.7	19.7	22.7	22.9	23.9	23.2	23.1	22.7	22.0	20.0	18.1
		MCDB	25.6	27.2	28.5	31.2	32.0	30.7	30.8	30.7	30.1	30.3	27.3	25.6
	2%	WB	15.6	16.8	18.0	20.2	21.6	22.2	22.1	22.1	21.3	20.2	18.0	16.3
		MCDB	24.4	26.1	27.4	30.1	30.9	30.5	29.9	29.9	28.1	27.5	25.4	24.8
	5%	WB	14.4	15.4	16.7	19.0	20.3	21.1	21.1	21.1	20.2	19.0	16.7	14.9
		MCDB	22.7	24.8	26.1	28.3	29.9	29.7	29.0	29.1	26.6	25.7	23.8	23.1
	10%	WB	12.8	14.3	15.4	17.8	19.2	20.1	20.2	20.2	19.4	18.0	15.4	13.6
		MCDB	20.4	22.7	24.5	27.3	28.3	28.3	27.7	27.7	25.2	24.3	22.2	21.0
Mean Daily Temperature Range	5% DB	MDBR	14.6	14.9	15.2	15.1	14.8	13.9	13.3	13.7	12.9	14.0	14.4	14.4
		MCDBR	17.0	17.4	17.3	17.4	16.3	15.9	15.0	15.6	15.4	16.9	16.9	16.7
		MCWBR	10.8	10.7	10.4	10.4	9.3	9.1	8.4	8.6	8.4	9.7	10.5	10.5
	5% WB	MCDBR	16.3	16.7	16.4	15.9	15.1	14.7	14.3	14.8	14.2	14.9	15.4	16.0
		MCWBR	11.0	10.9	10.6	10.7	9.5	9.3	8.8	8.7	8.3	9.1	10.1	10.6
Clear-Sky Solar Irradiance	taub	0.271	0.281	0.298	0.331	0.349	0.342	0.347	0.330	0.337	0.308	0.289	0.274	
	taud	2.594	2.549	2.500	2.403	2.392	2.480	2.498	2.559	2.516	2.581	2.571	2.596	
	Ebn at Noon	1001	1008	1001	966	941	940	935	955	946	966	970	983	
	Edh at Noon	85	96	107	121	122	111	109	102	104	92	87	82	
All-Sky Solar Radiation	RadAvg	4.12	5.06	6.00	6.69	6.81	6.81	6.47	6.36	5.38	5.14	4.38	3.90	
	RadStd	0.34	0.51	0.42	0.40	0.28	0.45	0.44	0.34	0.48	0.39	0.40	0.29	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	N/A	N/A	N/A	N/A	-0.99	-0.56	N/A	N/A	N/A	N/A

Nomenclature: See separate page