

MONTERREY, Mexico

WMO: 763930

Lat: 25.6825N

Lon: 100.2717W

Elev: 515

StdP: 95.29

Time Zone: -6.00 (MEX)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	4.2	6.1	-3.6	3.0	13.2	-1.4	3.6	13.8	6.8	15.6	5.1	15.5	1.5	0	0.301

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.2	38.2	23.6	37.2	23.7	36.2	23.7	27.2	34.6	26.2	33.7	25.5	32.8	2.7	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.1	21.6	32.3	24.2	20.4	30.8	23.6	19.6	29.5	89.3	34.6	85.1	33.9	81.7	32.9	33.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 6.1	5.1	4.3	2.0	41.7	1.9	2.0	0.6	43.1	-0.5	44.2	-1.6	45.3	-3.0	46.8		
(5)			0.7	29.6	1.9	1.3	-0.7	30.5	-1.8	31.3	-2.8	32.0	-4.2	32.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	23.4	16.2	18.1	21.0	24.4	27.3	29.0	29.3	29.2	26.8	23.6	19.9	16.1		
	DBStd	6.01	4.80	4.80	4.45	3.94	2.98	1.89	1.88	1.87	2.45	3.45	3.80	4.64		
	HDD10.0	24	11	4	1	0	0	0	0	0	0	1	1	8		
	HDD18.3	319	96	58	27	6	1	0	0	0	0	6	28	99		
	CDD10.0	4924	203	231	342	433	536	569	598	594	505	421	297	196		
	CDD18.3	2177	29	51	110	188	278	319	340	336	255	168	74	29		
	CDH23.3	23444	251	470	1027	1974	3141	3843	4216	4049	2537	1291	443	203		
(13)	CDH26.7	11411	68	171	417	967	1617	2026	2298	2134	1108	437	117	50		
(14)	Wind	WSAvg	1.8	1.5	1.6	1.9	1.9	2.0	2.1	2.2	1.9	1.6	1.4	1.3		
(15) Precipitation	PrecAvg	645	19	18	22	36	56	66	52	86	189	68	28	17		
	PrecMax	1210	114	120	97	182	247	391	366	488	450	170	106	83		
	PrecMin	373	0	0	0	0	0	0	0	1	12	0	0	0		
	PrecStd	177	22	23	23	39	49	65	76	90	116	48	28	21		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.4	34.7	36.3	39.0	40.7	39.4	38.9	38.5	37.3	34.5	32.8	30.7		
		MCWB	17.6	18.4	19.2	22.2	23.4	24.9	23.5	24.5	22.7	22.9	20.2	18.3		
	2%	DB	28.5	31.1	33.8	36.3	37.5	37.4	37.5	37.4	35.2	32.2	29.5	27.7		
		MCWB	17.8	18.4	19.8	21.4	23.8	24.3	23.9	24.0	22.9	22.9	20.4	18.3		
	5%	DB	26.1	28.6	31.4	34.1	35.7	36.1	36.5	36.2	33.6	30.7	27.5	25.5		
		MCWB	17.3	18.2	20.0	21.9	23.9	24.3	24.2	24.0	23.3	22.5	19.7	18.2		
	10%	DB	23.7	26.3	29.0	32.0	33.9	34.8	35.4	35.1	32.1	29.1	25.7	23.1		
		MCWB	16.0	17.8	19.5	21.4	23.9	24.0	24.1	24.0	23.5	22.1	19.2	17.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.5	21.6	24.5	26.1	27.9	28.4	28.2	27.6	26.5	25.7	23.1	21.5		
		MCDB	27.0	29.0	31.0	33.8	36.1	35.2	35.8	35.3	32.5	31.2	28.4	26.8		
	2%	WB	19.0	20.2	22.5	24.1	26.5	27.1	26.5	26.0	25.5	24.5	21.9	20.0		
		MCDB	25.3	26.8	29.4	32.0	33.9	34.3	34.5	34.1	31.4	29.5	26.1	24.7		
	5%	WB	18.0	19.3	21.5	23.2	25.5	26.1	25.6	25.2	24.7	23.7	21.1	19.1		
		MCDB	24.0	25.7	27.9	30.7	32.3	33.3	33.6	33.1	30.5	28.3	24.8	23.6		
	10%	WB	17.0	18.5	20.6	22.4	24.6	25.1	24.8	24.7	24.2	23.0	20.4	18.1		
		MCDB	22.1	24.5	26.4	29.1	31.0	31.9	32.7	32.2	29.8	27.2	24.3	22.4		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.7	10.9	11.1	11.6	10.9	10.8	11.2	10.7	9.3	8.9	9.4	10.2		
		MCDBR	15.1	15.9	16.0	15.5	14.5	13.0	13.1	12.7	11.8	11.1	12.6	14.1		
	5% WB	MCWBR	6.7	6.4	5.6	5.1	4.8	3.7	3.7	3.6	3.4	4.1	5.3	6.5		
		MCWBR	13.2	12.7	12.1	13.1	12.2	11.4	12.0	11.3	9.8	9.1	9.7	11.5		
(40) Clear-Sky Solar Irradiance	taub		0.329	0.350	0.387	0.410	0.442	0.409	0.402	0.393	0.409	0.378	0.362	0.336		
	taud		2.503	2.428	2.333	2.292	2.243	2.393	2.439	2.466	2.395	2.463	2.441	2.489		
	Ebn at Noon		928	929	909	891	857	878	885	895	875	889	882	904		
	Edh at Noon		94	109	126	135	141	121	115	112	117	104	100	92		
(44) All-Sky Solar Radiation	RadAvg		3.79	4.65	5.54	6.22	6.38	6.73	6.54	6.43	5.28	4.82	4.03	3.57		
	RadStd		0.38	0.57	0.54	0.47	0.33	0.40	0.50	0.35	0.50	0.47	0.45	0.36		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	-0.99	-0.56	N/A	N/A	N/A	N/A

Nomenclature: See separate page