

MONTERREY INTL, Mexico

WMO: 763943

Lat: 25.778N

Lon: 100.107W

Elev: 390

StdP: 96.73

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.0	4.9	-8.9	1.8	15.1	-5.2	2.5	15.5	11.4	17.3	10.2	16.3	3.2	330	0.409

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	12.2	38.8	22.8	37.8	22.7	36.8	22.6	26.3	34.2	25.8	33.2	25.3	32.5	5.5	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.2	20.1	29.2	24.0	19.8	29.0	23.2	18.8	28.1	84.4	33.9	82.0	34.3	79.9	31.9	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
10.2	8.9	7.8	DB	0.2	41.3	2.1	1.8	-1.3	42.6	-2.6	43.7	-3.8	44.7	-5.3	46.0
			WB	-1.7	27.7	2.2	1.9	-3.2	29.1	-4.5	30.2	-5.7	31.3	-7.3	32.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.1	15.2	17.8	20.9	24.3	27.1	29.0	29.3	29.4	26.9	23.3	18.9	15.4
	DBStd	6.28	4.80	4.93	4.38	3.76	3.08	1.90	1.91	1.60	2.38	3.55	4.16	4.56
	HDD10.0	28	13	4	1	0	0	0	0	0	0	0	2	8
	HDD18.3	377	119	65	27	4	0	0	0	0	0	7	42	113
	CDD10.0	4827	173	222	338	430	530	571	597	601	506	413	270	177
	CDD18.3	2136	21	49	106	184	272	321	338	343	256	161	61	23
	CDH23.3	22696	239	486	979	1882	2931	3807	4035	4100	2421	1224	388	205
	CDH26.7	11386	71	190	426	953	1517	2059	2214	2252	1100	434	110	59
Wind	WSAvg	3.4	3.1	3.3	3.6	3.8	3.9	4.1	4.0	3.6	2.9	3.0	2.9	3.0
Precipitation	PrecAvg	654	19	18	21	37	51	68	65	84	183	58	27	24
	PrecMax	1146	81	74	94	167	112	219	333	228	417	149	95	97
	PrecMin	421	0	0	0	5	2	12	10	13	20	2	0	1
	PrecStd	182	17	19	21	38	31	45	77	67	114	44	23	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.0	35.2	37.1	39.2	40.8	40.0	39.2	39.0	37.2	35.0	33.1	31.2
		MCWB	16.7	18.0	17.6	20.0	22.0	23.3	24.0	23.5	22.7	22.8	19.0	16.6
	2%	DB	28.8	31.8	34.0	36.9	37.9	38.0	38.0	37.9	35.2	32.8	29.8	28.0
		MCWB	16.7	17.7	19.2	20.9	23.2	23.6	23.1	22.8	23.1	22.8	19.6	17.4
	5%	DB	26.0	28.9	31.1	34.2	36.0	36.2	37.0	36.9	33.9	30.9	27.2	25.2
		MCWB	16.0	17.5	19.0	20.8	23.1	23.0	23.2	22.6	22.9	22.4	19.3	17.0
	10%	DB	23.2	26.1	28.8	32.1	33.9	35.1	35.8	35.2	32.2	29.1	25.2	22.9
		MCWB	15.1	17.2	18.8	20.6	23.0	23.2	22.8	22.8	23.2	21.9	18.7	16.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.2	21.4	23.3	25.1	26.5	27.1	26.7	26.8	26.4	26.0	22.8	20.9
		MCDB	26.0	30.0	31.3	33.9	35.5	35.7	35.3	35.5	32.3	31.0	28.2	26.0
	2%	WB	18.7	20.1	21.7	23.7	25.6	26.1	26.0	26.0	25.7	24.8	21.7	19.6
		MCDB	25.4	26.8	28.2	31.1	33.7	34.1	34.3	33.7	31.5	29.4	25.9	24.3
	5%	WB	17.5	19.2	20.9	22.7	24.8	25.4	25.4	25.4	25.1	23.9	20.9	18.4
		MCDB	23.2	25.6	26.9	29.6	32.2	33.0	33.2	32.7	30.8	28.3	24.8	23.1
	10%	WB	16.3	18.2	20.0	21.9	24.0	24.7	24.7	24.7	24.4	23.2	20.1	17.3
		MCDB	21.2	23.6	25.3	28.0	30.6	31.8	31.6	31.4	29.4	27.1	23.7	21.3
Mean Daily Temperature Range	5% DB	MDBR	12.0	12.6	12.4	12.8	11.7	11.8	12.0	12.2	10.1	10.2	10.5	11.4
		MCDBR	16.5	17.3	16.8	16.6	15.1	13.6	14.0	13.9	12.3	11.8	13.1	15.4
		MCWBR	7.4	7.1	6.0	5.6	4.6	3.9	4.1	3.9	3.8	4.3	5.9	7.3
	5% WB	MCDBR	13.4	13.6	12.4	13.3	12.0	12.0	11.8	11.5	10.2	9.5	10.1	12.0
		MCWBR	6.9	6.4	5.3	5.2	4.7	4.3	4.3	4.2	4.0	4.3	5.4	6.5
Clear-Sky Solar Irradiance	taub	0.328	0.349	0.386	0.410	0.443	0.409	0.403	0.395	0.409	0.376	0.365	0.338	
	taud	2.514	2.442	2.348	2.304	2.251	2.404	2.444	2.467	2.399	2.476	2.439	2.490	
	Ebn at Noon	929	931	910	891	856	878	884	893	875	891	878	901	
	Edh at Noon	93	107	124	133	140	120	115	112	117	103	100	92	
All-Sky Solar Radiation	RadAvg	3.68	4.52	5.42	6.11	6.30	6.78	6.62	6.49	5.30	4.76	3.94	3.45	
	RadStd	0.39	0.59	0.56	0.49	0.36	0.38	0.50	0.34	0.48	0.48	0.46	0.38	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	-0.99	-0.56	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page