

DURANGO, Mexico

WMO: 764230

Lat: 24.0614N

Lon: 104.6006W

Elev: 6142

StdP: 11.71

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.0	36.3	14.0	14.0	56.4	17.2	16.4	54.2	23.4	58.5	17.7	66.6	0.3	50	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	25.7	92.6	62.3	90.1	61.4	87.8	60.6	69.9	82.4	67.7	80.5	66.3	79.6	5.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
66.0	121.0	77.7	63.6	111.1	74.6	62.0	104.9	71.8	38.0	82.7	35.9	80.8	34.5	79.5	81.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	13.4	11.1		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.6	54.5	59.8	63.0	68.5	72.6	74.7	71.3	71.2	68.9	66.0	60.1	56.4
	DBStd	7.62	4.65	4.46	4.72	4.45	3.97	3.78	2.72	2.98	3.00	4.10	4.39	5.26
	HDD50	31	13	1	2	0	0	0	0	0	0	0	1	14
	HDD65	1054	325	152	90	21	5	0	0	1	5	37	152	266
	CDD50	5733	154	274	406	556	702	742	660	657	567	497	305	213
	CDD65	1280	0	6	29	127	241	292	195	193	122	69	6	0
	CDH74	12801	24	232	670	1750	2896	2843	1247	1370	816	697	193	63
	CDH80	4258	0	20	120	601	1295	1296	309	358	152	95	10	2
Wind	WSAvg	3.8	3.5	4.4	4.8	5.1	4.7	3.9	3.5	3.5	2.9	2.7	2.9	3.4
Precipitation	PrecAvg	12.6	0.4	0.2	0.0	0.2	0.7	1.7	3.0	3.1	2.7	0.7	0.4	0.6
	PrecMax	23.9	2.2	1.5	0.2	1.5	5.2	5.7	7.9	6.7	8.2	3.4	3.4	1.7
	PrecMin	3.9	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4	0.0	0.0	0.0
	PrecStd	6.3	0.5	0.4	0.0	0.4	1.1	1.6	2.5	1.9	2.2	0.8	0.7	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.9	82.6	86.6	90.9	95.3	96.0	89.5	89.5	87.1	85.5	81.5	78.5
		MCWB	53.0	55.9	57.7	57.6	63.2	63.3	66.8	64.7	64.6	62.2	60.3	59.0
	2%	DB	73.8	79.6	83.4	88.4	92.4	93.3	86.3	86.4	83.7	82.8	78.4	75.5
		MCWB	52.3	56.0	55.5	56.7	60.9	63.5	65.0	64.5	63.9	61.2	58.0	55.9
	5%	DB	71.3	77.1	80.7	86.3	89.8	90.8	84.0	84.0	81.6	80.8	76.1	73.2
		MCWB	51.1	54.9	54.9	56.2	60.3	62.7	64.6	64.3	63.8	61.1	56.4	53.7
	10%	DB	68.6	74.2	78.1	83.9	87.2	88.1	81.5	81.8	79.3	78.5	73.7	70.6
		MCWB	50.1	53.9	54.4	55.4	58.8	62.6	64.1	64.3	63.4	60.0	55.4	52.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.1	71.3	72.0	60.9	68.4	71.6	71.3	70.6	70.5	69.3	66.0	62.7
		MCDB	71.7	76.5	77.6	85.6	89.0	90.8	86.1	83.5	80.1	80.3	76.5	76.1
	2%	WB	54.5	65.1	64.8	58.9	64.5	67.4	68.3	67.9	67.0	65.0	60.6	57.8
		MCDB	69.5	70.7	70.8	84.9	85.7	84.6	81.8	80.6	78.5	77.0	74.0	72.9
	5%	WB	52.7	58.6	58.0	57.5	62.1	65.8	66.4	66.4	65.6	63.2	58.4	55.1
		MCDB	68.0	70.5	74.7	83.2	84.8	82.6	79.9	79.3	77.3	75.8	71.8	70.2
	10%	WB	51.1	54.7	55.3	56.0	60.4	64.4	64.9	65.2	64.5	61.9	56.5	53.1
		MCDB	66.2	70.6	75.0	81.2	82.7	81.0	78.0	78.0	76.0	74.1	69.8	68.2
Mean Daily Temperature Range		MDBR	28.9	29.2	29.7	30.8	30.1	25.7	21.2	22.0	20.6	26.1	28.0	28.8
	5% DB	MCDBR	32.2	32.6	33.5	33.5	33.5	29.9	25.1	25.6	25.4	28.5	31.5	32.1
		MCWBR	16.3	16.2	14.5	12.9	12.4	9.8	8.6	9.1	9.5	11.6	14.3	16.4
	5% WB	MCDBR	29.1	31.0	30.0	31.8	30.8	24.9	22.9	22.1	21.0	24.0	28.4	30.2
		MCWBR	16.1	21.8	17.6	13.0	13.1	9.4	9.6	9.4	9.0	11.0	14.2	17.1
Clear-Sky Solar Irradiance	taub	0.260	0.276	0.270	0.292	0.346	0.355	0.374	0.361	0.360	0.310	0.273	0.263	
	taud	2.632	2.535	2.574	2.512	2.386	2.412	2.417	2.460	2.445	2.583	2.642	2.639	
	Ebn at Noon	324	323	328	319	299	294	289	294	293	307	316	319	
	Edh at Noon	26	31	31	34	39	38	37	36	36	30	26	25	
All-Sky Solar Radiation	RadAvg	1453	1777	2140	2372	2365	2104	1907	1911	1708	1742	1556	1383	
	RadStd	109	150	88	144	134	153	103	105	123	105	106	80	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	+1.15	N/A	N/A	N/A	N/A

Nomenclature: See separate page