

MAZATLAN, Mexico

WMO: 764580

Lat: 23.2172N

Lon: 106.4111W

Elev: 3

StdP: 101.29

Time Zone: -7.00 (MEC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.9	15.0	8.1	6.7	17.6	9.9	7.6	17.6	6.9	22.1	6.2	23.2	1.5	340	0.293

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.6	33.2	27.3	32.7	27.1	32.3	26.9	28.3	31.9	28.0	31.6	27.6	31.3	3.1	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.3	23.1	31.0	26.9	22.6	30.8	26.5	22.1	30.6	91.4	32.1	89.4	31.7	87.8	31.3	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
6.3	5.5	5.0	DB	12.3	34.4	2.6	1.3	10.5	35.3	8.9	36.0	7.4	36.8	5.5	37.7	37.7
			WB	9.0	29.8	2.3	0.7	7.3	30.4	5.9	30.8	4.6	31.2	2.9	31.8	31.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.3	20.4	20.9	21.3	22.8	25.9	28.7	29.2	29.2	28.9	28.2	25.5	21.8
	DBStd	3.78	1.87	1.96	1.67	1.43	1.60	1.23	1.14	1.17	1.16	1.48	1.59	2.01
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	9	4	2	1	0	0	0	0	0	0	0	0	2
	CDD10.0	5569	323	305	351	383	492	562	596	596	568	564	464	364
	CDD18.3	2537	69	73	93	133	233	312	338	338	318	306	214	109
	CDH23.3	26457	229	259	321	649	2117	3859	4469	4488	4094	3678	1794	499
CDH26.7	10123	8	14	16	46	512	1564	2068	2101	1808	1481	468	38	
Wind	WSAvg	2.2	2.0	2.2	2.3	2.4	2.4	2.4	2.4	2.4	2.4	2.1	2.0	2.0
Precipitation	PrecAvg	707	17	10	4	0	1	32	158	236	243	69	20	15
	PrecMax	1236	136	121	110	6	33	174	510	600	507	246	145	70
	PrecMin	377	0	0	0	0	0	0	4	20	9	0	0	0
	PrecStd	222	34	22	18	1	5	46	121	135	127	69	36	20
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.7	28.0	28.2	28.9	31.4	33.0	33.6	33.7	33.5	33.2	31.7	28.9
		MCWB	20.5	21.6	21.0	22.2	24.6	26.4	27.2	27.8	27.6	27.4	25.2	21.7
	2%	DB	26.4	26.8	26.8	27.9	30.4	32.3	33.0	33.1	32.8	32.4	30.6	27.7
		MCWB	20.5	21.4	20.8	21.9	24.3	26.1	27.0	27.5	27.4	27.0	24.8	21.7
	5%	DB	25.6	25.9	25.9	27.1	29.7	31.7	32.5	32.6	32.3	31.9	29.9	26.9
		MCWB	20.3	20.9	20.5	21.7	24.1	25.9	26.8	27.2	27.3	26.7	24.3	21.5
	10%	DB	24.7	25.0	25.2	26.4	29.1	31.2	31.9	32.1	31.9	31.4	29.1	26.1
		MCWB	19.9	20.3	20.1	21.3	23.8	25.7	26.5	27.0	27.1	26.3	23.8	21.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.3	23.1	22.7	23.7	25.9	27.6	28.6	28.9	28.7	28.5	26.6	23.7
		MCDB	25.7	26.5	26.5	27.5	30.0	31.3	32.4	32.4	32.0	31.9	30.5	27.1
	2%	WB	21.6	22.3	21.9	22.8	25.2	27.0	27.9	28.2	28.2	27.9	25.7	23.0
		MCDB	25.1	25.8	25.6	26.6	29.2	31.2	31.8	31.9	31.6	31.3	29.4	26.6
	5%	WB	21.0	21.6	21.3	22.4	24.7	26.5	27.4	27.8	27.9	27.4	25.2	22.3
		MCDB	24.5	25.0	24.8	26.1	28.6	30.8	31.4	31.6	31.3	30.9	28.8	25.7
	10%	WB	20.3	20.8	20.7	21.8	24.3	26.1	27.0	27.4	27.5	27.0	24.6	21.6
		MCDB	23.9	24.1	24.2	25.6	28.2	30.4	31.1	31.3	31.0	30.5	28.2	25.0
Mean Daily Temperature Range	5% DB	MDBR	8.0	7.5	7.2	7.0	6.1	4.6	5.4	5.6	5.4	6.0	7.2	7.8
		MCDBR	8.6	8.0	7.7	7.4	6.1	4.9	5.7	6.0	5.8	6.0	7.4	8.3
		MCWBR	5.0	4.6	4.1	3.9	3.0	2.4	2.9	2.9	2.9	2.9	4.1	4.7
	5% WB	MCDBR	8.0	7.2	7.0	7.1	5.7	4.6	5.4	5.5	5.4	5.6	6.8	7.5
		MCWBR	5.0	4.4	4.1	4.1	3.0	2.7	3.1	3.0	3.0	3.0	4.2	4.5
Clear-Sky Solar Irradiance	taub	0.320	0.328	0.314	0.349	0.399	0.432	0.440	0.420	0.421	0.369	0.333	0.319	
	taud	2.596	2.550	2.596	2.453	2.371	2.352	2.376	2.439	2.397	2.578	2.625	2.631	
	Ebn at Noon	952	963	988	950	895	859	852	873	869	909	931	941	
	Edh at Noon	88	98	98	115	125	126	123	115	118	95	85	83	
All-Sky Solar Radiation	RadAvg	4.46	5.42	6.64	7.42	7.73	6.97	6.31	6.08	5.40	5.41	4.79	4.20	
	RadStd	0.34	0.46	0.22	0.38	0.25	0.29	0.32	0.21	0.26	0.25	0.27	0.24	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	+0.64	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page