

MAZATLAN INTL, Mexico

WMO: 764593

Lat: 23.161N

Lon: 106.266W

Elev: 38

StdP: 14.68

Time Zone: -7.00 (MEC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	47.7	49.8	37.7	33.3	56.2	41.0	37.9	56.1	46.8	60.6	18.1	75.1	5.6	10	0.358

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	92.9	77.6	91.6	77.4	91.0	77.3	82.1	88.4	81.0	87.4	80.2	86.7	10.3	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.6	159.2	86.1	79.1	151.4	85.1	78.7	149.4	84.9	46.1	88.4	44.9	87.8	44.0	87.2	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
18.1	15.8	13.9	44.4	95.6	3.5	2.3	41.9	97.2	39.9	98.5	37.9	99.8	35.4	101.4		
			41.3	84.6	3.5	1.1	38.8	85.3	36.7	86.0	34.7	86.6	32.2	87.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	75.3	67.2	67.4	68.1	70.9	76.0	82.0	82.9	82.5	81.8	80.1	74.8	68.9
	DBStd	6.92	3.76	3.65	3.16	2.80	3.38	2.67	2.27	2.09	2.12	2.80	3.48	3.80
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	55	21	15	9	0	0	0	0	0	0	0	0	10
	CDD50	9222	532	487	560	628	807	961	1020	1009	955	934	744	585
	CDD65	3803	89	82	104	178	342	511	555	544	505	469	294	130
	CDH74	40187	938	901	1311	1934	3597	5729	6452	6128	5342	4402	2359	1094
	CDH80	14902	167	159	253	508	1404	2388	2730	2506	1964	1743	851	229
Wind	WSAvg	5.9	5.7	6.1	6.4	6.5	6.9	7.1	6.2	5.6	5.2	5.0	5.3	5.2
Precipitation	PrecAvg	33.7	0.6	0.5	0.1	0.0	0.0	1.7	6.7	9.2	9.7	2.7	1.4	0.5
	PrecMax	47.6	11.4	4.8	1.4	1.1	0.1	6.9	14.8	20.8	19.2	8.8	9.1	3.3
	PrecMin	17.5	0.0	0.0	0.0	0.0	0.0	0.0	1.5	2.5	2.9	0.0	0.0	0.1
	PrecStd	7.8	2.2	1.0	0.3	0.2	0.0	2.0	3.3	4.3	4.5	2.3	2.0	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.4	87.5	87.9	89.4	91.6	93.5	93.6	93.3	92.9	92.9	91.5	87.9
		MCWB	68.6	67.7	65.4	66.6	70.7	76.1	78.3	79.0	80.9	79.8	74.6	70.4
	2%	DB	84.0	84.0	84.4	86.3	89.7	91.7	92.8	91.6	91.2	91.1	89.4	84.4
		MCWB	67.3	66.9	65.6	66.9	71.1	75.6	78.0	78.9	80.0	79.1	74.1	69.3
	5%	DB	82.0	82.1	82.6	84.4	88.1	91.2	91.4	91.0	89.7	89.6	87.6	82.5
		MCWB	66.8	66.5	65.8	66.8	71.5	75.4	77.7	78.9	79.6	77.9	73.8	68.8
	10%	DB	79.2	80.2	80.8	82.7	87.4	89.6	89.8	89.5	88.1	88.0	84.6	80.5
		MCWB	65.6	65.7	65.6	67.1	71.5	75.3	77.4	78.7	79.2	77.2	72.0	68.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.0	72.1	71.7	72.8	76.8	79.8	82.3	83.5	83.1	82.6	79.2	74.5
		MCDB	81.7	81.8	81.5	82.3	86.3	88.3	89.6	89.6	89.4	89.3	87.6	82.9
	2%	WB	69.9	69.9	69.6	71.1	75.4	78.5	80.8	82.0	81.9	81.0	76.8	72.3
		MCDB	80.3	79.9	80.2	81.3	85.4	87.1	87.9	87.9	88.0	87.6	85.6	81.3
	5%	WB	68.4	68.4	68.2	69.9	74.2	77.4	79.8	80.9	80.8	79.7	75.2	70.4
		MCDB	79.2	78.8	79.3	80.8	84.2	86.9	87.2	87.2	86.8	86.5	84.1	79.8
	10%	WB	66.8	66.8	66.8	68.8	72.9	76.5	79.0	80.0	79.9	78.6	73.8	69.0
		MCDB	77.5	77.3	78.1	79.9	83.0	86.2	86.8	86.4	85.9	85.6	82.4	78.2
Mean Daily Temperature Range	5% DB	MDBR	26.5	26.0	26.6	25.4	22.0	14.7	13.9	13.6	12.7	16.3	21.8	24.4
		MCDBR	28.2	27.8	28.7	27.7	22.5	15.9	15.5	15.0	14.4	17.2	23.2	25.8
		MCWBR	15.2	14.8	15.1	14.2	10.7	6.7	6.9	7.4	7.3	8.0	11.5	13.7
	5% WB	MCDBR	25.0	24.6	25.2	23.7	18.9	14.3	14.0	13.8	13.2	15.3	20.4	23.2
		MCWBR	14.5	14.0	14.3	12.5	9.2	6.3	7.1	7.8	7.6	7.7	11.0	13.2
Clear-Sky Solar Irradiance	taub	0.318	0.331	0.316	0.353	0.400	0.426	0.437	0.413	0.419	0.368	0.328	0.317	
	taud	2.603	2.534	2.588	2.442	2.370	2.370	2.380	2.457	2.400	2.577	2.652	2.640	
	Ebn at Noon	303	304	313	300	284	274	271	279	276	288	297	299	
	Edh at Noon	28	32	31	37	40	39	39	36	37	30	26	26	
All-Sky Solar Radiation	RadAvg	1418	1727	2114	2360	2449	2181	1976	1914	1704	1713	1524	1338	
	RadStd	110	148	71	119	82	97	101	69	83	83	87	76	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	+1.15	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	+1.15	N/A	N/A	N/A	N/A

Nomenclature: See separate page