

SAN LUIS POTOSI, Mexico

WMO: 765390

Lat: 22.1758N

Lon: 100.9875W

Elev: 6178

StdP: 11.70

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	33.5	36.0	3.2	8.1	73.3	10.0	11.5	68.1	22.9	67.3	21.0	64.9	1.0	0	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	29.4	90.0	57.3	87.8	57.5	85.7	57.5	65.6	76.4	64.6	75.2	63.6	74.1	8.6	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
63.0	108.7	66.7	62.4	106.2	66.2	61.0	101.0	65.7	34.0	76.3	33.1	74.3	32.3	73.0	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	18.2	15.5	28.4	94.2	3.8	2.8	25.6	96.2	23.4	97.9	21.2	99.4	18.4	101.5
			25.0	68.8	2.9	1.4	22.9	69.8	21.3	70.6	19.7	71.3	17.6	72.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.0	55.1	59.1	63.0	68.0	70.6	70.1	68.2	68.4	66.8	63.6	59.1	56.2	(6)
(7)		DBStd	6.68	5.05	5.40	4.81	4.29	3.89	3.14	2.34	2.17	2.80	4.31	4.84	4.90	(7)
(8)		HDD50	34	14	5	1	0	0	0	0	0	0	0	3	11	(8)
(9)		HDD65	1150	306	173	92	21	6	2	3	2	15	75	180	275	(9)
(10)		CDD50	5156	174	259	404	539	639	603	565	570	503	422	277	201	(10)
(11)		CDD65	797	1	7	30	109	180	155	103	107	68	32	4	1	(11)
(12)		CDH74	9202	100	377	883	1776	2174	1315	768	772	385	371	178	103	(12)
(13)		CDH80	2529	3	55	208	663	877	391	121	115	36	47	10	3	(13)
(14)	Wind	WSAvg	5.4	4.7	5.5	6.1	6.2	5.8	6.3	6.3	6.1	5.2	4.5	4.2	4.3	(14)
(15)	Precipitation	PrecAvg	15.7	0.5	0.4	0.4	0.5	1.7	2.0	2.9	2.1	2.9	1.4	0.6	0.3	(15)
(16)		PrecMax	25.8	4.2	2.8	2.1	3.3	5.5	6.6	8.9	6.5	5.9	6.0	2.8	1.7	(16)
(17)		PrecMin	8.8	0.0	0.0	0.0	0.0	0.0	0.0	0.3	0.7	0.3	0.0	0.1	0.0	(17)
(18)		PrecStd	4.3	0.8	0.7	0.6	0.7	1.3	1.5	1.9	1.3	1.5	1.4	0.7	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.4	84.5	88.0	91.7	94.9	91.5	85.9	86.0	83.8	84.2	81.0	79.7	(19)
(20)			MCWB	51.3	54.6	54.9	57.4	59.4	60.4	59.6	61.0	59.9	57.4	55.7	53.3	(20)
(21)		2%	DB	76.9	81.3	84.6	89.3	91.3	87.7	82.8	82.7	80.6	80.9	78.8	76.9	(21)
(22)			MCWB	50.8	52.1	53.7	56.2	57.9	60.1	59.5	60.0	60.3	58.0	54.6	52.3	(22)
(23)		5%	DB	73.8	78.8	82.3	86.4	88.0	84.4	80.8	80.7	78.5	78.6	75.6	74.1	(23)
(24)			MCWB	49.9	52.0	52.6	54.9	57.8	60.3	59.4	59.8	60.2	57.7	54.9	51.6	(24)
(25)		10%	DB	71.2	75.6	79.2	84.2	85.6	81.7	78.7	78.7	75.7	75.3	73.1	71.4	(25)
(26)			MCWB	49.7	51.2	52.5	53.7	58.3	60.2	59.6	60.1	60.3	57.7	54.7	51.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.5	60.6	61.8	62.7	66.2	66.9	66.9	66.1	66.4	64.6	62.2	59.0	(27)
(28)			MCDWB	71.3	75.7	77.6	79.9	79.7	77.9	76.0	77.5	75.2	75.2	73.2	72.5	(28)
(29)		2%	WB	55.2	57.4	58.9	60.8	64.6	65.1	64.8	64.4	64.6	62.7	60.2	56.7	(29)
(30)			MCDWB	67.6	73.3	74.2	76.8	78.1	76.8	72.6	75.5	73.4	72.9	69.7	69.8	(30)
(31)		5%	WB	53.3	55.5	57.0	59.3	63.0	63.9	63.5	63.1	63.5	61.4	58.7	54.9	(31)
(32)			MCDWB	66.4	71.2	72.9	75.1	76.9	75.3	71.5	73.6	71.6	70.9	68.3	68.6	(32)
(33)		10%	WB	51.6	53.8	55.5	58.2	62.1	62.8	62.4	62.2	62.5	60.2	57.3	53.3	(33)
(34)			MCDWB	64.5	69.1	70.8	73.8	75.8	73.6	70.9	72.4	70.3	69.4	66.7	66.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	29.4	31.0	31.7	31.7	29.4	23.9	22.1	22.5	20.1	24.2	27.2	29.6	(35)
(36)			MCDBR	35.4	36.7	36.5	36.0	34.2	29.3	26.6	26.4	24.2	30.1	32.4	35.0	(36)
(37)			MCWBR	16.6	15.4	14.1	13.8	11.5	10.1	9.9	9.4	9.1	12.2	13.7	16.0	(37)
(38)		5% WB	MCDWB	28.8	30.9	31.7	31.4	29.3	24.9	21.0	23.1	19.8	23.3	24.5	29.2	(38)
(39)			MCWBR	15.6	15.1	14.2	12.9	10.7	9.9	9.5	9.2	9.1	10.5	12.3	15.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.294	0.307	0.318	0.341	0.392	0.374	0.364	0.355	0.358	0.335	0.305	0.298	(40)	
(41)		taud	2.498	2.445	2.423	2.361	2.261	2.343	2.396	2.436	2.421	2.473	2.510	2.516	(41)	
(42)		Ebn at Noon	312	313	312	304	286	289	292	296	295	299	305	306	(42)	
(43)		Edh at Noon	31	35	37	40	44	40	38	37	37	33	30	29	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1422	1734	2061	2242	2228	2088	2034	2015	1713	1655	1476	1365	(44)	
(45)		RadStd	107	166	129	117	97	114	167	101	122	122	136	101	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.92	N/A	N/A	N/A	N/A	N/A	N/A	-202	+356	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-202	+356	N/A

Nomenclature: See separate page