

AGUASCALIENTES, Mexico

WMO: 765710

Lat: 21.8511N

Lon: 102.2911W

Elev: 6158

StdP: 11.71

Time Zone: -6.00 (MEX)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.8	37.6	1.4	7.4	62.3	6.3	9.5	62.6	21.7	64.5	18.9	63.8	5.3	0	0.379

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	31.5	90.0	57.9	88.0	57.1	86.2	56.3	65.7	78.6	64.2	77.0	62.9	75.1	7.1	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
62.2	105.6	69.8	60.7	100.1	67.4	59.4	95.2	65.9	34.3	78.0	32.8	77.3	31.8	75.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.6	16.5	13.8	DB	27.9	94.2	3.6	2.4	25.3	95.9	23.2	97.3	21.1	98.7	18.5	100.4
			WB	22.9	68.7	3.9	4.8	20.0	72.2	17.8	75.0	15.6	77.7	12.7	81.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	65.0	56.0	59.9	63.1	67.6	71.4	72.0	69.1	68.9	68.0	65.9	60.6	57.2
	DBStd	6.13	3.56	3.78	3.94	3.00	3.16	3.17	2.26	2.11	2.24	2.61	4.26	3.47
	HDD50	8	2	0	1	0	0	0	0	0	0	0	1	4
	HDD65	918	279	147	77	10	0	0	1	1	3	20	139	241
	CDD50	5481	188	278	408	527	663	660	591	585	540	494	319	228
	CDD65	918	0	4	19	87	199	210	127	121	93	50	8	0
	CDH74	11259	88	459	1018	1947	2612	1896	856	776	564	595	328	120
	CDH80	3149	2	72	232	645	1072	711	166	101	57	62	27	2
(14) Wind	WSAvg	5.7	6.2	6.2	6.3	6.4	5.9	5.9	5.3	5.0	5.0	5.3	5.4	5.6
(15) Precipitation	PrecAvg	23.4	0.6	0.4	0.2	0.4	0.5	2.9	4.0	5.2	5.0	1.6	0.4	0.8
	PrecMax	30.9	2.9	1.7	3.3	2.7	1.6	7.4	7.0	10.6	13.5	4.2	1.3	4.2
	PrecMin	15.0	0.0	0.0	0.0	0.0	0.0	0.4	2.0	1.7	0.4	0.0	0.0	0.0
	PrecStd	4.8	0.9	0.6	0.7	0.7	0.6	2.0	1.6	2.6	3.6	1.0	0.5	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.1	86.2	86.4	91.2	93.3	94.7	87.5	85.0	84.0	84.3	82.7	79.2
		MCWB	52.0	57.2	54.4	56.2	60.9	58.1	60.1	60.2	59.7	58.0	57.6	53.7
	2%	DB	76.8	82.2	84.6	88.1	90.0	89.9	84.2	82.5	82.0	82.1	80.4	77.1
		MCWB	52.0	53.3	53.6	55.2	57.9	58.6	59.6	59.8	60.0	58.5	56.5	52.9
	5%	DB	73.8	79.2	82.6	86.3	88.2	87.5	81.8	80.8	79.2	80.3	78.4	75.2
		MCWB	50.0	51.9	52.5	54.3	57.3	58.6	59.4	60.0	60.4	58.3	55.4	51.7
	10%	DB	71.7	77.0	80.4	84.3	86.2	84.3	79.0	78.8	77.3	77.9	75.4	73.1
		MCWB	49.4	51.4	52.1	53.2	56.2	59.1	59.7	60.2	60.2	58.1	54.4	51.4
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.9	59.6	62.5	62.2	68.9	67.7	65.4	66.6	67.0	65.9	63.7	57.8
		MCDB	70.8	82.7	80.1	85.1	85.0	81.4	76.1	77.1	77.6	77.2	77.5	74.7
	2%	WB	54.8	56.7	57.4	58.9	63.9	64.9	63.3	64.0	64.3	63.4	60.2	55.5
		MCDB	70.3	78.0	78.0	81.7	82.8	79.0	74.8	75.5	75.1	75.5	74.8	71.8
	5%	WB	53.0	54.4	55.1	56.7	61.5	63.0	62.2	62.7	63.0	61.8	58.1	53.9
		MCDB	68.3	74.2	75.8	80.0	80.3	76.5	73.6	73.6	72.7	73.5	72.1	70.1
	10%	WB	51.3	52.6	53.2	55.0	59.8	61.8	61.4	61.8	62.0	60.4	56.5	52.6
		MCDB	66.5	71.4	74.4	78.5	77.0	74.7	73.0	72.6	71.4	71.8	70.0	68.5
(35) Mean Daily Temperature Range	5% DB	MDBR	32.6	34.2	34.8	34.6	31.5	25.9	23.6	22.6	22.6	26.3	30.7	32.0
		MCDBR	36.7	38.3	38.3	37.2	33.9	30.5	27.3	25.4	25.0	29.5	34.1	36.0
		MCWBR	17.6	17.3	17.5	16.2	14.5	11.6	8.8	8.3	8.7	11.5	14.8	16.8
	5% WB	MCDBR	30.0	34.5	33.7	34.0	29.6	24.9	22.7	21.0	20.7	23.5	27.7	32.1
		MCWBR	15.4	17.0	16.5	16.0	13.6	10.5	8.7	9.0	8.8	10.9	13.8	16.3
(40) Clear-Sky Solar Irradiance	taub		0.287	0.306	0.300	0.327	0.387	0.382	0.374	0.366	0.364	0.335	0.299	0.295
	taud		2.496	2.439	2.454	2.341	2.259	2.303	2.365	2.392	2.398	2.468	2.521	2.517
	Ebn at Noon		315	314	318	308	288	286	289	293	293	300	308	308
	Edh at Noon		31	35	36	41	44	42	39	38	37	34	30	30
(44) All-Sky Solar Radiation	RadAvg		1517	1820	2153	2345	2304	2094	2009	1999	1752	1740	1594	1441
	RadStd		110	161	119	120	111	122	151	112	123	107	125	91

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	+0.81	+1.98	N/A	N/A	N/A	N/A	N/A	N/A	-198	+394	+216

Nomenclature: See separate page