

AGUASCALIENTES, Mexico

WMO: 765710

Lat: 21.8511N

Lon: 102.2911W

Elev: 1877

StdP: 80.72

Time Zone: -6.00 (MEX)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.6	3.1	-17.0	1.1	16.8	-14.3	1.4	17.0	9.7	18.1	8.5	17.7	2.4	0	0.379

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	17.5	32.2	14.4	31.1	14.0	30.1	13.5	18.7	25.9	17.9	25.0	17.2	23.9	3.2	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.8	15.1	21.0	16.0	14.3	19.7	15.2	13.6	18.8	61.9	25.6	58.5	25.2	56.1	24.0	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.3	7.4	6.2	DB	-2.3	34.6	2.0	1.3	-3.7	35.5	-4.9	36.3	-6.0	37.0	-7.5	38.0	
			WB	-5.1	20.4	2.2	2.7	-6.6	22.3	-7.9	23.9	-9.1	25.4	-10.7	27.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.3	13.3	15.5	17.3	19.8	21.9	22.2	20.6	20.5	20.0	18.9	15.9	14.0
	DBStd	3.41	1.98	2.10	2.19	1.67	1.76	1.76	1.26	1.17	1.24	1.45	2.36	1.93
	HDD10.0	4	1	0	1	0	0	0	0	0	0	0	1	2
	HDD18.3	510	155	82	43	6	0	0	1	1	2	11	77	134
	CDD10.0	3045	104	154	227	293	368	367	328	325	300	274	177	127
	CDD18.3	510	0	2	11	48	111	117	71	67	52	28	4	0
	CDH23.3	6255	49	255	566	1082	1451	1053	476	431	313	331	182	67
CDH26.7	1749	1	40	129	358	596	395	92	56	32	34	15	1	
Wind	WSAvg	2.6	2.8	2.8	2.8	2.8	2.7	2.6	2.4	2.3	2.2	2.4	2.4	2.5
Precipitation	PrecAvg	595	16	10	6	9	12	73	102	133	128	40	10	20
	PrecMax	785	73	44	83	69	40	188	177	270	342	106	34	107
	PrecMin	381	0	0	0	0	0	10	50	42	10	0	0	0
	PrecStd	122	23	14	19	17	14	51	40	65	92	25	12	29
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.2	30.1	30.2	32.9	34.0	34.8	30.8	29.4	28.9	29.1	28.2	26.2
		MCWB	11.1	14.0	12.4	13.5	16.1	14.5	15.6	15.6	15.4	14.5	14.2	12.0
	2%	DB	24.9	27.9	29.2	31.2	32.2	32.2	29.0	28.1	27.8	27.9	26.9	25.0
		MCWB	11.1	11.8	12.0	12.9	14.4	14.8	15.4	15.5	15.6	14.7	13.6	11.6
	5%	DB	23.2	26.2	28.1	30.1	31.2	30.8	27.7	27.1	26.2	26.8	25.8	24.0
		MCWB	10.0	11.1	11.4	12.4	14.1	14.8	15.2	15.5	15.8	14.6	13.0	10.9
	10%	DB	22.0	25.0	26.9	29.0	30.1	29.0	26.1	26.0	25.2	25.5	24.1	22.8
		MCWB	9.7	10.8	11.1	11.8	13.4	15.0	15.4	15.6	15.7	14.5	12.5	10.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.5	15.4	17.0	16.8	20.5	19.8	18.6	19.2	19.4	18.8	17.6	14.3
		MCDB	21.6	28.1	26.7	29.5	29.5	27.5	24.5	25.1	25.3	25.1	25.3	23.7
	2%	WB	12.7	13.7	14.1	14.9	17.7	18.3	17.4	17.8	18.0	17.5	15.6	13.0
		MCDB	21.3	25.6	25.5	27.6	28.2	26.1	23.8	24.2	24.0	24.2	23.8	22.1
	5%	WB	11.6	12.4	12.8	13.7	16.4	17.2	16.8	17.1	17.2	16.5	14.5	12.2
		MCDB	20.2	23.4	24.3	26.7	26.8	24.7	23.1	23.1	22.6	23.1	22.3	21.2
	10%	WB	10.7	11.4	11.8	12.8	15.4	16.5	16.3	16.6	16.7	15.8	13.6	11.4
		MCDB	19.2	21.9	23.6	25.8	25.0	23.7	22.8	22.6	21.9	22.1	21.1	20.3
Mean Daily Temperature Range	5% DB	MDBR	18.1	19.0	19.3	19.2	17.5	14.4	13.1	12.6	12.5	14.6	17.0	17.8
		MCDBR	20.4	21.3	21.3	20.7	18.8	16.9	15.2	14.1	13.9	16.4	18.9	20.0
		MCWBR	9.8	9.6	9.7	9.0	8.0	6.4	4.9	4.6	4.8	6.4	8.2	9.3
	5% WB	MCDBR	16.7	19.2	18.7	18.9	16.5	13.8	12.6	11.6	11.5	13.1	15.4	17.8
		MCWBR	8.5	9.4	9.2	8.9	7.6	5.8	4.8	5.0	4.9	6.1	7.7	9.0
Clear-Sky Solar Irradiance	taub	0.287	0.306	0.300	0.327	0.387	0.382	0.374	0.366	0.364	0.335	0.299	0.295	
	taud	2.496	2.439	2.454	2.341	2.259	2.303	2.365	2.392	2.398	2.468	2.521	2.517	
	Ebn at Noon	992	989	1004	972	907	903	911	923	925	945	971	971	
	Edh at Noon	98	110	113	129	139	132	124	121	118	106	94	93	
All-Sky Solar Radiation	RadAvg	4.78	5.74	6.79	7.39	7.26	6.60	6.33	6.30	5.52	5.48	5.03	4.54	
	RadStd	0.35	0.51	0.38	0.38	0.35	0.39	0.47	0.35	0.39	0.34	0.39	0.29	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (5 neighbors)	+0.45	+1.10	N/A	N/A	N/A	N/A	N/A	-110	+219	+120	

Nomenclature: See separate page