

GUANAJUATO, Mexico

WMO: 765770

Lat: 21.014N

Lon: 101.266W

Elev: 1999

StdP: 79.50

Time Zone: -6.00 (MEX)

Period: 94-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.8	7.2	-2.5	3.9	14.1	-0.7	4.6	13.9	8.0	16.8	6.3	18.9	0.1	0	0.305

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	14.0	32.1	20.6	30.9	20.0	29.8	19.5	24.7	29.2	23.6	28.3	22.5	27.2	1.9	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	23.6	28.3	22.3	21.8	27.3	21.1	20.2	26.2	88.1	29.2	82.9	28.2	77.7	27.3	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.1	5.1	4.2	DB	2.6	34.3	1.5	0.8	1.5	34.9	0.7	35.3	-0.2	35.8	-1.2	36.4	(4)
			WB	0.0	24.2	1.7	2.3	-1.2	25.8	-2.2	27.2	-3.1	28.4	-4.3	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.4	15.2	17.1	19.0	21.5	22.9	22.2	20.9	21.0	20.4	19.1	17.3	15.6
	DBStd	3.04	1.81	2.08	2.16	1.98	1.86	1.91	1.42	1.33	1.31	1.90	1.85	1.81
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	1
	HDD18.3	301	97	43	16	2	0	0	1	1	2	14	40	85
	CDD10.0	3418	162	198	281	345	398	366	339	341	312	283	218	174
	CDD18.3	676	1	8	38	97	141	116	82	83	63	39	8	1
	CDH23.3	5504	24	167	498	1027	1317	874	475	465	289	251	86	30
	CDH26.7	1469	0	13	92	353	504	295	82	74	29	24	2	0
Wind	WSAvg	1.1	0.9	1.2	1.2	1.2	1.1	1.2	1.2	1.3	1.2	1.1	1.0	0.8
Precipitation	PrecAvg	695	18	9	7	11	36	132	163	152	131	49	10	9
	PrecMax	1246	162	67	52	78	130	562	540	489	320	147	69	40
	PrecMin	295	0	0	0	0	0	0	10	30	20	0	0	0
	PrecStd	256	30	13	11	16	31	103	97	89	77	40	15	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.4	28.2	30.3	33.0	34.0	33.4	30.2	30.0	28.9	28.9	26.8	25.5
		MCWB	16.7	17.0	19.4	20.0	21.9	22.8	20.0	21.2	19.6	19.6	18.2	16.4
	2%	DB	23.9	26.7	28.9	31.5	32.3	31.6	28.7	28.4	27.6	27.3	25.5	24.1
		MCWB	15.2	16.4	18.2	19.6	20.8	21.1	20.1	20.6	19.6	19.0	17.5	16.2
	5%	DB	22.7	25.5	27.6	30.2	31.0	30.0	27.5	27.3	26.5	26.1	24.3	23.0
		MCWB	14.3	15.9	17.8	18.6	19.9	20.8	19.7	20.2	19.4	18.6	16.9	15.8
	10%	DB	21.5	24.2	26.3	28.9	29.7	28.3	26.2	26.1	25.2	24.8	23.1	21.7
		MCWB	13.8	15.3	16.7	18.5	19.3	19.9	19.5	19.7	19.0	17.8	16.2	14.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.1	22.0	24.5	24.9	25.8	26.4	25.1	24.7	23.9	23.2	21.9	20.5
		MCDB	23.8	25.1	28.8	30.1	31.2	30.9	28.0	27.8	26.7	26.2	24.4	23.6
	2%	WB	17.9	19.7	22.2	23.2	23.9	24.4	23.2	23.0	22.0	21.1	19.8	18.6
		MCDB	21.7	24.1	26.4	29.0	30.2	29.5	26.6	26.6	25.2	25.5	23.5	22.2
	5%	WB	16.1	17.8	19.8	21.5	22.3	22.8	21.5	21.6	20.7	19.7	18.4	17.0
		MCDB	20.5	23.3	24.8	28.0	29.0	28.2	25.5	25.8	24.7	24.7	22.9	21.3
	10%	WB	14.5	16.1	17.8	19.6	20.7	21.0	20.1	20.2	19.5	18.5	17.0	15.4
		MCDB	19.8	22.6	24.6	26.9	27.7	26.2	24.4	24.8	23.9	23.5	21.9	20.5
Mean Daily Temperature Range	5% DB	MDBR	13.1	14.1	14.5	14.8	14.0	12.1	11.1	10.9	10.1	11.7	12.9	13.3
		MCDBR	14.9	15.7	16.2	16.5	15.7	14.9	13.1	12.8	12.3	14.0	14.2	14.8
		MCWBR	8.8	9.1	9.4	8.6	8.1	7.8	6.8	7.3	6.7	7.9	8.2	8.9
	5% WB	MCDBR	13.9	14.7	15.4	15.5	14.7	13.8	11.9	12.1	10.8	12.5	13.0	14.1
MCWBR		10.6	10.9	11.7	10.8	9.8	9.6	8.7	8.7	7.6	8.2	9.4	10.4	
Clear-Sky Solar Irradiance	taub	0.304	0.315	0.314	0.347	0.405	0.379	0.373	0.360	0.360	0.342	0.309	0.305	
	taud	2.463	2.427	2.428	2.331	2.218	2.323	2.363	2.402	2.404	2.445	2.489	2.489	
	Ebn at Noon	974	980	991	954	891	906	912	929	930	940	962	962	
	Edh at Noon	102	112	117	131	145	130	125	120	118	109	98	96	
All-Sky Solar Radiation	RadAvg	4.79	5.71	6.70	7.20	6.98	6.40	6.22	6.24	5.49	5.39	4.97	4.61	
	RadStd	0.33	0.52	0.38	0.31	0.32	0.36	0.44	0.32	0.36	0.34	0.40	0.28	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	-0.56	N/A	N/A	-112	+198	N/A

Nomenclature: See separate page