

GUANAJUATO INTL, Mexico

WMO: 765773

Lat: 20.983N

Lon: 101.483W

Elev: 1815

StdP: 81.33

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	4.0	5.8	-12.2	1.6	20.8	-9.9	2.0	19.8	10.2	18.5	9.3	18.0	1.5	30	0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	17.3	34.1	14.7	32.9	14.6	31.8	14.6	19.5	26.0	19.0	25.2	18.6	24.8	3.5	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	16.3	19.6	17.4	15.5	19.5	17.1	15.2	19.5	64.2	25.7	62.6	25.3	60.7	25.1	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.3	8.0	6.7	DB	0.5	36.3	1.3	1.6	-0.5	37.5	-1.2	38.4	-1.9	39.3	-2.8	40.5	(4)
(5)			WB	-2.5	20.8	1.5	0.9	-3.6	21.5	-4.6	22.0	-5.4	22.5	-6.5	23.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	15.4	17.3	19.3	21.8	23.4	22.9	21.4	21.3	20.7	19.6	17.3	15.7	(6)
(7)		DBStd	3.15	1.91	1.98	2.11	1.94	1.71	1.81	1.26	1.16	1.24	1.79	2.00	1.88	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	279	92	39	14	1	0	0	0	0	1	9	42	82	(9)
(10)		CDD10.0	3536	167	204	287	354	417	388	353	349	322	298	219	177	(10)
(11)		CDD18.3	772	1	9	43	104	158	138	95	91	73	48	11	1	(11)
(12)		CDH23.3	9008	156	410	907	1593	1913	1243	612	642	479	542	332	179	(12)
(13)	CDH26.7	3056	12	93	303	718	911	503	128	124	79	122	48	14	(13)	
(14)	Wind	WSAvg	2.5	2.4	2.5	2.7	2.7	2.8	2.4	2.3	2.3	2.3	2.3	2.1	(14)	
(15)	Precipitation	PrecAvg	725	17	6	8	8	37	120	182	152	129	46	9	6	(15)
(16)		PrecMax	1027	133	22	38	41	87	206	366	237	227	106	42	20	(16)
(17)		PrecMin	422	0	0	0	0	1	32	97	91	45	3	0	0	(17)
(18)		PrecStd	166	33	8	12	10	29	46	75	46	51	30	11	6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.0	31.1	32.8	35.8	36.8	35.9	31.2	31.0	30.2	31.1	29.2	28.1	(19)
(20)			MCWB	12.3	13.1	13.6	14.8	15.6	15.4	16.8	17.0	17.1	15.8	14.3	13.0	(20)
(21)		2%	DB	26.8	29.0	31.2	33.8	34.2	33.2	29.1	29.0	28.8	29.1	28.0	26.9	(21)
(22)			MCWB	12.4	12.7	13.3	14.1	14.9	15.2	17.0	17.5	17.7	16.1	14.0	13.0	(22)
(23)		5%	DB	25.1	27.8	29.9	32.2	33.0	31.3	28.0	28.0	27.2	28.0	26.9	25.8	(23)
(24)			MCWB	12.6	12.7	13.1	13.8	14.9	15.9	17.1	17.6	17.6	16.0	14.2	12.8	(24)
(25)		10%	DB	23.8	26.0	28.2	31.0	31.8	29.2	26.9	27.0	26.1	26.8	25.3	23.9	(25)
(26)			MCWB	12.2	12.6	12.7	13.6	14.9	16.3	17.5	17.7	17.5	16.0	13.9	12.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.2	17.7	17.9	18.1	19.9	20.0	19.9	19.9	19.9	19.2	17.2	16.0	(27)
(28)			MCD B	23.3	24.4	27.6	30.3	29.8	27.2	25.3	26.6	26.5	26.4	24.9	25.0	(28)
(29)		2%	WB	14.3	15.1	15.5	16.5	18.1	18.9	19.1	19.2	19.2	18.3	16.4	14.7	(29)
(30)			MCD B	22.9	24.9	26.8	28.5	28.3	25.3	24.5	25.4	25.1	25.3	24.3	23.7	(30)
(31)		5%	WB	13.5	14.1	14.4	15.3	17.2	18.2	18.6	18.7	18.7	17.8	15.5	13.8	(31)
(32)			MCD B	22.5	24.4	26.2	27.9	27.4	24.8	24.2	24.8	24.3	24.5	23.9	22.8	(32)
(33)		10%	WB	12.6	13.2	13.6	14.6	16.5	17.8	18.1	18.2	18.2	17.1	14.8	12.9	(33)
(34)			MCD B	22.0	23.8	25.7	27.6	26.8	24.5	23.9	24.3	23.7	23.5	23.1	22.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	17.3	18.0	18.8	19.1	17.3	13.9	12.1	12.5	12.5	15.1	17.3	17.6	(35)
(36)			MCD BR	19.5	20.6	20.9	20.4	19.2	17.2	14.0	14.2	14.2	17.3	19.0	19.4	(36)
(37)			MCWBR	8.8	8.6	8.2	7.4	6.6	5.4	4.8	5.4	5.7	6.8	7.8	8.5	(37)
(38)		5% WB	MCD BR	16.6	17.3	18.2	18.1	15.7	12.3	11.6	12.2	12.0	13.8	15.9	16.7	(38)
(39)			MCWBR	8.6	8.7	8.0	7.2	6.0	4.6	4.9	5.0	5.0	5.6	7.0	7.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.310	0.324	0.319	0.356	0.417	0.392	0.387	0.374	0.372	0.350	0.316	0.313	(40)	
(41)		taud	2.455	2.410	2.421	2.310	2.194	2.297	2.337	2.373	2.384	2.436	2.478	2.472	(41)	
(42)		Ebn at Noon	968	971	986	945	880	894	899	916	919	932	954	952	(42)	
(43)		Edh at Noon	103	114	118	134	149	133	128	124	121	110	100	98	(43)	
(44)	All-Sky Solar Radiation	RadAvg	4.82	5.74	6.74	7.23	7.01	6.43	6.24	6.25	5.53	5.44	5.01	4.63	(44)	
(45)		RadStd	0.33	0.52	0.38	0.31	0.31	0.36	0.43	0.33	0.36	0.33	0.39	0.28	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	-0.56	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	+0.47	+1.11	-1.65	N/A	-0.30	N/A	N/A	-110	+219	+120

Nomenclature: See separate page