

PUERTO VALLARTA INTL, Mexico

WMO: 766013

Lat: 20.680N

Lon: 105.254W

Elev: 23

StdP: 14.68

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	57.5	59.3	51.4	56.2	64.1	53.4	60.8	64.4	16.0	78.0	14.3	78.0	3.5	30	0.317

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.5	91.8	80.3	91.5	80.1	90.1	79.5	82.7	88.9	81.9	88.3	81.0	87.7	9.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.9	160.8	86.1	80.5	158.5	86.0	79.2	151.4	85.2	46.7	88.7	45.7	89.4	44.8	87.7	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	16.4	14.5	13.0	DB	53.9	95.7	2.6	2.5	52.1	97.5	50.6	99.0	49.1	100.4	47.2	102.3
(5)				WB	50.9	84.8	2.5	1.4	49.1	85.8	47.6	86.7	46.2	87.5	44.4	88.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	77.6	71.2	71.4	71.7	73.8	78.2	82.6	83.2	83.3	83.2	82.1	77.8	72.7
	DBStd	5.50	2.95	2.55	2.57	2.45	2.77	2.23	1.80	1.55	1.80	2.22	2.76	2.92
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	1	1	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10084	656	598	673	714	874	977	1029	1034	995	994	835	705
	CDD65	4610	192	178	208	264	409	527	564	569	545	529	385	240
	CDH74	45625	1189	1086	1332	1937	4000	6046	6614	6517	6036	5883	3445	1540
	CDH80	15962	133	107	116	265	1171	2340	2837	2806	2450	2357	1124	256
Wind	WSAvg	4.8	4.3	4.8	5.2	5.4	5.6	5.7	4.9	4.8	4.3	4.2	4.3	4.2
Precipitation	PrecAvg	43.0	1.0	0.4	0.0	0.1	0.0	5.3	9.7	11.1	9.0	3.2	0.6	0.8
	PrecMax	55.4	3.9	1.9	0.2	2.1	0.8	16.1	17.3	20.8	16.6	10.7	4.6	3.7
	PrecMin	34.5	0.0	0.0	0.0	0.0	0.0	0.9	3.8	5.1	3.1	0.0	0.0	0.0
	PrecStd	5.5	1.3	0.6	0.0	0.4	0.2	3.9	3.8	4.1	3.6	2.5	1.3	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.3	84.5	84.4	85.7	89.7	91.8	93.3	93.4	93.4	92.9	89.9	86.2
		MCWB	70.4	70.9	70.7	72.8	76.4	79.8	80.8	81.5	81.2	79.9	75.7	73.0
	2%	DB	82.7	82.5	82.5	84.0	87.9	91.2	91.6	91.7	91.6	91.2	88.1	84.3
		MCWB	71.1	71.1	71.2	72.5	76.8	79.8	80.2	80.6	80.6	79.7	76.5	72.3
	5%	DB	81.0	80.9	80.9	82.5	86.3	89.7	91.1	91.3	90.2	89.8	87.4	82.6
		MCWB	70.8	70.9	71.0	72.2	76.1	79.4	79.9	80.3	80.1	79.1	76.3	71.8
	10%	DB	80.3	80.2	80.3	81.6	85.7	88.2	89.7	89.8	89.5	89.2	85.9	80.9
		MCWB	70.5	70.7	70.8	71.9	75.8	78.9	79.4	79.7	79.9	79.0	75.6	71.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.4	75.4	74.7	76.1	80.0	82.3	83.5	83.7	83.4	83.0	80.6	77.2
		MCDB	79.9	80.6	80.6	81.8	86.0	89.1	89.0	90.3	90.3	88.1	85.8	82.5
	2%	WB	73.7	73.7	73.4	74.6	78.7	81.0	82.1	82.5	82.3	81.9	79.1	75.5
		MCDB	79.3	79.4	79.6	81.2	85.6	88.0	88.8	89.1	88.6	87.6	85.0	81.0
	5%	WB	72.6	72.6	72.4	73.7	77.8	80.3	81.0	81.4	81.3	80.8	78.1	74.2
		MCDB	78.8	78.6	78.9	80.4	84.7	87.2	88.0	88.3	87.8	87.1	84.4	79.9
	10%	WB	71.6	71.7	71.7	72.8	76.9	79.7	80.4	80.6	80.6	80.0	77.1	72.9
		MCDB	78.3	78.0	78.4	79.6	83.9	86.4	87.5	87.8	87.2	86.3	83.7	78.9
Mean Daily Temperature Range	5% DB	MDBR	18.4	17.8	17.6	16.3	14.2	11.7	13.5	14.1	13.3	14.0	16.5	17.6
		MCDBR	19.2	19.0	18.3	16.8	14.6	13.1	14.6	15.3	14.4	14.8	17.1	18.7
		MCWBR	11.7	11.8	11.4	10.3	8.6	6.4	7.2	7.6	6.7	7.6	9.5	11.2
	5% WB	MCDBR	18.1	18.0	17.4	16.4	13.3	12.1	13.6	14.2	13.5	13.4	15.3	17.2
		MCWBR	11.8	11.8	11.3	10.6	8.2	6.3	7.3	7.6	6.9	7.3	9.1	10.9
Clear-Sky Solar Irradiance	taub	0.341	0.346	0.336	0.364	0.435	0.458	0.437	0.434	0.432	0.388	0.353	0.348	
	taud	2.564	2.521	2.523	2.418	2.289	2.288	2.385	2.387	2.374	2.516	2.586	2.570	
	Ebn at Noon	298	301	307	298	274	266	271	274	274	284	291	291	
	Edh at Noon	30	33	34	38	43	43	39	39	39	32	29	29	
All-Sky Solar Radiation	RadAvg	1465	1748	2098	2305	2314	2010	1906	1869	1659	1650	1539	1390	
	RadStd	113	141	75	91	94	94	122	76	104	104	103	74	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page