

PUERTO VALLARTA INTL, Mexico

WMO: 766013

Lat: 20.680N

Lon: 105.254W

Elev: 7

StdP: 101.24

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.1	15.2	10.8	8.0	17.8	11.9	8.7	18.0	7.2	25.6	6.4	25.6	1.5	30	0.317

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.5	33.2	26.8	33.0	26.7	32.3	26.4	28.1	31.6	27.7	31.3	27.2	31.0	4.3	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	30.1	26.9	22.6	30.0	26.2	21.6	29.6	90.8	31.5	88.5	31.9	86.4	31.0	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.3	6.5	5.8	DB	12.2	35.4	1.4	1.4	11.2	36.4	10.3	37.2	9.5	38.0	8.5	39.1	
			WB	10.5	29.3	1.4	0.8	9.5	29.9	8.7	30.4	7.9	30.8	6.9	31.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	25.3	21.8	21.9	22.1	23.2	25.7	28.1	28.4	28.5	28.4	27.8	25.5	22.6	
		DBStd	3.06	1.64	1.42	1.43	1.36	1.54	1.24	1.00	0.86	1.00	1.23	1.53	1.62	
		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
		HDD18.3	1	1	0	0	0	0	0	0	0	0	0	0	0	
		CDD10.0	5602	364	332	374	397	486	543	572	574	553	552	464	392	
		CDD18.3	2561	107	99	116	147	227	293	313	316	303	294	214	133	
		CDH23.3	25347	661	603	740	1076	2222	3359	3674	3621	3353	3268	1914	856	
		CDH26.7	8868	74	59	64	147	651	1300	1576	1559	1361	1309	624	142	
(14)	Wind	WSAvg	2.1	1.9	2.2	2.3	2.4	2.5	2.5	2.2	2.1	1.9	1.9	1.9	1.9	
(15)	Precipitation	PrecAvg	1092	26	9	1	2	1	135	247	283	228	82	16	21	
		PrecMax	1406	100	49	6	53	20	410	440	528	422	272	117	94	
		PrecMin	877	0	0	0	0	0	22	96	130	80	0	0	0	
		PrecStd	139	32	15	1	10	4	99	97	105	91	64	32	27	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.6	29.2	29.1	29.8	32.0	33.2	34.1	34.1	34.1	33.8	32.2	30.1	
			MCWB	21.3	21.6	21.5	22.7	24.7	26.6	27.1	27.5	27.3	26.6	24.3	22.8	
		2%	DB	28.2	28.1	28.0	28.9	31.1	32.9	33.1	33.2	33.1	32.9	31.2	29.0	
			MCWB	21.7	21.7	21.8	22.5	24.9	26.5	26.8	27.0	27.0	26.5	24.7	22.4	
		5%	DB	27.2	27.2	27.2	28.1	30.2	32.1	32.8	32.9	32.3	32.1	30.8	28.1	
			MCWB	21.5	21.6	21.6	22.3	24.5	26.3	26.6	26.8	26.7	26.2	24.6	22.1	
		10%	DB	26.8	26.8	26.8	27.6	29.8	31.2	32.0	32.1	31.9	31.8	29.9	27.2	
			MCWB	21.4	21.5	21.5	22.2	24.3	26.0	26.3	26.5	26.6	26.1	24.2	21.9	
		0.4%	WB	24.1	24.1	23.7	24.5	26.7	28.0	28.6	28.7	28.6	28.3	27.0	25.1	
			MCDB	26.6	27.0	27.0	27.6	30.0	31.7	31.6	32.4	32.4	31.2	29.9	28.1	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	23.2	23.2	23.0	23.7	26.0	27.2	27.8	28.0	28.0	27.7	26.2	24.2	
			MCDB	26.3	26.3	26.5	27.3	29.8	31.1	31.6	31.7	31.5	30.9	29.5	27.2	
		5%	WB	22.6	22.5	22.4	23.1	25.4	26.8	27.2	27.5	27.4	27.1	25.6	23.4	
			MCDB	26.0	25.9	26.1	26.9	29.3	30.7	31.1	31.3	31.0	30.6	29.1	26.6	
		10%	WB	22.0	22.0	22.0	22.7	25.0	26.5	26.9	27.0	27.0	26.7	25.0	22.7	
			MCDB	25.7	25.6	25.8	26.5	28.8	30.2	30.8	31.0	30.7	30.1	28.7	26.1	
		5% DB	MDBR	10.2	9.9	9.8	9.0	7.9	6.5	7.5	7.8	7.4	7.8	9.1	9.8	
			MCDBR	10.7	10.6	10.2	9.3	8.1	7.3	8.1	8.5	8.0	8.2	9.5	10.4	
			MCWBR	6.5	6.5	6.3	5.7	4.8	3.6	4.0	4.2	3.7	4.2	5.3	6.2	
			MCWBR	10.1	10.0	9.7	9.1	7.4	6.7	7.6	7.9	7.5	7.4	8.5	9.5	
(40)	Clear-Sky Solar Irradiance	taub	0.341	0.346	0.336	0.364	0.435	0.458	0.437	0.434	0.432	0.388	0.353	0.348		
		taud	2.564	2.521	2.523	2.418	2.289	2.288	2.385	2.387	2.374	2.516	2.586	2.570		
		Ebn at Noon	938	950	969	939	864	837	855	863	864	895	917	918		
		Edh at Noon	93	103	106	120	135	134	122	122	122	102	91	90		
(44)	All-Sky Solar Radiation	RadAvg	4.62	5.51	6.62	7.27	7.29	6.34	6.01	5.89	5.23	5.20	4.85	4.38		
		RadStd	0.36	0.45	0.24	0.29	0.30	0.30	0.38	0.24	0.33	0.33	0.33	0.23		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page