

GUADALAJARA INTL, Mexico

WMO: 766133

Lat: 20.522N

Lon: 103.311W

Elev: 1529

StdP: 84.26

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12	1.9	3.1	-9.2	2.1	22.2	-7.1	2.5	20.0	8.4	22.3	7.4	22.2	0.2	210	0.343

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	17.6	33.1	15.2	32.2	14.9	31.2	14.6	20.0	26.4	19.5	25.7	19.1	25.1	4.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.1	15.7	22.5	17.2	14.9	21.6	17.1	14.8	21.5	64.5	26.3	62.7	25.9	61.3	25.4	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.2	5.7	DB	-0.3	35.2	1.7	1.4	-1.6	36.1	-2.6	36.9	-3.6	37.7	-4.9	38.7	(4)
(5)			WB	-2.3	21.3	1.8	1.1	-3.6	22.1	-4.6	22.8	-5.6	23.4	-6.9	24.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.4	14.7	16.7	18.5	20.9	23.1	23.1	21.4	21.3	21.1	19.7	17.0	15.0	(6)	
	DBStd	3.27	1.74	1.89	1.92	1.75	1.54	1.53	0.99	0.97	1.06	1.86	2.16	1.89	(7)	
	HDD10.0	1	0	0	0	0	0	0	0	0	0	0	0	1	(8)	
	HDD18.3	348	112	51	21	2	0	0	0	0	1	9	51	103	(9)	
	CDD10.0	3428	147	187	265	326	407	392	354	352	332	301	209	156	(10)	
	CDD18.3	733	0	4	27	78	148	142	96	93	82	52	10	1	(11)	
	CDH23.3	8325	166	439	938	1561	1971	1127	448	421	368	418	298	168	(12)	
(13)	CDH26.7	2575	8	74	284	674	926	414	50	36	28	47	26	8	(13)	
(14)	Wind	WSAvg	1.7	1.3	1.7	2.1	2.4	2.6	2.3	1.6	1.5	1.4	1.2	1.2	(14)	
(15) Precipitation	PrecAvg	901	17	9	5	4	23	173	230	185	156	52	11	5	(15)	
	PrecMax	1237	265	81	57	70	82	330	386	282	304	129	56	59	(16)	
	PrecMin	587	0	0	0	0	1	56	117	73	63	0	0	0	(17)	
	PrecStd	147	50	19	13	14	21	63	73	55	57	32	15	12	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.8	30.0	32.0	33.9	34.9	34.0	29.1	28.8	28.2	29.1	28.8	27.7	(19)	
		MCWB	13.0	13.7	13.6	14.8	16.0	16.2	18.0	18.3	18.5	17.3	16.8	14.4	(20)	
	2%	DB	26.2	28.2	30.9	32.8	33.2	32.2	28.0	27.8	27.2	28.0	27.2	26.2	(21)	
		MCWB	12.6	13.1	13.4	14.4	15.3	16.4	18.2	18.4	18.3	17.0	15.5	13.5	(22)	
	5%	DB	25.2	27.8	29.2	31.9	32.8	31.0	27.0	26.9	26.8	27.0	26.2	25.1	(23)	
		MCWB	12.2	13.0	13.1	14.0	15.2	16.6	18.3	18.6	18.2	17.0	14.9	13.3	(24)	
	10%	DB	24.0	26.2	28.2	30.9	31.8	29.0	26.0	26.0	25.9	26.0	25.2	24.0	(25)	
		MCWB	11.9	12.6	12.8	13.7	15.0	17.3	18.2	18.4	18.2	16.8	14.7	12.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.2	16.0	16.1	17.1	19.4	20.4	20.2	20.6	20.4	19.9	18.5	16.9	(27)	
		MCDB	23.9	26.3	27.9	29.2	29.5	27.7	26.5	26.5	26.3	26.6	26.4	24.8	(28)	
	2%	WB	14.3	14.9	15.0	15.9	18.1	19.6	19.6	19.7	19.7	19.0	17.3	15.4	(29)	
		MCDB	23.2	25.2	26.8	28.4	27.9	26.8	25.6	25.5	25.4	25.1	24.6	23.5	(30)	
	5%	WB	13.6	14.1	14.2	15.1	17.3	19.0	19.1	19.3	19.2	18.3	16.6	14.4	(31)	
		MCDB	22.4	24.9	26.4	28.3	27.0	25.9	24.9	24.8	24.7	24.2	23.6	22.8	(32)	
	10%	WB	12.9	13.2	13.5	14.4	16.6	18.5	18.6	18.9	18.7	17.9	15.7	13.6	(33)	
		MCDB	21.7	23.7	25.9	28.0	26.4	25.1	24.1	24.1	23.9	23.4	22.4	22.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	19.1	19.5	20.1	19.9	17.6	12.4	10.2	10.2	10.3	13.4	17.5	18.9	(35)	
		MCDBR	21.4	21.5	21.4	21.1	19.1	15.8	11.5	11.4	11.6	14.6	18.5	20.5	(36)	
	5% WB	MCWBR	9.7	8.9	8.5	7.9	6.5	4.9	4.5	4.6	4.7	6.1	8.4	9.6	(37)	
		MCWBR	17.9	18.7	19.3	19.1	15.8	11.7	10.3	10.2	10.2	12.1	15.4	18.0	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.306	0.318	0.305	0.339	0.416	0.422	0.413	0.408	0.395	0.354	0.313	0.312	(40)	
		taud	2.513	2.473	2.497	2.367	2.237	2.263	2.308	2.306	2.366	2.464	2.547	2.534	(41)	
	Ebn at Noon		975	980	1002	962	881	868	876	885	898	929	961	957	(42)	
		Edh at Noon	97	108	109	126	142	138	132	132	123	107	94	93	(43)	
(44) All-Sky Solar Radiation	RadAvg		4.81	5.77	6.83	7.41	7.17	6.43	5.97	5.94	5.38	5.37	5.05	4.62	(44)	
	RadStd		0.37	0.52	0.40	0.32	0.34	0.38	0.36	0.33	0.35	0.34	0.38	0.27	(45)	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.54	+1.41	-1.83	N/A	N/A	N/A	N/A	-107	+228	+130	(46)
(47)	Regional (4 neighbors)	+0.45	+1.24	-1.65	N/A	-0.30	N/A	N/A	-107	+228	+130	(47)

Nomenclature: See separate page