

QUERETARO, Mexico

WMO: 766250

Lat: 20.5634N

Lon: 100.3694W

Elev: 6168

StdP: 11.70

Time Zone: -6.00 (MEX)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	35.9	39.1	16.2	15.7	69.0	20.9	19.7	67.2	24.4	61.1	21.7	64.3	2.3	90	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	31.1	89.7	59.3	87.6	59.0	85.7	59.0	66.3	80.2	65.2	78.7	64.1	77.2	8.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.4	106.2	70.0	61.0	101.3	68.5	60.2	98.3	67.7	34.6	79.8	33.6	79.0	32.7	77.4	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation	n=5 years		n=10 years		n=20 years		n=50 years			
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
21.2	18.8	16.9	DB	32.5	94.1	0.8	2.2	31.9	95.6	31.4	96.9	30.9	98.2	30.3	99.8	
			WB	28.4	70.0	1.4	2.2	27.4	71.6	26.5	72.9	25.7	74.1	24.7	75.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.2	57.0	60.6	64.1	68.4	71.6	70.5	69.0	69.2	68.0	65.2	61.0	58.0
	DBStd	5.80	3.29	3.79	4.22	3.17	3.26	2.55	2.04	1.95	2.45	3.54	4.17	3.35
	HDD50	2	1	0	0	0	0	0	0	0	0	0	0	1
	HDD65	842	248	128	63	6	2	1	1	6	41	128	218	
	CDD50	5563	218	297	438	553	669	615	590	594	540	471	330	248
	CDD65	926	0	4	35	109	206	166	126	130	96	47	7	0
	CDH74	10519	131	507	1030	1801	2357	1335	795	959	595	584	270	155
	CDH80	2746	3	67	226	600	941	415	131	173	82	85	17	6
Wind	WSAvg	6.8	6.3	6.6	7.5	7.5	7.0	7.1	6.5	6.8	6.8	6.8	6.6	5.7
Precipitation	PrecAvg	22.7	0.6	0.2	0.4	0.6	2.0	4.1	4.9	4.3	3.6	1.5	0.2	0.4
	PrecMax	37.2	2.6	0.9	2.0	2.1	8.0	11.7	12.8	10.7	7.9	3.5	1.3	1.8
	PrecMin	10.7	0.0	0.0	0.0	0.0	0.2	0.2	1.1	0.4	0.3	0.0	0.0	0.0
	PrecStd	7.2	0.8	0.3	0.5	0.6	2.0	3.1	3.0	2.9	2.4	1.1	0.4	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.8	84.5	87.3	91.0	93.4	91.6	86.2	86.7	84.7	85.6	82.2	80.5
		MCWB	54.7	55.2	58.4	57.3	59.9	59.2	63.4	63.0	63.0	61.6	59.5	57.9
	2%	DB	77.3	82.2	84.5	87.9	90.0	87.9	83.8	84.2	82.4	82.5	79.1	77.4
		MCWB	53.9	55.1	56.3	57.0	59.6	60.8	62.7	63.4	62.6	60.4	57.8	55.5
	5%	DB	75.1	80.2	82.5	86.0	88.0	85.0	80.9	82.0	80.1	80.3	77.1	75.4
		MCWB	53.1	54.8	55.5	57.0	59.0	60.5	62.1	62.4	62.0	60.3	57.5	54.3
	10%	DB	72.0	77.2	80.4	84.0	85.7	82.2	78.8	79.3	77.3	77.3	74.9	73.2
		MCWB	52.4	54.5	55.1	56.1	58.6	60.6	61.4	61.8	61.8	59.9	56.9	54.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.9	61.8	62.2	63.1	67.1	67.0	66.6	67.4	67.7	66.1	63.8	62.3
		MCDB	72.6	78.2	81.5	81.8	82.1	81.8	81.0	81.1	80.3	79.4	76.7	74.7
	2%	WB	57.0	59.3	60.2	61.0	64.7	65.1	65.3	65.6	65.2	64.2	61.9	59.5
		MCDB	71.5	75.0	78.3	79.1	80.7	78.8	79.2	79.2	76.8	77.4	74.2	73.0
	5%	WB	55.2	57.4	58.5	59.5	62.9	63.7	64.0	64.3	63.9	62.7	60.2	57.2
		MCDB	71.1	74.2	76.3	77.9	78.4	76.3	77.2	77.5	75.2	74.4	71.9	70.7
	10%	WB	53.7	55.7	57.0	58.4	61.5	62.6	62.7	62.9	62.8	61.5	58.7	55.6
		MCDB	69.6	73.1	74.9	76.8	77.0	74.3	75.1	75.2	73.4	72.6	70.6	69.7
Mean Daily Temperature Range	5% DB	MDBR	32.4	33.6	33.5	33.3	31.1	26.3	24.8	26.1	24.4	28.4	29.8	32.4
		MCDBR	37.0	38.4	36.3	35.6	33.8	31.6	27.3	28.6	27.6	32.3	33.2	36.4
		MCWBR	18.1	17.4	15.1	14.1	12.7	11.7	11.4	11.5	11.6	14.3	15.9	18.2
	5% WB	MCDBR	32.9	34.1	33.4	32.8	29.8	25.0	25.4	25.8	23.7	26.6	28.5	32.4
		MCWBR	17.4	17.7	15.4	14.5	12.2	10.3	11.1	11.3	10.7	12.3	14.8	18.0
Clear-Sky Solar Irradiance	taub		0.329	0.338	0.353	0.375	0.433	0.395	0.398	0.379	0.378	0.368	0.333	0.326
	taud		2.413	2.385	2.341	2.298	2.161	2.305	2.314	2.370	2.368	2.387	2.439	2.442
	Ebn at Noon		300	304	302	294	275	283	282	289	290	290	297	298
	Edh at Noon		34	37	41	43	49	42	42	39	39	37	33	32
All-Sky Solar Radiation	RadAvg		1523	1805	2104	2242	2157	1970	1937	1940	1714	1683	1562	1477
	RadStd		103	162	115	89	108	111	134	88	112	108	118	85

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	+0.67	+1.75	-2.97	N/A	N/A	N/A	N/A	N/A	-220	+317	+13

Nomenclature: See separate page