

QUERETARO, Mexico

WMO: 766250

Lat: 20.5634N

Lon: 100.3694W

Elev: 1880

StdP: 80.69

Time Zone: -6.00 (MEX)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.2	3.9	-8.8	2.2	20.6	-6.1	2.8	19.6	10.9	16.2	9.7	18.0	1.0	90	0.426

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	17.3	32.0	15.2	30.9	15.0	29.8	15.0	19.0	26.8	18.4	26.0	17.8	25.1	4.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	15.2	21.1	16.1	14.5	20.3	15.7	14.0	19.8	62.7	26.6	60.3	26.1	58.3	25.2	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.5	8.4	7.6	0.3	34.5	0.5	1.2	-0.1	35.4	-0.4	36.1	-0.6	36.8	-0.9	37.7		
			-2.0	21.1	0.8	1.2	-2.6	22.0	-3.0	22.7	-3.5	23.4	-4.1	24.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.5	13.9	15.9	17.8	20.2	22.0	21.4	20.6	20.6	20.0	18.4	16.1	14.4
	DBStd	3.22	1.83	2.11	2.34	1.76	1.81	1.41	1.13	1.08	1.36	1.97	2.32	1.86
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	1
	HDD18.3	468	138	71	35	3	1	0	1	1	3	23	71	121
	CDD10.0	3091	121	165	243	307	372	342	328	330	300	262	183	138
	CDD18.3	514	0	2	19	61	114	92	70	72	53	26	4	0
	CDH23.3	5844	73	282	572	1001	1309	742	442	533	331	324	150	86
CDH26.7	1526	2	37	126	333	523	231	73	96	46	47	9	3	
Wind	WSAvg	3.0	2.8	3.0	3.4	3.4	3.1	3.2	2.9	3.0	3.0	3.0	3.0	2.6
Precipitation	PrecAvg	577	15	6	9	14	51	104	125	110	91	38	6	10
	PrecMax	944	65	22	51	54	204	297	324	273	201	88	33	46
	PrecMin	273	0	0	0	0	4	6	28	9	7	0	0	0
	PrecStd	183	20	7	12	15	51	79	77	73	60	28	9	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.5	29.2	30.7	32.8	34.1	33.1	30.1	30.4	29.3	29.8	27.9	27.0
		MCWB	12.6	12.9	14.6	14.1	15.5	15.1	17.4	17.2	17.2	16.4	15.3	14.4
	2%	DB	25.1	27.9	29.2	31.1	32.2	31.1	28.8	29.0	28.0	28.1	26.2	25.2
		MCWB	12.2	12.8	13.5	13.9	15.3	16.0	17.1	17.5	17.0	15.8	14.3	13.0
	5%	DB	23.9	26.8	28.1	30.0	31.1	29.4	27.2	27.8	26.7	26.8	25.1	24.1
		MCWB	11.7	12.7	13.1	13.9	15.0	15.8	16.7	16.9	16.7	15.7	14.1	12.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	22.2	25.1	26.9	28.9	29.9	27.9	26.0	26.3	25.2	25.2	23.9	22.9
		MCWB	11.3	12.5	12.8	13.4	14.8	15.9	16.3	16.6	16.6	15.5	13.8	12.4
	0.4%	WB	15.0	16.6	16.8	17.3	19.5	19.5	19.2	19.7	19.8	19.0	17.7	16.9
		MCDB	22.6	25.7	27.5	27.6	27.8	27.7	27.2	27.3	26.8	26.4	24.8	23.7
	2%	WB	13.9	15.2	15.6	16.1	18.2	18.4	18.5	18.7	18.5	17.9	16.6	15.3
		MCDB	22.0	23.9	25.7	26.2	27.1	26.0	26.2	26.2	24.9	25.2	23.4	22.8
Mean Daily Temperature Range	5% DB	WB	12.9	14.1	14.7	15.3	17.1	17.6	17.8	18.0	17.7	17.1	15.7	14.0
		MCDB	21.7	23.4	24.6	25.5	25.8	24.6	25.1	25.3	24.0	23.6	22.2	21.5
	5% WB	WB	12.1	13.2	13.9	14.6	16.4	17.0	17.0	17.2	17.1	16.4	14.8	13.1
		MCDB	20.9	22.8	23.9	24.9	25.0	23.5	24.0	24.0	23.0	22.6	21.4	20.9
	Clear-Sky Solar Irradiance	taub	0.329	0.338	0.353	0.375	0.433	0.395	0.398	0.379	0.378	0.368	0.333	0.326
		taud	2.413	2.385	2.341	2.298	2.161	2.305	2.314	2.370	2.368	2.387	2.439	2.442
Ebn at Noon		947	957	952	927	866	891	889	912	914	914	936	938	
Edh at Noon		108	117	128	135	154	132	131	124	123	116	104	102	
All-Sky Solar Radiation	RadAvg	4.80	5.69	6.63	7.07	6.80	6.21	6.11	6.12	5.40	5.30	4.92	4.66	
	RadStd	0.32	0.51	0.36	0.28	0.34	0.35	0.42	0.28	0.35	0.34	0.37	0.27	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	+0.37	+0.97	-1.65	N/A	N/A	N/A	N/A	-122	+176	+7	

Nomenclature: See separate page