

TUXPAN, Mexico

WMO: 766400

Lat: 20.9600N

Lon: 97.4172W

Elev: 33

StdP: 14.68

Time Zone: -6.00 (MEX)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	51.9	54.6	47.8	49.2	53.9	51.2	56.0	56.7	16.8	63.3	13.3	63.0	4.5	320	0.255

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	13.0	93.9	84.8	92.5	84.0	91.2	83.3	86.9	92.1	85.7	90.7	84.6	89.4	4.9	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
85.5	187.4	91.4	84.3	180.4	89.9	83.3	174.4	88.6	51.6	92.3	50.1	90.9	48.8	89.6	93.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.6	9.4	7.7	47.7	99.5	3.1	4.2	45.5	102.5	43.7	104.9	41.9	107.3	39.7	110.3		
(5)			46.2	88.3	2.6	2.7	44.3	90.2	42.7	91.8	41.2	93.4	39.3	95.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.0	67.2	69.9	74.2	78.7	82.2	83.7	83.1	83.8	81.3	78.1	72.9	68.3
	DBStd	7.34	5.79	5.86	5.08	4.28	3.62	2.45	2.42	2.30	2.61	4.41	5.06	5.43
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	116	47	22	5	0	0	0	0	0	0	1	9	32
	CDD50	9857	535	558	751	862	999	1012	1026	1047	940	872	687	568
	CDD65	4497	116	159	292	412	534	562	561	582	490	408	246	135
	CDH74	41479	319	621	1628	3417	5758	6641	6429	6805	4869	3354	1238	400
	CDH80	14708	22	73	326	1063	2217	2806	2582	2882	1595	955	170	17
(14) Wind	WSAvg	3.2	3.4	3.5	3.6	3.5	3.3	3.4	3.0	2.9	2.9	3.1	3.1	3.2
(15) Precipitation	PrecAvg	59.8	2.0	1.8	1.4	1.9	2.4	7.4	7.5	7.0	12.7	10.0	4.2	1.1
	PrecMax	83.5	3.3	6.8	3.8	4.9	5.8	14.9	24.4	19.3	26.3	24.8	10.4	3.8
	PrecMin	44.3	0.7	0.7	0.3	0.3	0.2	1.1	1.1	1.3	6.0	0.7	1.9	0.0
	PrecStd	10.0	0.8	1.4	1.0	1.4	1.6	4.3	5.7	4.4	5.7	5.7	2.2	1.1
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	82.5	84.5	88.6	94.2	95.4	96.3	94.4	95.0	92.2	90.2	85.6	81.9
		MCWB	76.2	77.1	79.5	83.1	84.5	85.7	85.0	87.2	84.2	83.0	79.4	76.4
	2%	DB	79.4	82.3	85.5	90.4	92.7	93.5	92.3	93.2	90.3	88.2	83.8	79.8
		MCWB	73.8	76.3	78.4	81.5	84.0	84.2	83.9	85.3	83.1	81.8	78.2	75.2
	5%	DB	77.4	80.4	83.5	87.9	90.9	91.7	90.8	91.7	88.9	86.7	82.1	78.1
		MCWB	72.4	75.1	77.3	80.3	83.0	83.7	83.2	83.9	82.4	80.9	77.0	74.0
	10%	DB	75.2	78.2	81.5	85.7	89.1	90.2	89.5	90.4	87.5	85.1	80.3	76.1
		MCWB	71.0	73.6	76.0	79.1	82.0	82.8	82.4	83.0	81.8	80.0	76.0	72.5
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.4	78.9	81.4	85.3	87.6	87.9	87.3	88.5	86.1	85.0	81.3	77.9
		MCDB	80.9	82.6	86.2	91.6	93.3	93.6	92.2	93.8	90.5	88.6	84.5	80.5
	2%	WB	74.6	77.1	79.4	82.5	85.5	86.0	85.5	86.9	84.7	83.1	79.2	76.0
		MCDB	78.1	81.2	84.1	88.7	90.7	91.5	90.6	92.0	88.8	86.8	82.5	78.8
	5%	WB	73.1	75.6	77.9	80.9	84.0	84.8	84.2	85.5	83.4	81.7	77.8	74.7
		MCDB	76.4	79.3	82.4	86.8	88.8	90.1	89.3	90.2	87.5	85.3	80.9	77.3
	10%	WB	71.6	74.1	76.5	79.6	82.6	83.5	82.9	84.0	82.2	80.5	76.5	73.0
		MCDB	74.9	77.3	80.5	84.6	87.6	88.7	87.8	88.3	86.1	84.1	79.4	75.5
(35) Mean Daily Temperature Range	5% DB	MDBR	12.2	12.1	12.3	13.8	13.5	13.0	12.8	13.3	11.2	11.8	11.6	11.6
		MCDBR	14.4	13.9	14.0	16.0	14.9	15.0	14.5	14.8	13.5	13.0	12.6	13.3
	5% WB	MCWBR	9.3	8.2	7.9	8.5	7.8	7.5	7.4	7.6	7.4	7.5	7.5	9.0
		MCWBR	13.8	13.2	13.4	15.3	14.0	14.4	13.7	14.4	13.0	12.4	11.7	12.2
(40) Clear-Sky Solar Irradiance	taub		0.420	0.433	0.470	0.506	0.530	0.475	0.465	0.451	0.449	0.440	0.427	0.421
		taud	2.325	2.291	2.187	2.112	2.057	2.239	2.284	2.322	2.312	2.332	2.328	2.319
	Ebn at Noon		269	273	267	258	249	261	264	269	269	267	265	264
		Edn at Noon	38	41	47	52	54	45	43	41	41	39	37	37
(44) All-Sky Solar Radiation	RadAvg		993	1202	1466	1697	1800	1817	1754	1760	1506	1371	1135	988
	RadStd		128	141	148	143	103	108	128	86	127	97	119	100

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	+0.86	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page