

MEXICO CITY INTL, Mexico

WMO: 766793

Lat: 19.436N

Lon: 99.072W

Elev: 7316

StdP: 11.20

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 37.6	(c) 40.9	(d) 12.3	(e) 13.5	(f) 66.9	(g) 17.2	(h) 17.2	(i) 67.4	(j) 21.8	(k) 64.8	(l) 19.4	(m) 64.3	(n) 5.0	(o) 50	(p) 0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 24.2	(c) 84.4	(d) 54.2	(e) 82.5	(f) 53.8	(g) 80.6	(h) 53.7	(i) 60.6	(j) 71.7	(k) 60.0	(l) 70.9	(m) 59.3	(n) 70.0	(o) 10.4	(p) 340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
57.4	92.8	62.7	57.0	91.3	62.5	55.7	87.1	62.2	30.5	72.7	29.9	71.1	29.4	70.0	67.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
21.0	18.4	16.2	32.6	88.1	3.0	2.1	30.5	89.6	28.7	90.9	27.0	92.1	24.8	93.6
			28.1	63.0	2.6	1.8	26.2	64.3	24.7	65.4	23.2	66.4	21.3	67.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.3	57.0	60.4	63.4	67.0	68.2	67.0	65.4	65.4	64.8	62.8	59.7	57.8	(6)
	DBStd	4.79	3.39	3.74	3.70	3.44	3.46	2.75	1.94	1.97	2.30	3.47	3.75	3.49	(7)
	HDD50	3	1	0	0	0	0	0	0	0	0	0	1	1	(8)
	HDD65	1023	247	132	73	19	10	10	19	18	30	81	160	224	(9)
	CDD50	4844	220	292	417	511	564	511	476	478	443	397	293	242	(10)
	CDD65	389	0	4	25	80	109	71	30	32	23	13	2	0	(11)
	CDH74	3647	33	188	516	913	984	463	131	128	81	114	62	34	(12)
	CDH80	538	0	7	54	172	221	80	2	1	0	1	0	0	(13)
(14) Wind	WSAvg	6.6	5.8	6.4	6.9	7.0	7.0	7.2	6.7	6.7	6.7	6.8	6.0	5.6	(14)
(15) Precipitation	PrecAvg	31.5	0.3	0.4	0.5	0.9	2.4	5.4	6.3	6.5	5.8	2.3	0.5	0.2	(15)
	PrecMax	48.7	1.5	2.6	1.6	2.2	6.7	12.1	9.4	10.5	10.8	6.5	2.3	2.2	(16)
	PrecMin	24.2	0.0	0.0	0.0	0.2	0.2	2.1	3.9	2.2	1.4	0.0	0.0	0.0	(17)
	PrecStd	4.6	0.4	0.5	0.4	0.6	1.4	2.1	1.3	1.8	2.3	1.5	0.7	0.4	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.1	80.8	84.0	87.4	88.0	85.9	79.2	79.1	78.7	79.1	77.4	77.1	(19)
		MCWB	50.4	51.2	53.2	54.2	54.9	55.2	56.4	56.9	56.3	55.0	53.7	51.8	(20)
	2%	DB	74.9	78.7	81.0	84.1	84.5	82.3	77.2	77.1	75.6	77.0	75.5	75.0	(21)
		MCWB	49.7	50.7	52.2	53.5	54.6	55.3	56.8	57.2	57.2	55.2	53.1	51.2	(22)
	5%	DB	73.0	76.6	79.1	82.2	82.5	79.1	75.2	75.2	74.8	75.1	73.7	73.1	(23)
		MCWB	49.7	50.6	51.6	53.2	54.5	55.7	56.8	57.0	57.3	55.3	52.9	50.8	(24)
	10%	DB	70.1	73.8	77.0	80.2	80.2	75.6	73.3	73.4	72.0	73.1	71.7	70.3	(25)
		MCWB	49.3	50.4	51.3	53.1	54.5	56.4	57.4	57.6	57.6	55.6	52.5	50.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	54.0	55.1	56.5	58.3	60.8	61.2	60.9	61.1	61.2	60.8	58.5	55.5	(27)
		MCDB	70.4	72.7	75.1	75.8	76.4	72.7	71.5	71.5	71.8	71.4	71.7	71.0	(28)
	2%	WB	52.6	53.8	55.1	56.7	59.2	60.1	59.9	60.1	60.3	59.6	56.9	54.1	(29)
		MCDB	68.8	71.4	73.7	74.3	74.4	71.2	70.4	70.4	70.3	69.9	68.6	69.1	(30)
	5%	WB	51.5	52.9	54.0	55.7	58.1	59.3	59.0	59.3	59.6	58.4	55.8	53.0	(31)
		MCDB	67.2	70.5	72.8	73.3	72.8	70.1	69.4	69.6	69.2	68.5	67.5	67.8	(32)
	10%	WB	50.6	51.9	53.0	54.8	57.1	58.4	58.2	58.4	58.7	57.6	54.8	51.9	(33)
		MCDB	66.1	69.5	71.6	72.5	71.4	68.9	68.3	68.5	67.7	67.4	66.3	66.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	27.3	28.0	27.9	26.0	24.2	19.9	18.6	18.3	17.2	20.7	25.0	26.8	(35)
		MCDBR	30.7	31.1	30.4	28.6	27.4	24.8	20.9	20.6	20.2	24.6	27.6	29.2	(36)
		MCWBR	12.2	11.6	10.8	9.5	8.5	7.2	6.5	6.6	6.8	8.7	10.4	11.5	(37)
	5% WB	MCDBR	26.6	26.7	26.8	25.3	23.1	18.9	18.2	18.0	16.7	19.0	22.2	25.5	(38)
		MCWBR	11.0	10.5	9.7	8.5	7.2	6.2	6.2	6.5	6.2	7.0	8.7	10.6	(39)
(40) Clear-Sky Solar Irradiance	taub		0.415	0.433	0.446	0.519	0.448	0.516	0.494	0.476	0.359	0.449	0.357	0.403	(40)
	taud		2.088	2.038	2.024	1.870	2.117	1.899	1.980	2.037	2.448	2.070	2.366	2.119	(41)
	Ebn at Noon		271	273	274	255	270	250	256	263	296	265	289	270	(42)
	Edh at Noon		48	53	56	66	51	63	58	55	36	51	36	45	(43)
(44) All-Sky Solar Radiation	RadAvg		1563	1818	2025	2072	1930	1760	1756	1753	1553	1616	1574	1537	(44)
	RadStd		104	148	124	86	126	126	155	97	123	119	120	86	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.85	+2.41	-2.83	N/A	N/A	N/A	N/A	-252	+446	+139
Regional (5 neighbors)	+0.67	+1.89	-3.15	N/A	N/A	N/A	-4	-229	+297	+5

Nomenclature: See separate page