

TLAXCALA, Mexico

WMO: 766830

Lat: 19.3250N

Lon: 98.2472W

Elev: 7375

StdP: 11.18

Time Zone: -6.00 (MEX)

Period: 88-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.1	38.6	25.5	25.7	50.9	29.2	30.6	51.0	13.4	51.4	9.8	51.9	0.6	60	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	26.3	82.7	59.8	80.7	59.8	78.8	59.5	65.3	75.5	64.1	74.5	63.1	73.3	4.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.0	110.1	70.7	60.8	105.1	69.4	59.6	100.9	67.9	34.5	75.7	33.5	74.4	32.6	73.5	71.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.8	8.5	7.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.9	54.6	57.8	60.0	63.3	65.2	64.1	63.1	63.5	63.5	61.3	59.0	55.2
	DBStd	4.59	3.23	3.67	3.71	3.01	3.15	2.59	2.12	2.16	2.19	3.19	3.32	3.83
	HDD50	12	5	2	0	0	0	0	0	0	0	0	0	5
	HDD65	1608	321	203	158	68	35	46	66	54	53	119	182	303
	CDD50	3986	149	219	310	398	472	423	405	419	405	350	269	167
	CDD65	107	0	0	3	16	42	19	6	8	8	4	1	0
	CDH74	2064	6	61	250	502	594	201	109	119	56	96	59	11
	CDH80	221	0	1	30	67	96	18	4	1	1	2	1	0
Wind	WSAvg	2.8	2.7	3.0	3.2	3.0	3.0	2.7	3.0	2.8	2.8	2.6	2.4	2.2
Precipitation	PrecAvg	31.1	0.3	0.2	0.2	1.1	3.0	5.7	6.1	6.6	4.8	2.4	0.4	0.3
	PrecMax	47.9	1.9	0.9	1.0	2.8	8.0	11.7	10.6	12.2	9.4	8.7	1.3	1.9
	PrecMin	22.1	0.0	0.0	0.0	0.0	0.5	2.0	2.1	1.9	1.8	0.1	0.0	0.0
	PrecStd	6.4	0.5	0.3	0.4	0.9	1.9	2.7	2.6	2.8	1.9	2.2	0.4	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.7	78.8	83.2	85.1	86.1	83.1	79.9	79.5	78.1	79.3	78.9	75.4
		MCWB	54.2	58.7	61.0	59.8	59.0	62.6	59.8	62.4	59.9	59.4	57.7	55.1
	2%	DB	71.6	76.2	79.4	82.3	82.8	79.5	77.1	77.0	75.8	76.6	75.8	72.7
		MCWB	54.3	56.6	59.0	59.9	59.2	60.8	59.9	61.6	60.2	59.7	58.3	54.7
	5%	DB	69.2	74.1	77.0	80.2	80.4	76.8	75.1	75.1	73.9	74.4	73.2	70.6
		MCWB	54.0	56.1	58.1	59.4	59.7	60.8	60.0	61.0	60.4	59.6	58.2	54.3
	10%	DB	66.8	71.6	74.3	77.7	78.0	74.1	72.8	72.9	71.9	71.9	70.8	68.0
		MCWB	53.5	55.9	57.4	58.4	59.7	60.4	59.7	60.8	60.4	59.3	57.2	53.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.3	62.7	65.1	65.5	66.7	66.3	64.9	66.3	64.8	64.7	63.7	60.0
		MCDB	68.8	74.4	80.0	78.9	77.1	75.4	74.5	74.7	73.2	73.0	74.2	68.2
	2%	WB	57.4	60.6	62.1	63.5	64.6	64.1	63.3	64.3	63.2	63.0	61.8	58.1
		MCDB	67.1	72.0	75.3	77.0	76.0	74.7	72.8	72.8	71.7	71.4	71.8	67.2
	5%	WB	56.0	58.9	60.6	61.7	62.9	62.8	61.8	62.8	62.1	61.8	60.1	56.6
		MCDB	65.8	69.8	73.3	75.1	74.7	72.8	71.2	71.6	70.4	70.2	70.2	66.5
	10%	WB	54.6	57.2	58.9	60.2	61.4	61.6	60.6	61.5	61.1	60.5	58.5	55.2
		MCDB	64.4	68.3	71.4	74.0	73.4	70.9	69.8	70.2	69.2	68.8	68.3	65.2
Mean Daily Temperature Range	5% DB	MDBR	26.6	28.0	29.1	28.8	26.3	19.9	20.7	20.7	18.2	22.6	26.8	27.2
		MCDBR	30.0	32.1	34.8	34.0	31.1	26.0	25.3	24.7	22.3	27.8	30.4	30.7
		MCWBR	15.9	16.3	18.4	15.9	12.5	11.4	10.7	11.3	9.8	13.6	15.6	14.7
	5% WB	MCDBR	28.3	29.4	32.7	29.3	26.7	21.0	21.2	21.7	18.6	22.5	26.4	26.6
		MCWBR	18.3	18.0	20.3	17.5	14.1	11.1	11.3	12.2	9.4	13.1	15.4	16.2
Clear-Sky Solar Irradiance	taub	0.390	0.390	0.416	0.462	0.425	0.453	0.424	0.420	0.349	0.401	0.345	0.370	
	taud	2.155	2.175	2.115	2.029	2.178	2.096	2.205	2.217	2.465	2.234	2.376	2.224	
	Ebn at Noon	279	287	283	270	277	266	275	278	299	280	293	282	
	Edh at Noon	45	46	51	56	48	52	46	46	36	43	36	41	
All-Sky Solar Radiation	RadAvg	1536	1782	1979	2041	1929	1779	1794	1770	1559	1607	1553	1509	
	RadStd	106	133	126	93	123	114	156	96	130	106	111	79	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (6 neighbors)		+0.67	+1.89	-3.15	N/A	N/A	N/A	-4	-229	+297	+5	

Nomenclature: See separate page