

PUEBLA, Mexico

WMO: 766850

Lat: 19.0550N

Lon: 98.1633W

Elev: 2179

StdP: 77.74

Time Zone: -6.00 (MEX)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	3.1	4.4	-8.1	2.5	15.7	-5.5	3.1	14.8	11.1	16.9	9.9	16.3	2.7	320	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	15.3	28.3	14.5	27.2	14.0	26.1	13.9	17.3	23.3	16.7	22.7	16.1	22.0	3.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
15.8	14.7	18.8	15.0	13.9	18.1	14.3	13.3	17.5	57.8	23.0	55.7	22.8	53.9	22.2	22.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.3	7.9	6.6	-0.3	30.6	1.2	1.2	-1.2	31.4	-1.9	32.1	-2.6	32.8	-3.5	33.6		
			-3.2	19.9	1.3	1.1	-4.1	20.7	-4.9	21.3	-5.6	21.9	-6.6	22.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.5	13.1	14.9	16.4	18.6	19.1	18.3	17.6	17.7	17.4	16.3	14.8	13.7
	DBStd	2.41	1.62	1.60	1.80	1.53	1.55	1.41	1.08	1.11	1.15	1.50	1.64	1.56
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	1
	HDD18.3	760	161	96	64	14	9	16	28	26	31	63	106	144
	CDD10.0	2373	98	137	197	258	283	250	234	238	223	196	144	114
	CDD18.3	90	0	0	3	23	34	16	4	6	4	1	0	0
	CDH23.3	1422	9	57	171	406	401	151	63	64	29	38	18	15
CDH26.7	169	0	1	12	64	74	15	2	1	1	0	0	0	
Wind	WSAvg	2.5	2.7	2.6	2.9	2.8	2.4	2.2	2.1	2.0	2.1	2.5	2.5	2.5
Precipitation	PrecAvg	812	7	6	10	30	81	168	145	149	160	71	17	5
	PrecMax	1021	53	36	47	101	207	330	251	481	623	218	164	45
	PrecMin	632	0	0	0	0	21	62	14	34	67	0	0	0
	PrecStd	125	12	9	12	26	41	73	65	90	92	50	29	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.4	26.4	28.1	30.0	30.2	28.2	26.2	26.2	25.5	25.9	25.2	25.0
		MCWB	11.2	12.4	13.7	14.8	14.8	15.7	14.6	14.7	15.5	13.5	12.9	12.4
	2%	DB	22.9	25.0	26.3	28.2	28.7	26.6	25.0	25.0	24.1	24.2	23.8	23.2
		MCWB	11.2	11.6	12.7	14.1	14.9	15.2	14.4	14.6	15.0	14.1	12.9	11.8
	5%	DB	21.7	23.8	25.1	27.1	27.1	25.1	23.9	24.0	23.1	23.1	22.8	22.1
		MCWB	10.9	11.5	12.4	13.5	14.4	14.9	14.5	14.8	15.1	13.9	12.7	11.4
	10%	DB	20.2	22.5	24.0	25.9	25.8	23.8	22.9	22.9	22.1	22.0	21.3	20.9
		MCWB	10.7	11.3	12.0	13.4	14.4	14.7	14.4	14.7	14.8	13.8	12.5	11.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	13.6	14.7	15.7	17.2	17.7	18.1	17.2	17.5	18.5	17.3	15.6	14.2
		MCDB	21.2	23.4	24.5	26.2	25.8	24.3	22.7	22.5	22.7	22.4	22.0	21.5
	2%	WB	12.6	13.5	14.4	16.0	16.7	17.0	16.2	16.6	17.0	16.2	14.6	13.3
		MCDB	20.5	22.2	23.6	25.2	24.4	23.4	22.0	21.9	21.3	20.9	21.0	20.8
	5%	WB	11.9	12.7	13.5	15.1	16.0	16.1	15.6	15.9	16.2	15.6	13.8	12.6
		MCDB	19.7	21.8	22.9	24.4	23.8	22.1	21.3	21.0	20.6	20.3	20.2	20.1
	10%	WB	11.1	11.9	12.7	14.3	15.3	15.6	15.1	15.4	15.6	14.9	13.2	11.9
		MCDB	18.9	20.8	21.9	23.2	23.0	21.1	20.5	20.4	19.9	19.7	19.4	19.2
Mean Daily Temperature Range	5% DB	MDBR	16.4	17.2	17.1	16.6	15.3	12.2	12.3	12.0	11.0	13.3	15.3	16.4
		MCDBR	18.1	18.8	18.6	18.1	16.9	14.4	13.9	13.4	12.5	15.1	16.6	17.8
		MCWBR	9.3	9.3	8.9	8.3	7.6	6.6	6.3	6.0	6.1	7.3	8.4	9.0
	5% WB	MCDBR	16.4	16.9	17.1	16.8	15.1	12.0	12.1	11.8	10.8	12.3	14.5	16.1
		MCWBR	9.2	9.1	8.8	8.3	7.4	6.2	6.3	6.2	5.8	6.7	7.9	8.7
Clear-Sky Solar Irradiance	taub	0.371	0.367	0.399	0.438	0.429	0.432	0.403	0.400	0.353	0.382	0.339	0.353	
	taud	2.236	2.273	2.182	2.111	2.177	2.182	2.285	2.292	2.454	2.321	2.405	2.307	
	Ebn at Noon	903	930	909	872	869	858	884	893	941	903	934	911	
	Edh at Noon	130	133	151	163	151	149	135	135	113	125	109	118	
All-Sky Solar Radiation	RadAvg	4.88	5.67	6.33	6.57	6.20	5.77	5.87	5.76	5.09	5.18	4.97	4.79	
	RadStd	0.33	0.40	0.37	0.27	0.35	0.33	0.47	0.31	0.40	0.31	0.32	0.23	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.37	+1.05	-1.75	N/A	N/A	N/A	-2	-127	+165	+3

Nomenclature: See separate page