

JALAPA, Mexico

WMO: 766870

Lat: 19.5125N

Lon: 96.9042W

Elev: 4462

StdP: 12.48

Time Zone: -6.00 (MEX)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	45.9	48.1	31.2	30.0	68.8	37.0	38.0	64.9	9.7	63.7	7.5	64.6	1.9	220	0.259

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	17.8	87.1	65.6	84.5	66.1	82.2	66.2	72.7	79.7	71.6	78.2	70.6	77.1	3.3	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
70.7	133.8	76.8	69.5	128.5	75.6	68.6	124.2	74.6	39.6	79.7	38.4	78.3	37.5	77.2	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.9	6.2	5.2	DB	40.9	92.4	2.6	4.0	39.0	95.2	37.5	97.5	36.0	99.8	34.1	102.7	(4)
(5)			WB	37.6	76.8	3.1	2.1	35.4	78.4	33.6	79.6	31.9	80.8	29.7	82.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	66.2	59.7	62.5	65.6	69.4	70.7	69.8	68.7	69.0	68.5	66.5	63.0	60.9
	DBStd	5.51	5.23	5.22	5.86	5.31	4.55	3.03	2.20	1.95	2.00	3.35	3.98	4.58
	HDD50	4	2	1	0	0	0	0	0	0	0	0	0	1
	HDD65	617	177	99	64	21	8	1	2	1	1	23	82	138
	CDD50	5923	304	350	484	582	643	595	580	590	554	511	389	341
	CDD65	1057	14	28	82	153	185	146	116	126	105	69	21	12
	CDH74	5425	122	226	607	1103	1164	624	481	497	238	181	94	88
	CDH80	1067	16	32	155	353	325	94	33	26	5	11	8	9
Wind	WSAvg	2.5	2.3	2.5	2.6	2.5	2.5	2.4	2.5	2.4	2.3	2.7	2.5	2.3
Precipitation	PrecAvg	54.0	1.8	1.8	1.9	2.4	4.2	10.0	8.5	7.0	9.4	4.7	2.0	1.9
	PrecMax	68.8	3.7	4.3	3.5	5.4	11.7	16.6	16.7	19.6	16.5	10.7	6.1	4.8
	PrecMin	40.4	0.2	0.2	0.6	0.4	0.7	3.3	3.6	2.2	3.8	1.0	0.4	0.3
	PrecStd	7.4	0.9	1.0	0.9	1.5	2.8	3.4	3.9	3.7	3.5	2.5	1.5	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.9	83.6	88.2	91.4	91.4	87.5	83.1	82.5	80.7	81.1	81.1	80.8
		MCWB	59.4	61.1	63.7	64.3	65.5	64.9	69.3	68.8	69.3	67.1	63.4	59.7
	2%	DB	77.2	80.1	84.5	86.9	86.7	82.2	80.6	80.4	78.6	78.0	76.8	76.1
		MCWB	61.1	61.8	63.8	64.6	68.4	67.8	67.5	67.9	68.8	67.4	64.5	61.2
	5%	DB	73.0	76.7	80.9	84.1	83.6	79.8	78.6	78.7	76.9	75.9	73.6	72.6
		MCWB	60.7	61.8	63.0	65.4	68.8	68.1	67.5	67.6	68.6	66.6	63.8	61.9
	10%	DB	69.2	73.2	76.9	80.7	80.5	77.6	76.8	77.0	75.1	73.7	70.8	69.5
		MCWB	60.0	61.3	63.1	65.7	68.9	67.7	67.1	67.2	67.9	65.5	62.9	61.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	66.4	68.0	70.8	72.1	74.3	73.4	72.8	73.1	72.6	72.4	69.4	67.4
		MCDB	73.7	76.0	79.8	80.7	82.3	79.5	79.0	79.1	77.5	77.9	74.7	73.9
	2%	WB	64.4	66.1	68.5	70.5	72.7	71.6	70.9	71.0	71.0	70.1	67.4	65.3
		MCDB	71.7	73.7	77.5	79.1	81.0	77.5	77.2	76.9	75.9	75.4	73.2	71.0
	5%	WB	62.5	64.5	66.9	69.1	71.3	70.4	69.7	69.9	69.8	68.6	65.7	63.8
		MCDB	68.9	72.1	75.2	77.8	79.2	76.3	75.9	75.9	74.9	73.5	70.8	69.0
	10%	WB	60.8	62.9	65.2	67.8	69.9	69.3	68.5	68.8	68.8	67.3	64.2	62.3
		MCDB	66.6	69.9	72.7	76.1	77.5	75.1	74.6	74.8	73.6	71.7	68.9	67.2
Mean Daily Temperature Range	5% DB	MDBR	15.8	18.0	18.4	19.3	17.8	16.1	17.0	17.0	14.5	14.8	15.1	15.3
		MCDBR	23.6	24.6	25.2	25.2	22.5	19.5	20.0	19.8	17.3	17.8	19.9	21.5
		MCWBR	13.3	13.4	12.3	11.7	11.2	10.5	11.5	11.4	10.4	10.7	11.6	12.5
	5% WB	MCDBR	20.2	22.1	21.9	21.8	19.6	17.2	18.6	18.3	15.5	15.9	17.4	18.1
		MCWBR	13.3	13.3	12.5	12.1	11.7	10.9	11.8	11.8	10.4	10.7	11.4	12.1
Clear-Sky Solar Irradiance	taub		0.359	0.369	0.401	0.444	0.464	0.416	0.410	0.402	0.406	0.380	0.373	0.364
	taud		2.416	2.390	2.294	2.185	2.145	2.317	2.344	2.367	2.346	2.420	2.388	2.395
	Ebn at Noon		292	295	288	275	266	277	279	283	282	287	284	285
	Edh at Noon		35	37	43	48	49	41	40	40	40	36	35	34
All-Sky Solar Radiation	RadAvg		1237	1473	1669	1794	1781	1740	1743	1697	1496	1441	1317	1235
	RadStd		110	134	135	123	109	98	154	94	128	87	112	76

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (7 neighbors)	N/A	N/A	N/A	N/A	-0.76	-0.59	N/A	N/A	N/A	N/A

Nomenclature: See separate page