

JALAPA, Mexico

WMO: 766870

Lat: 19.5125N

Lon: 96.9042W

Elev: 1360

StdP: 86.02

Time Zone: -6.00 (MEX)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.7	9.0	-0.5	4.3	20.5	2.8	5.4	18.3	4.3	17.6	3.3	18.1	0.9	220	0.259

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	9.9	30.6	18.7	29.1	18.9	27.9	19.0	22.6	26.5	22.0	25.7	21.4	25.1	1.5	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.5	19.1	24.9	20.9	18.4	24.2	20.3	17.7	23.7	74.3	26.5	71.5	25.7	69.4	25.1	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 3.5	2.8	2.3	4.9	33.5	1.5	2.2	3.9	35.1	3.0	36.4	2.2	37.6	1.2	39.3		
(5)			3.1	24.9	1.7	1.2	1.9	25.8	0.9	26.5	0.0	27.1	-1.3	28.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	15.4	16.9	18.7	20.8	21.5	21.0	20.4	20.6	20.3	19.2	17.2	16.1		
	DBStd	3.06	2.91	2.90	3.26	2.95	2.53	1.68	1.22	1.08	1.11	1.86	2.21	2.54		
	HDD10.0	2	1	1	0	0	0	0	0	0	0	0	0	1		
	HDD18.3	343	98	55	36	12	4	1	1	1	1	13	46	77		
	CDD10.0	3291	169	194	269	323	357	331	322	328	308	284	216	189		
	CDD18.3	587	8	16	46	85	103	81	64	70	58	38	12	7		
	CDH23.3	3014	68	126	337	613	647	347	267	276	132	101	52	49		
(13)	CDH26.7	593	9	18	86	196	181	52	18	14	3	6	4	5		
(14)	Wind	WSAvg	1.1	1.0	1.1	1.2	1.1	1.1	1.1	1.1	1.0	1.2	1.1	1.0		
(15) Precipitation	PrecAvg	1372	45	45	49	60	106	253	216	179	238	120	50	49		
	PrecMax	1748	95	108	88	137	297	422	423	497	420	273	154	122		
	PrecMin	1027	4	5	15	9	17	84	92	56	96	25	11	8		
	PrecStd	188	23	25	22	39	71	87	98	94	88	64	38	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	27.7	28.7	31.2	33.0	33.0	30.8	28.4	28.1	27.0	27.3	27.3	27.1		
		MCWB	15.2	16.1	17.6	17.9	18.6	18.3	20.7	20.4	20.7	19.5	17.5	15.4		
	2%	DB	25.1	26.7	29.2	30.5	30.4	27.9	27.0	26.9	25.9	25.5	24.9	24.5		
		MCWB	16.2	16.6	17.7	18.1	20.2	19.9	19.7	19.9	20.5	19.7	18.0	16.2		
	5%	DB	22.8	24.8	27.2	28.9	28.6	26.6	25.9	25.9	24.9	24.4	23.1	22.5		
		MCWB	16.0	16.6	17.2	18.6	20.4	20.1	19.7	19.8	20.3	19.2	17.7	16.6		
	10%	DB	20.7	22.9	24.9	27.1	27.0	25.3	24.9	25.0	23.9	23.2	21.6	20.9		
		MCWB	15.5	16.3	17.3	18.7	20.5	19.8	19.5	19.6	19.9	18.6	17.2	16.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.1	20.0	21.5	22.3	23.5	23.0	22.7	22.8	22.6	22.4	20.8	19.7		
		MCDB	23.1	24.4	26.5	27.1	27.9	26.4	26.1	26.2	25.3	25.5	23.7	23.3		
	2%	WB	18.0	18.9	20.3	21.4	22.6	22.0	21.6	21.7	21.6	21.2	19.7	18.5		
		MCDB	22.0	23.2	25.3	26.2	27.2	25.3	25.1	25.0	24.4	24.1	22.9	21.6		
	5%	WB	16.9	18.0	19.4	20.6	21.9	21.4	20.9	21.0	21.0	20.4	18.7	17.6		
		MCDB	20.5	22.3	24.0	25.4	26.2	24.6	24.4	24.4	23.8	23.1	21.6	20.5		
	10%	WB	16.0	17.1	18.5	19.9	21.1	20.7	20.3	20.5	20.4	19.6	17.9	16.8		
		MCDB	19.2	21.1	22.6	24.5	25.3	23.9	23.7	23.8	23.1	22.1	20.5	19.5		
(35) Mean Daily Temperature Range	5% DB	MDBR	8.8	10.0	10.2	10.7	9.9	9.0	9.5	9.5	8.1	8.2	8.4	8.5		
		MCDBR	13.1	13.7	14.0	14.0	12.5	10.9	11.1	11.0	9.6	9.9	11.0	11.9		
		MCWBR	7.4	7.4	6.8	6.5	6.2	5.8	6.4	6.3	5.8	5.9	6.5	6.9		
	5% WB	MCDBR	11.2	12.3	12.2	12.1	10.9	9.6	10.3	10.2	8.6	8.9	9.7	10.0		
		MCWBR	7.4	7.4	6.9	6.7	6.5	6.1	6.5	6.5	5.8	5.9	6.3	6.7		
(40) Clear-Sky Solar Irradiance	taub		0.359	0.369	0.401	0.444	0.464	0.416	0.410	0.402	0.406	0.380	0.373	0.364		
	taud		2.416	2.390	2.294	2.185	2.145	2.317	2.344	2.367	2.346	2.420	2.388	2.395		
	Ebn at Noon		919	929	907	866	839	873	878	892	889	905	896	899		
	Edh at Noon		109	118	135	152	156	130	127	125	126	113	111	108		
(44) All-Sky Solar Radiation	RadAvg		3.90	4.64	5.26	5.66	5.62	5.48	5.49	5.35	4.72	4.54	4.15	3.89		
	RadStd		0.35	0.42	0.43	0.39	0.34	0.31	0.49	0.30	0.40	0.27	0.35	0.24		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.42	-0.33	N/A	N/A	N/A

Nomenclature: See separate page