

VERACRUZ INTL, Mexico

WMO: 766913

Lat: 19.146N

Lon: 96.187W

Elev: 90

StdP: 14.65

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	58.7	60.7	48.5	50.6	64.0	51.8	57.4	65.9	46.9	69.5	34.4	70.7	7.8	270	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	15.0	95.3	80.2	93.5	80.3	91.8	79.8	82.7	91.6	81.7	90.1	80.9	89.0	11.5	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.6	159.3	87.5	79.2	151.9	85.9	78.9	150.6	85.6	46.7	91.8	45.5	90.1	44.7	90.2	95.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
32.5	23.4	22.0	DB	53.4	102.6	3.3	3.0	51.1	104.7	49.1	106.5	47.3	108.1	44.9	110.3	
			WB	50.8	84.7	3.1	2.9	48.6	86.8	46.8	88.5	45.1	90.2	42.9	92.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.6	71.4	73.1	76.3	80.2	83.3	83.6	82.3	82.4	81.9	79.8	75.8	72.8
	DBStd	5.40	3.86	3.92	4.37	3.85	3.01	2.66	2.20	2.11	2.25	3.16	3.48	3.80
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	6	3	1	0	0	0	0	0	0	0	0	0	2
	CDD50	10439	663	646	814	906	1032	1008	1002	1004	958	925	774	707
	CDD65	4972	201	228	349	456	567	558	537	539	508	460	324	245
	CDH74	46644	949	1262	2477	4089	6321	6514	5980	5969	5402	4274	2180	1227
	CDH80	17813	209	336	849	1560	2687	2847	2441	2451	2103	1476	576	278
Wind	WSAvg	8.4	9.9	9.6	9.6	9.3	7.9	7.4	6.5	6.4	7.3	8.5	9.2	9.6
Precipitation	PrecAvg	60.6	1.0	0.6	0.6	0.7	1.9	9.1	12.0	12.7	12.6	6.1	2.6	0.7
	PrecMax	88.9	4.8	3.3	3.3	2.7	11.3	17.3	23.9	20.5	24.8	28.6	6.9	5.1
	PrecMin	38.5	0.0	0.0	0.0	0.0	0.0	2.1	2.3	4.2	2.4	0.0	0.0	0.0
	PrecStd	12.8	1.2	0.7	0.8	0.7	2.3	4.4	4.6	5.0	5.4	5.6	1.8	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.9	91.1	96.6	98.7	99.0	97.2	93.6	93.6	94.7	93.2	89.9	87.7
		MCWB	76.4	75.0	77.2	79.1	80.6	81.5	80.8	81.0	81.5	81.5	78.8	76.7
	2%	DB	84.5	86.3	91.0	94.0	95.2	94.8	91.8	92.8	92.0	91.2	87.7	85.7
		MCWB	73.7	74.7	77.0	78.8	80.4	81.1	80.4	80.7	80.5	80.1	77.9	75.2
	5%	DB	82.3	84.2	87.6	91.2	93.1	92.8	91.3	91.4	91.1	89.4	85.8	82.8
		MCWB	72.3	73.8	76.4	78.1	79.9	80.6	80.1	80.2	80.1	78.7	75.8	73.1
	10%	DB	79.1	81.0	84.5	88.0	91.0	91.0	89.6	89.8	89.4	87.5	83.9	80.7
		MCWB	70.5	71.8	74.2	77.0	79.2	79.6	79.4	79.4	79.2	77.7	74.2	72.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.8	77.5	79.7	81.5	83.1	83.5	83.2	83.3	83.1	82.7	80.1	77.7
		MCDB	86.7	87.4	91.6	93.3	93.7	93.9	89.1	92.2	92.4	90.7	87.7	86.1
	2%	WB	74.9	75.6	77.9	80.0	81.6	82.1	81.8	81.6	81.6	80.9	78.5	75.9
		MCDB	83.2	84.3	88.5	90.4	91.2	90.8	89.3	89.7	89.9	88.4	85.1	83.5
	5%	WB	73.2	74.4	76.5	78.9	80.6	81.0	80.8	80.7	80.6	79.8	77.2	74.6
		MCDB	80.2	82.1	85.7	88.1	89.2	88.9	88.5	88.8	88.2	86.5	83.8	81.5
	10%	WB	71.9	73.1	75.3	77.8	79.8	80.3	80.0	80.0	79.8	78.8	75.8	73.2
		MCDB	77.7	79.6	82.6	86.0	87.5	87.7	87.2	87.4	86.7	84.7	81.6	79.0
Mean Daily Temperature Range	5% DB	MDBR	15.4	16.0	16.8	16.8	16.1	15.0	14.6	14.7	14.3	14.6	15.0	14.9
		MCDBR	20.3	20.7	21.5	21.2	19.2	16.9	16.1	16.3	16.9	16.7	17.8	18.4
		MCWBR	10.8	10.4	9.8	8.8	7.9	6.7	7.1	7.2	7.5	7.7	9.0	9.6
	5% WB	MCDBR	18.8	19.1	20.1	19.5	17.2	15.9	15.4	15.4	15.5	15.4	16.0	17.5
		MCWBR	10.3	10.1	9.7	8.5	7.6	6.9	7.3	7.2	7.3	7.8	9.0	9.5
Clear-Sky Solar Irradiance	taub	0.393	0.405	0.444	0.506	0.541	0.470	0.458	0.444	0.435	0.420	0.402	0.401	
	taud	2.438	2.405	2.287	2.126	2.047	2.273	2.326	2.358	2.364	2.417	2.436	2.420	
	Ebn at Noon	281	284	275	258	246	262	266	271	274	275	276	274	
	Edh at Noon	34	37	43	51	55	43	41	40	39	36	34	34	
All-Sky Solar Radiation	RadAvg	1125	1375	1626	1806	1824	1820	1805	1752	1545	1410	1245	1132	
	RadStd	111	141	143	120	101	92	143	92	124	86	116	82	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	-1.24	-0.99	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	-0.76	-0.59	N/A	N/A	N/A	N/A

Nomenclature: See separate page