

VERACRUZ INTL, Mexico

WMO: 766913

Lat: 19.146N

Lon: 96.187W

Elev: 27

StdP: 101.00

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.8	16.0	9.1	7.2	17.8	11.0	8.2	18.8	21.0	20.8	15.4	21.5	3.5	270	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	8.3	35.2	26.8	34.2	26.8	33.2	26.6	28.2	33.1	27.6	32.3	27.2	31.7	5.1	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.0	22.8	30.8	26.2	21.7	29.9	26.1	21.5	29.8	90.6	33.2	87.9	32.3	86.2	32.3	35.0

Extreme Annual Design Conditions

Extreme Annual WS							Extreme Annual Temperature										n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years										
Min	Max				Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max										
(a)	(b)	(c)			(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)										
14.5	10.5	9.9			11.9	39.2	1.8	1.7	10.6	40.4	9.5	41.4	8.5	42.3	7.2	43.5										
			DB		10.5	29.3	1.7	1.6	9.2	30.5	8.2	31.4	7.3	32.3	6.1	33.5										
			WB																							

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.9	21.9	22.8	24.6	26.8	28.5	28.7	28.0	28.0	27.7	26.6	24.3	22.7
	DBStd	3.00	2.14	2.18	2.43	2.14	1.67	1.48	1.22	1.17	1.25	1.76	1.94	2.11
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	3	2	1	0	0	0	0	0	0	0	0	0	1
	CDD10.0	5799	368	359	452	503	573	560	557	558	532	514	430	393
	CDD18.3	2762	112	127	194	253	315	310	298	299	282	256	180	136
	CDH23.3	25913	527	701	1376	2272	3512	3619	3322	3316	3001	2374	1211	682
	CDH26.7	9896	116	187	472	867	1493	1582	1356	1362	1168	820	320	154
Wind	WSAvg	3.8	4.4	4.3	4.3	4.1	3.5	3.3	2.9	3.3	3.3	3.8	4.1	4.3
Precipitation	PrecAvg	1540	26	14	15	18	49	230	304	322	321	156	65	19
	PrecMax	2257	123	83	84	69	288	439	607	521	629	726	174	129
	PrecMin	977	0	0	0	0	0	54	59	106	61	0	0	0
	PrecStd	324	30	18	21	19	59	112	118	126	136	141	45	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.1	32.8	35.9	37.1	37.2	36.2	34.2	34.2	34.8	34.0	32.1	31.0
		MCWB	24.6	23.9	25.1	26.1	27.0	27.5	27.1	27.2	27.5	27.5	26.0	24.9
	2%	DB	29.2	30.2	32.8	34.4	35.1	34.9	33.2	33.8	33.3	32.9	30.9	29.9
		MCWB	23.2	23.7	25.0	26.0	26.9	27.3	26.9	27.0	27.0	26.7	25.5	24.0
	5%	DB	28.0	29.0	30.9	32.9	33.9	33.8	32.9	33.0	32.9	31.9	29.9	28.2
		MCWB	22.4	23.2	24.7	25.6	26.6	27.0	26.7	26.8	26.7	26.0	24.3	22.8
	10%	DB	26.2	27.2	29.2	31.1	32.8	32.8	32.0	32.1	31.9	30.8	28.8	27.1
		MCWB	21.4	22.1	23.4	25.0	26.2	26.5	26.3	26.3	26.2	25.4	23.5	22.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.9	25.3	26.5	27.5	28.4	28.6	28.5	28.5	28.4	28.2	26.7	25.4
		MCDB	30.4	30.8	33.1	34.0	34.3	34.4	31.7	33.4	33.6	32.6	30.9	30.1
	2%	WB	23.8	24.2	25.5	26.7	27.6	27.8	27.7	27.5	27.5	27.2	25.8	24.4
		MCDB	28.5	29.1	31.4	32.5	32.9	32.7	31.8	32.1	32.2	31.3	29.5	28.6
	5%	WB	22.9	23.6	24.7	26.0	27.0	27.2	27.1	27.1	27.0	26.6	25.1	23.7
		MCDB	26.8	27.8	29.8	31.1	31.8	31.6	31.4	31.5	31.2	30.3	28.8	27.5
	10%	WB	22.2	22.8	24.1	25.4	26.6	26.8	26.7	26.6	26.6	26.0	24.3	22.9
		MCDB	25.4	26.4	28.1	30.0	30.8	30.9	30.7	30.8	30.4	29.3	27.6	26.1
Mean Daily Temperature Range	5% DB	MDBR	8.6	8.9	9.3	9.3	8.9	8.3	8.1	8.2	8.0	8.1	8.4	8.3
		MCDBR	11.3	11.5	11.9	11.8	10.7	9.4	8.9	9.0	9.4	9.3	9.9	10.2
		MCWBR	6.0	5.8	5.4	4.9	4.4	3.7	4.0	4.0	4.2	4.3	5.0	5.4
	5% WB	MCDBR	10.5	10.6	11.2	10.8	9.6	8.8	8.6	8.5	8.6	8.6	8.9	9.7
		MCWBR	5.7	5.6	5.4	4.7	4.2	3.8	4.0	4.0	4.0	4.3	5.0	5.3
Clear-Sky Solar Irradiance	taub	0.393	0.405	0.444	0.506	0.541	0.470	0.458	0.444	0.435	0.420	0.402	0.401	
	taud	2.438	2.405	2.287	2.126	2.047	2.273	2.326	2.358	2.364	2.417	2.436	2.420	
	Ebn at Noon	885	894	868	814	777	826	838	855	864	867	869	863	
	Edh at Noon	108	117	136	161	172	136	129	126	124	114	107	107	
All-Sky Solar Radiation	RadAvg	3.55	4.33	5.13	5.69	5.75	5.74	5.69	5.52	4.87	4.45	3.92	3.57	
	RadStd	0.35	0.45	0.45	0.38	0.32	0.29	0.45	0.29	0.39	0.27	0.36	0.26	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	-0.69	-0.55	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	-0.42	-0.33	N/A	N/A	N/A	N/A

Nomenclature: See separate page