

VERACRUZ, Mexico

WMO: 766920

Lat: 19.1431N

Lon: 96.1114W

Elev: 62

StdP: 14.66

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	60.6	62.8	50.8	55.2	65.6	53.7	61.5	66.5	38.9	69.7	33.1	69.2	7.5	340	0.334

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	10.2	90.9	80.2	89.9	80.1	89.0	79.9	83.5	87.6	82.5	87.1	81.6	86.7	8.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.4	169.2	86.8	81.2	162.3	85.9	80.2	156.9	85.3	47.5	87.6	46.3	87.3	45.4	86.8	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.9	22.3	17.9	DB	55.9	99.1	3.0	3.2	53.8	101.4	52.0	103.3	50.4	105.1	48.2	107.5	(4)
(5)			WB	52.9	84.9	2.6	1.2	51.1	85.8	49.6	86.6	48.1	87.3	46.3	88.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.4	71.2	72.8	75.9	79.6	82.6	82.8	82.0	82.4	81.7	80.0	76.2	73.1	(6)	
	DBStd	5.07	3.61	3.68	3.82	3.52	2.69	2.21	2.04	1.97	1.82	2.91	3.02	3.48	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	6	3	1	0	0	0	0	0	0	0	0	0	2	(9)	
	CDD50	10362	657	638	804	888	1010	983	992	1005	952	930	787	716	(10)	
	CDD65	4893	195	219	339	438	545	533	527	540	502	465	337	253	(11)	
	CDH74	46698	588	870	2109	3959	6221	6450	6261	6517	5710	4683	2288	1042	(12)	
	CDH80	15026	47	86	365	1017	2211	2520	2385	2600	2024	1356	331	84	(13)	
(14) Wind	WSAvg	7.1	8.1	7.7	7.8	7.8	6.7	6.3	5.7	5.7	6.4	7.8	7.8	7.9	(14)	
(15) Precipitation	PrecAvg	67.4	0.9	0.7	0.8	0.9	2.1	9.5	14.4	13.5	13.8	5.6	3.0	1.3	(15)	
	PrecMax	91.3	4.1	3.1	3.2	3.5	7.6	19.9	33.0	35.0	28.3	11.3	10.2	5.4	(16)	
	PrecMin	48.9	0.0	0.0	0.0	0.0	0.0	1.5	3.0	3.6	3.8	0.5	0.0	0.0	(17)	
	PrecStd	11.4	0.9	0.7	1.0	0.9	2.0	4.8	7.0	6.6	6.1	3.0	2.4	1.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.5	86.5	90.9	94.3	93.5	91.4	90.6	91.0	90.7	90.3	86.7	84.5	(19)	
		MCWB	74.9	75.3	77.1	79.5	79.8	80.8	80.4	80.5	80.6	80.8	78.2	76.3	(20)	
	2%	DB	80.5	82.3	85.8	89.2	90.4	89.8	89.4	89.9	89.4	88.5	84.7	82.2	(21)	
		MCWB	73.5	74.8	76.1	78.1	80.1	80.3	79.9	80.3	80.3	79.7	76.9	75.3	(22)	
	5%	DB	78.8	80.3	83.3	86.6	88.8	88.9	88.5	89.0	88.4	87.2	83.3	80.6	(23)	
		MCWB	72.7	73.9	75.7	78.1	80.0	80.0	79.8	80.1	79.9	78.9	76.1	74.3	(24)	
	10%	DB	77.2	78.7	81.6	84.8	87.5	87.9	87.6	88.1	87.4	85.8	82.0	79.0	(25)	
		MCWB	71.6	73.0	75.0	77.4	79.6	79.7	79.6	79.9	79.5	78.2	75.3	73.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.0	77.5	79.6	82.8	83.7	84.0	83.9	84.5	84.6	83.6	80.7	78.3	(27)	
		MCDB	80.3	82.3	85.4	87.3	88.8	88.2	87.1	87.5	87.8	87.3	84.8	82.3	(28)	
	2%	WB	75.0	75.9	77.9	80.6	82.3	82.7	82.4	82.7	82.3	81.6	79.0	76.7	(29)	
		MCDB	79.1	80.5	83.0	86.1	87.2	87.3	86.8	87.2	87.0	86.5	82.8	80.6	(30)	
	5%	WB	73.8	74.8	76.7	79.2	81.4	81.7	81.2	81.5	81.0	80.5	77.8	75.3	(31)	
		MCDB	77.5	79.1	81.8	84.6	86.4	86.6	86.5	86.9	86.5	85.4	81.8	79.2	(32)	
	10%	WB	72.7	73.9	75.7	78.2	80.5	80.8	80.4	80.7	80.1	79.4	76.6	74.3	(33)	
		MCDB	76.2	77.9	80.4	83.4	85.6	86.0	86.1	86.7	85.9	84.4	80.8	78.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.6	10.5	10.5	10.4	9.7	10.2	10.9	11.1	10.8	10.6	10.6	10.4	(35)	
		MCDBR	12.5	12.3	12.8	12.9	11.1	10.7	11.4	11.4	12.1	11.8	11.9	12.2	(36)	
	5% WB	MCWBR	7.2	6.6	6.2	6.5	5.4	4.9	5.3	5.1	5.6	5.7	6.3	6.9	(37)	
		MCWBR	11.8	11.8	12.0	11.9	10.4	10.3	10.9	11.2	11.5	10.9	11.0	11.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.393	0.405	0.444	0.506	0.541	0.471	0.460	0.446	0.436	0.420	0.402	0.401	(40)	
		taud	2.443	2.409	2.289	2.126	2.048	2.277	2.324	2.360	2.364	2.423	2.442	2.426	(41)	
	Ebn at Noon		281	284	275	258	246	262	265	271	274	275	276	274	(42)	
		Edh at Noon	34	37	43	51	55	43	41	40	39	36	34	34	(43)	
(44) All-Sky Solar Radiation	RadAvg		1123	1375	1634	1818	1836	1827	1808	1753	1544	1409	1243	1129	(44)	
	RadStd		111	142	143	119	102	93	144	93	123	87	117	82	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.43	N/A	-2.14	+0.79	-0.45	-0.52	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	-0.76	-0.59	N/A	N/A	N/A	N/A

Nomenclature: See separate page