

VERACRUZ, Mexico

WMO: 766920

Lat: 19.1431N

Lon: 96.1114W

Elev: 19

StdP: 101.10

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.9	17.1	10.4	7.9	18.7	12.1	8.8	19.2	17.4	20.9	14.8	20.7	3.4	340	0.334

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	5.7	32.7	26.8	32.1	26.7	31.7	26.6	28.6	30.9	28.0	30.6	27.6	30.4	3.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.0	24.2	30.5	27.3	23.2	30.0	26.8	22.4	29.6	92.6	30.9	89.9	30.7	87.7	30.5	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.5	10.0	8.0	DB	13.3	37.3	1.6	1.8	12.1	38.6	11.1	39.6	10.2	40.6	9.0	41.9	(4)
			WB	11.6	29.4	1.4	0.7	10.6	29.9	9.8	30.3	9.0	30.7	7.9	31.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	25.8	21.8	22.7	24.4	26.4	28.1	28.2	27.8	28.0	27.6	26.7	24.6	22.8
	DBStd	2.82	2.01	2.05	2.12	1.95	1.49	1.23	1.13	1.09	1.01	1.62	1.68	1.93
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	3	2	1	0	0	0	0	0	0	0	0	0	1
	CDD10.0	5757	365	354	447	493	561	546	551	558	529	517	437	398
	CDD18.3	2718	108	122	188	243	303	296	293	300	279	258	187	141
	CDH23.3	25943	327	483	1172	2199	3456	3583	3478	3621	3172	2602	1271	579
	CDH26.7	8348	26	48	203	565	1228	1400	1325	1444	1124	753	184	47
Wind	WSAvg	3.2	3.6	3.4	3.5	3.5	3.0	2.8	2.5	2.5	2.9	3.5	3.5	3.5
Precipitation	PrecAvg	1712	23	17	20	22	53	242	367	344	350	143	77	34
	PrecMax	2320	104	80	82	88	194	505	837	889	718	287	259	137
	PrecMin	1242	0	0	0	0	0	37	76	92	97	12	0	0
	PrecStd	289	22	18	25	24	52	123	179	167	155	77	61	33
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.2	30.3	32.7	34.6	34.2	33.0	32.6	32.8	32.6	32.4	30.4	29.1
		MCWB	23.8	24.1	25.1	26.4	26.5	27.1	26.9	27.0	27.0	27.1	25.7	24.6
	2%	DB	27.0	27.9	29.9	31.8	32.5	32.1	31.9	32.2	31.9	31.4	29.3	27.9
		MCWB	23.1	23.8	24.5	25.6	26.7	26.8	26.6	26.8	26.8	26.5	24.9	24.1
	5%	DB	26.0	26.8	28.5	30.4	31.5	31.6	31.4	31.7	31.3	30.7	28.5	27.0
		MCWB	22.6	23.3	24.3	25.6	26.6	26.7	26.5	26.7	26.6	26.1	24.5	23.5
	10%	DB	25.1	25.9	27.5	29.4	30.8	31.1	30.9	31.2	30.8	29.9	27.8	26.1
		MCWB	22.0	22.8	23.9	25.2	26.4	26.5	26.5	26.6	26.4	25.7	24.0	23.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.0	25.3	26.4	28.2	28.7	28.9	28.8	29.1	29.2	28.7	27.1	25.7
		MCDB	26.9	28.0	29.6	30.7	31.6	31.2	30.6	30.9	31.0	30.7	29.3	28.0
	2%	WB	23.9	24.4	25.5	27.0	27.9	28.2	28.0	28.2	27.9	27.5	26.1	24.9
		MCDB	26.2	26.9	28.3	30.0	30.7	30.7	30.4	30.7	30.5	30.3	28.2	27.0
	5%	WB	23.2	23.8	24.8	26.2	27.4	27.6	27.3	27.5	27.2	26.9	25.4	24.1
		MCDB	25.3	26.2	27.7	29.2	30.2	30.3	30.3	30.5	30.3	29.7	27.7	26.2
	10%	WB	22.6	23.3	24.3	25.6	27.0	27.1	26.9	27.0	26.7	26.3	24.8	23.5
		MCDB	24.6	25.5	26.9	28.6	29.8	30.0	30.1	30.4	29.9	29.1	27.1	25.6
Mean Daily Temperature Range	5% DB	MDBR	5.9	5.8	5.9	5.8	5.4	5.7	6.1	6.1	6.0	5.9	5.9	5.8
		MCDBR	6.9	6.8	7.1	7.2	6.1	5.9	6.3	6.4	6.7	6.6	6.6	6.8
		MCWBR	4.0	3.7	3.4	3.6	3.0	2.7	2.9	2.9	3.1	3.2	3.5	3.8
	5% WB	MCDBR	6.6	6.5	6.7	6.6	5.8	5.7	6.1	6.2	6.4	6.1	6.1	6.4
	MCWBR	4.3	3.9	3.7	3.9	3.4	3.4	3.6	3.7	3.5	3.6	4.1	4.1	
Clear-Sky Solar Irradiance	taub	0.393	0.405	0.444	0.506	0.541	0.471	0.460	0.446	0.436	0.420	0.402	0.401	
	taud	2.443	2.409	2.289	2.126	2.048	2.277	2.324	2.360	2.364	2.423	2.442	2.426	
	Ebn at Noon	885	894	868	814	777	826	836	854	863	868	869	864	
	Edh at Noon	107	116	135	161	172	136	130	126	124	113	106	106	
All-Sky Solar Radiation	RadAvg	3.54	4.33	5.15	5.73	5.79	5.76	5.70	5.53	4.87	4.44	3.92	3.56	
	RadStd	0.35	0.45	0.45	0.38	0.32	0.29	0.45	0.29	0.39	0.27	0.37	0.26	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.24	N/A	-1.19	+0.44	-0.25	-0.29	N/A	N/A	N/A	N/A
Regional (3 neighbors)		N/A	N/A	N/A	N/A	-0.42	-0.33	N/A	N/A	N/A	N/A

Nomenclature: See separate page