

CAMPECHE INTL, Mexico

WMO: 766950

Lat: 19.8364N

Lon: 90.5075W

Elev: 5

StdP: 101.26

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.6	16.2	11.8	8.6	20.2	13.0	9.3	20.1	10.3	24.1	9.6	24.6	0.7	90	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	10.9	37.2	25.8	36.1	25.6	35.1	25.9	29.5	33.7	28.6	32.6	27.9	31.9	3.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.4	24.7	32.8	27.5	23.4	31.7	26.9	22.5	30.9	96.8	33.6	92.5	32.7	89.2	32.3	34.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.6	8.4	7.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	27.1	23.6	25.1	26.7	28.6	29.4	29.0	28.9	28.8	28.2	27.0	25.1	24.8
	DBStd	2.77	2.57	2.66	2.45	2.51	2.19	1.35	1.09	1.03	1.04	1.70	2.21	2.23
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	1	0	1	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6243	422	423	517	558	601	569	586	582	544	527	453	460
	CDD18.3	3202	163	191	259	308	343	319	328	323	294	268	203	202
	CDH23.3	30538	993	1515	2370	3386	3974	3428	3447	3261	2792	2392	1568	1411
Wind	WSAvg	3.4	3.3	3.6	4.1	4.3	4.2	3.5	3.2	3.1	2.7	2.9	3.1	3.1
	PrecAvg	1227	31	23	14	20	64	200	182	225	233	153	49	33
	PrecMax	1932	93	80	69	73	197	410	361	370	709	536	164	96
	PrecMin	845	0	0	0	0	14	76	66	122	99	45	4	1
	PrecStd	208	22	22	15	21	40	80	68	58	127	99	37	21
	DB	33.5	35.2	37.0	39.1	39.0	37.1	36.9	36.1	35.0	34.1	32.9	33.2	33.2
	MCWB	24.5	25.0	25.6	26.7	26.7	27.0	26.2	27.6	27.8	28.0	26.9	26.2	26.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	31.9	33.8	35.1	37.1	37.2	35.8	35.2	35.0	33.9	32.8	31.6	32.0	32.0
	2% MCWB	24.1	24.1	24.7	25.2	25.4	26.6	26.3	27.2	27.5	27.0	25.7	25.0	25.0
	5% DB	30.1	32.1	33.8	35.8	35.9	34.7	34.1	34.0	33.0	31.8	30.5	30.8	30.8
	5% MCWB	23.7	24.0	24.2	24.6	25.5	26.3	26.5	27.2	27.1	26.6	25.2	24.8	24.8
	10% DB	28.1	30.2	31.8	33.4	34.0	33.1	33.1	32.9	32.0	30.8	29.2	29.1	29.1
	10% MCWB	23.5	23.6	23.9	24.6	25.5	26.3	26.5	26.9	26.8	26.2	24.6	24.4	24.4
	WB	26.8	27.6	28.1	29.2	29.5	30.3	29.7	30.4	30.0	29.2	27.8	27.7	27.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	31.2	32.6	33.9	35.3	35.0	35.1	33.7	34.5	33.2	32.4	31.3	31.5	31.5
	2% WB	25.1	26.1	26.5	27.6	28.2	28.5	28.6	28.9	28.5	27.8	26.8	26.5	26.5
	2% MCDB	29.0	31.0	31.9	32.9	33.0	32.5	32.3	32.6	32.0	31.6	30.0	29.9	29.9
	5% WB	24.5	25.0	25.6	26.7	27.4	27.6	27.6	28.0	27.6	27.0	26.1	25.6	25.6
	5% MCDB	28.1	29.0	30.7	31.9	32.0	31.7	31.6	31.8	31.2	30.3	29.3	28.9	28.9
	10% WB	23.8	24.2	25.0	26.0	26.7	26.9	27.0	27.3	27.1	26.5	25.3	24.9	24.9
	10% MCDB	27.1	28.4	29.7	31.3	31.6	31.3	31.5	31.2	30.8	29.7	28.4	28.0	28.0
Mean Daily Temperature Range	MDBR	9.7	11.6	11.7	11.7	10.9	10.0	10.9	10.2	9.3	8.9	9.6	9.6	9.6
	5% DB MCDBR	12.0	13.5	13.8	13.9	12.6	11.6	11.6	11.1	10.3	9.5	10.1	10.9	10.9
	5% DB MCWBR	6.1	6.5	6.0	5.7	5.4	5.4	5.4	5.6	5.4	4.9	5.4	5.7	5.7
	5% WB MCDBR	10.6	12.2	12.3	12.1	11.5	10.3	11.0	10.5	9.7	8.9	9.0	9.7	9.7
	5% WB MCWBR	6.0	6.5	6.0	5.8	5.6	5.5	5.7	5.8	5.5	5.1	5.1	5.8	5.8
Clear-Sky Solar Irradiance	taub	0.361	0.380	0.415	0.459	0.475	0.446	0.464	0.437	0.413	0.393	0.374	0.377	0.377
	taud	2.570	2.510	2.380	2.242	2.237	2.373	2.315	2.398	2.448	2.515	2.534	2.522	2.522
	Ebn at Noon	920	918	894	853	830	846	832	860	883	893	898	889	889
	Edh at Noon	94	105	123	143	142	123	131	121	114	103	96	96	96
All-Sky Solar Radiation	RadAvg	4.29	5.06	5.92	6.50	6.49	6.06	6.52	6.39	5.84	5.24	4.64	4.17	4.17
	RadStd	0.31	0.38	0.27	0.26	0.39	0.35	0.25	0.23	0.36	0.25	0.22	0.27	0.27

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	+0.88	+1.06	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page