

ORIZABA, Mexico

WMO: 767370

Lat: 18.8656N

Lon: 97.0983W

Elev: 4131

StdP: 12.63

Time Zone: -6.00 (MEX)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	47.3	49.4	40.5	43.3	57.7	43.7	49.0	58.2	17.8	68.6	13.5	71.6	0.9	320	N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	17.2	87.8	69.0	85.2	69.0	83.2	69.1	72.8	82.2	71.9	81.2	71.0	79.9	6.6	160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.0	128.9	78.4	69.0	124.5	77.2	68.2	120.9	76.1	39.5	82.4	38.5	81.6	37.7	80.3	81.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.2	9.4	7.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.3	61.0	63.5	66.2	70.4	71.2	70.6	69.6	70.1	69.9	67.8	64.0	62.9
	DBStd	5.44	5.54	5.34	5.71	5.30	4.39	2.50	2.24	2.06	2.12	3.63	4.20	4.92
	HDD50	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD65	486	151	84	51	12	7	0	1	0	0	16	65	99
	CDD50	6308	341	379	501	612	657	619	608	623	597	551	421	399
	CDD65	1316	26	42	87	174	199	169	144	158	147	101	36	33
	CDH74	7307	232	390	736	1466	1316	712	667	668	420	327	154	219
Wind	WSAvg	3.0	2.9	2.9	3.5	3.7	3.4	2.9	3.0	2.7	2.6	2.7	2.5	2.7
	PrecAvg	71.5	1.6	1.3	1.7	2.0	4.3	11.5	11.4	12.2	11.4	6.3	2.8	1.5
Precipitation	PrecMax	89.1	3.7	3.1	5.3	4.4	9.5	19.9	21.2	21.2	17.3	12.8	8.5	4.7
	PrecMin	51.6	0.5	0.2	0.5	0.6	1.2	4.7	3.8	6.6	6.1	1.9	0.0	0.1
	PrecStd	8.5	0.8	0.8	1.0	0.9	2.2	3.9	5.2	4.2	2.6	2.8	1.6	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.8	86.3	89.1	92.8	90.1	84.5	83.5	83.4	82.2	83.5	82.7	84.8
		MCWB	65.0	67.3	68.8	67.4	69.1	71.6	69.9	71.3	71.8	71.4	68.1	66.7
	2%	DB	79.9	82.6	85.6	88.7	86.1	82.2	81.3	81.4	80.3	79.9	78.0	79.2
		MCWB	65.3	66.7	68.4	68.4	70.9	70.7	69.5	70.3	70.7	70.4	68.1	65.2
	5%	DB	75.2	78.8	82.0	85.3	83.5	80.4	79.7	79.8	78.5	77.5	75.0	75.1
		MCWB	63.2	66.3	67.8	68.7	70.3	69.9	69.0	69.5	69.8	68.9	66.5	64.9
	10%	DB	71.6	75.5	78.3	82.3	81.3	78.5	77.8	78.0	76.5	75.3	72.3	72.3
		MCWB	61.0	64.5	66.2	67.6	69.6	69.0	68.4	68.6	68.9	67.7	64.9	63.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.6	71.5	72.1	73.1	74.0	73.3	72.3	72.8	72.9	73.4	70.7	69.5
		MCDB	79.1	81.4	84.5	85.9	84.1	82.6	80.6	81.1	80.2	80.0	78.7	79.0
	2%	WB	66.5	68.4	70.4	71.5	72.5	71.7	70.8	71.2	71.4	71.2	68.7	67.3
		MCDB	76.1	79.3	81.7	84.2	82.5	80.3	79.1	79.4	78.8	78.0	76.0	75.5
	5%	WB	64.7	66.7	68.7	70.1	71.4	70.6	69.8	70.2	70.3	69.7	67.3	65.7
		MCDB	73.5	76.9	79.4	81.6	81.3	78.6	78.0	78.1	77.0	76.1	73.6	73.5
	10%	WB	62.8	65.1	66.9	68.9	70.2	69.6	68.8	69.2	69.3	68.4	65.8	64.2
		MCDB	69.8	74.3	76.4	79.5	79.4	76.9	76.4	76.5	75.2	73.8	70.8	71.1
Mean Daily Temperature Range	5% DB	MDBR	16.2	18.4	18.2	19.6	17.2	15.8	17.5	17.0	14.6	14.8	14.8	16.5
		MCDBR	24.6	25.2	24.5	24.8	21.4	18.7	20.1	19.2	17.6	17.9	19.8	22.5
		MCWBR	14.7	15.1	14.4	14.2	12.2	9.9	11.2	10.5	9.6	10.3	11.8	13.5
	5% WB	MCDBR	21.9	23.4	22.8	22.2	19.5	17.1	18.7	18.0	16.5	17.0	18.4	20.5
		MCWBR	13.6	15.0	14.3	13.7	12.1	9.7	11.0	10.2	9.2	10.0	11.3	13.0
Clear-Sky Solar Irradiance	taub		0.371	0.386	0.417	0.457	0.503	0.440	0.420	0.408	0.414	0.399	0.382	0.380
	taud		2.370	2.326	2.241	2.159	2.047	2.260	2.330	2.362	2.336	2.366	2.363	2.333
	Ebn at Noon		288	289	283	271	256	270	276	281	280	281	282	280
	Edh at Noon		36	40	45	49	55	44	41	40	41	38	36	37
All-Sky Solar Radiation	RadAvg		1347	1590	1799	1904	1844	1789	1816	1771	1564	1518	1415	1338
	RadStd		110	129	129	109	106	97	148	95	133	90	104	79

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.76	-0.59	N/A	N/A	N/A

Nomenclature: See separate page