

ORIZABA, Mexico

WMO: 767370

Lat: 18.8656N

Lon: 97.0983W

Elev: 1259

StdP: 87.09

Time Zone: -6.00 (MEX)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 8.5	(c) 9.7	(d) 4.7	(e) 6.2	(f) 14.3	(g) 6.5	(h) 7.0	(i) 14.6	(j) 8.0	(k) 20.3	(l) 6.0	(m) 22.0	(n) 0.4	(o) 320	(p) N/A

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 5	(b) 9.6	(c) 31.0	(d) 20.5	(e) 29.6	(f) 20.6	(g) 28.4	(h) 20.6	(i) 22.7	(j) 27.9	(k) 22.2	(l) 27.3	(m) 21.7	(n) 26.6	(o) 3.0	(p) 160

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.1	18.4	25.8	20.6	17.8	25.1	20.1	17.3	24.5	73.9	28.0	71.7	27.5	69.9	26.8	27.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 5.5	(b) 4.2	(c) 3.4	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.6	16.1	17.5	19.0	21.3	21.8	21.5	20.9	21.2	21.0	19.9	17.8	17.2
	DBStd	3.02	3.08	2.97	3.17	2.95	2.44	1.39	1.25	1.15	1.18	2.02	2.33	2.73
	HDD10.0	1	1	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	270	84	47	28	7	4	0	1	0	0	9	36	55
	CDD10.0	3504	189	211	278	340	365	344	338	346	332	306	234	222
	CDD18.3	731	14	23	48	97	111	94	80	88	82	56	20	18
	CDH23.3	4059	129	217	409	814	731	396	371	371	233	182	86	122
	CDH26.7	792	28	44	114	264	179	39	30	28	12	18	11	24
Wind	WSAvg	1.3	1.3	1.3	1.6	1.6	1.5	1.3	1.4	1.2	1.2	1.2	1.1	1.2
Precipitation	PrecAvg	1816	41	32	42	50	108	293	290	309	289	161	72	38
	PrecMax	2262	95	78	134	112	241	505	538	538	439	324	216	120
	PrecMin	1310	12	5	13	16	30	119	97	167	155	47	0	3
	PrecStd	217	21	20	26	24	55	98	131	106	67	70	41	25
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.3	30.1	31.7	33.8	32.3	29.2	28.6	28.6	27.9	28.6	28.2	29.3
		MCWB	18.4	19.6	20.4	19.7	20.6	22.0	21.0	21.8	22.1	21.9	20.0	19.3
	2%	DB	26.6	28.1	29.8	31.5	30.0	27.9	27.4	27.4	26.8	26.6	25.6	26.2
		MCWB	18.5	19.3	20.2	20.2	21.6	21.5	20.9	21.3	21.5	21.3	20.1	18.5
	5%	DB	24.0	26.0	27.8	29.6	28.6	26.9	26.5	26.5	25.9	25.3	23.9	24.0
		MCWB	17.3	19.0	19.9	20.4	21.3	21.0	20.6	20.8	21.0	20.5	19.2	18.3
	10%	DB	22.0	24.2	25.7	27.9	27.4	25.8	25.5	25.6	24.7	24.1	22.4	22.4
		MCWB	16.1	18.0	19.0	19.8	20.9	20.5	20.2	20.3	20.5	19.9	18.3	17.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.4	22.0	22.3	22.8	23.3	22.9	22.4	22.7	22.7	23.0	21.5	20.9
		MCDB	26.2	27.5	29.2	29.9	28.9	28.1	27.0	27.3	26.8	26.7	25.9	26.1
	2%	WB	19.2	20.2	21.3	21.9	22.5	22.1	21.6	21.8	21.9	21.8	20.4	19.6
		MCDB	24.5	26.3	27.6	29.0	28.1	26.8	26.2	26.4	26.0	25.5	24.4	24.2
	5%	WB	18.1	19.3	20.4	21.2	21.9	21.5	21.0	21.2	21.3	21.0	19.6	18.7
		MCDB	23.1	24.9	26.3	27.6	27.4	25.9	25.6	25.6	25.0	24.5	23.1	23.1
	10%	WB	17.1	18.4	19.4	20.5	21.2	20.9	20.4	20.6	20.7	20.2	18.8	17.9
		MCDB	21.0	23.5	24.7	26.4	26.3	24.9	24.7	24.7	24.0	23.2	21.5	21.7
Mean Daily Temperature Range	5% DB	MDBR	9.0	10.2	10.1	10.9	9.6	8.8	9.7	9.4	8.1	8.2	8.2	9.2
		MCDBR	13.7	14.0	13.6	13.8	11.9	10.4	11.2	10.7	9.8	10.0	11.0	12.5
		MCWBR	8.2	8.4	8.0	7.9	6.8	5.5	6.2	5.8	5.3	5.7	6.5	7.5
	5% WB	MCDBR	12.1	13.0	12.7	12.3	10.8	9.5	10.4	10.0	9.1	9.4	10.2	11.4
		MCWBR	7.6	8.3	8.0	7.6	6.7	5.4	6.1	5.7	5.1	5.6	6.3	7.2
Clear-Sky Solar Irradiance	taub	0.371	0.386	0.417	0.457	0.503	0.440	0.420	0.408	0.414	0.399	0.382	0.380	
	taud	2.370	2.326	2.241	2.159	2.047	2.260	2.330	2.362	2.336	2.366	2.363	2.333	
	Ebn at Noon	907	912	892	855	807	852	870	886	883	887	888	884	
	Edh at Noon	115	126	142	156	172	138	129	125	128	120	115	116	
All-Sky Solar Radiation	RadAvg	4.25	5.01	5.67	6.00	5.81	5.64	5.72	5.58	4.93	4.79	4.46	4.22	
	RadStd	0.35	0.41	0.41	0.34	0.33	0.31	0.47	0.30	0.42	0.28	0.33	0.25	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.42	-0.33	N/A	N/A	N/A

Nomenclature: See separate page