

COATZACOALCOS, Mexico

WMO: 767410

Lat: 18.1403N

Lon: 94.5108W

Elev: 52

StdP: 14.67

Time Zone: -6.00 (MEX)

Period: 82-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	61.6	63.5	55.8	66.4	65.3	58.0	71.9	66.8	44.4	66.8	39.2	69.0	6.8	0	0.344

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.5	96.5	80.2	93.6	79.9	91.3	80.0	83.6	90.0	82.6	88.7	81.8	87.6	9.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.9	166.4	87.8	81.0	161.2	86.8	80.2	157.1	86.0	47.8	90.5	46.6	89.0	45.7	87.9	94.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
47.4	30.2	22.8	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.0	72.3	74.3	77.3	81.0	83.6	82.9	82.4	82.5	81.6	79.3	76.7	73.4
	DBStd	5.25	3.96	4.26	4.67	4.96	3.63	2.45	2.27	2.30	2.26	3.17	3.36	4.16
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	2	1	0	0	0	0	0	0	0	0	0	0	1
	CDD50	10574	692	681	847	931	1041	988	1004	1007	949	908	800	726
	CDD65	5102	228	261	383	481	576	538	539	542	499	443	350	262
	CDH74	48780	780	1289	2809	4990	6807	6372	6355	6360	5382	4081	2391	1164
	CDH80	16583	122	265	812	1860	2794	2480	2346	2462	1824	1064	383	171
Wind	WSAvg	8.3	10.0	9.8	9.5	8.6	9.6	9.2	7.8	6.1	5.1	7.2	8.6	8.3
Precipitation	PrecAvg	89.8	3.1	1.5	0.9	0.7	3.1	8.9	10.6	14.2	18.5	13.5	8.9	4.4
	PrecMax	126.3	10.4	4.6	3.1	5.5	13.9	20.5	22.5	26.6	49.7	28.5	22.5	9.1
	PrecMin	55.2	0.0	0.0	0.0	0.0	0.0	2.3	3.4	5.4	7.8	4.9	0.0	0.0
	PrecStd	15.9	2.4	1.3	0.9	1.2	3.6	4.6	4.5	5.5	8.8	7.0	5.5	1.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.0	92.6	96.1	100.9	99.5	96.3	91.6	92.9	92.8	91.8	89.2	89.4
		MCWB	76.2	75.7	78.9	79.4	80.4	82.9	81.8	82.6	81.4	82.2	78.3	76.3
	2%	DB	82.7	87.1	92.6	97.2	96.0	92.6	89.8	90.6	90.6	89.2	86.1	84.3
		MCWB	74.8	76.2	77.1	80.2	80.0	81.1	81.1	81.5	80.8	79.7	77.2	75.1
	5%	DB	80.1	83.2	87.7	93.3	92.7	90.0	88.4	89.2	88.7	86.9	84.0	80.9
		MCWB	73.9	75.7	76.2	79.3	80.2	81.0	80.5	81.2	80.4	79.3	76.9	75.0
	10%	DB	77.7	80.4	84.0	88.1	89.5	88.2	87.1	87.9	87.1	85.3	82.2	78.9
		MCWB	72.8	74.6	76.1	78.2	80.0	80.5	79.9	80.6	79.7	78.6	76.4	74.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.4	79.1	82.2	85.4	84.9	84.6	83.3	84.1	83.5	83.3	80.3	77.9
		MCDB	84.7	86.6	90.8	94.7	91.6	91.0	88.8	89.9	89.5	88.8	85.6	83.5
	2%	WB	75.7	77.2	79.0	82.0	82.8	83.0	82.0	82.7	82.2	81.4	78.7	76.8
		MCDB	80.2	83.7	86.6	88.4	89.5	89.1	87.4	88.4	87.7	86.3	82.8	81.4
	5%	WB	74.5	76.0	77.6	80.3	81.7	81.9	81.2	81.8	81.3	80.2	77.7	75.9
		MCDB	78.6	81.3	84.2	86.6	88.3	87.8	86.3	87.3	86.5	84.9	82.0	80.0
	10%	WB	73.6	74.9	76.5	79.0	80.7	80.9	80.5	80.9	80.4	79.1	77.0	74.8
		MCDB	77.5	79.2	82.4	84.9	87.3	86.6	85.5	86.1	85.4	83.7	81.4	78.5
Mean Daily Temperature Range	5% DB	MDBR	9.7	10.4	12.1	13.6	12.5	11.3	9.9	11.1	11.4	10.3	10.0	10.2
		MCDBR	14.3	16.2	20.0	22.1	17.8	14.4	11.2	12.4	13.5	12.8	12.7	14.0
		MCWBR	8.1	8.8	9.8	9.5	8.2	6.8	5.9	6.1	6.7	6.5	7.2	7.2
	5% WB	MCDBR	12.3	13.2	14.8	15.9	13.9	12.4	10.3	11.4	12.2	11.0	11.1	12.5
		MCWBR	7.7	7.7	8.6	8.8	7.7	7.2	6.0	6.5	6.8	6.6	7.1	7.0
Clear-Sky Solar Irradiance	taub	0.380	0.394	0.440	0.494	0.541	0.460	0.468	0.457	0.445	0.418	0.396	0.388	
	taud	2.487	2.442	2.293	2.152	2.044	2.312	2.296	2.323	2.343	2.433	2.462	2.474	
	Ebn at Noon	287	288	277	261	246	265	263	268	272	277	279	280	
	Edh at Noon	33	36	43	50	55	42	42	42	40	36	33	32	
All-Sky Solar Radiation	RadAvg	1023	1302	1636	1824	1826	1762	1800	1706	1491	1312	1146	1025	
	RadStd	137	161	136	103	121	106	105	91	108	115	118	102	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page