

OAXACA INTL, Mexico

WMO: 767750

Lat: 17.002N

Lon: 96.721W

Elev: 4980

StdP: 12.24

Time Zone: -6.00 (MEX)

Period: 01-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	44.5	46.9	23.2	21.0	74.5	28.2	26.6	76.1	23.2	69.4	19.2	69.6	4.1	0	0.312

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	26.7	91.6	63.3	89.6	62.2	87.7	62.2	75.1	83.1	71.6	80.8	69.0	79.1	6.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
72.7	146.6	81.3	68.7	127.4	77.7	66.0	115.8	73.6	42.6	83.2	38.9	80.6	36.3	78.9	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
17.7	14.8	12.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	69.8	64.3	68.4	70.4	73.6	74.8	72.5	71.1	71.3	71.0	69.0	66.3	64.8
	DBStd	4.32	3.61	3.12	3.21	3.13	2.72	2.50	1.83	1.93	2.06	2.95	3.65	3.31
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	140	55	7	2	0	0	0	0	0	0	5	29	42
	CDD50	7230	445	515	634	707	770	675	655	661	630	589	490	459
	CDD65	1895	35	102	171	258	305	225	190	196	181	128	68	36
	CDH74	15256	759	1405	1953	2618	2340	1162	988	1024	717	831	716	743
	CDH80	4585	144	431	717	1167	939	285	177	204	101	163	130	127
Wind	WSAvg	4.7	5.0	5.2	5.5	5.5	4.8	4.2	4.2	4.2	3.7	4.7	4.6	4.5
Precipitation	PrecAvg	30.9	0.1	0.2	0.7	1.5	3.1	5.9	4.9	5.1	5.5	2.6	0.6	0.3
	PrecMax	41.3	0.5	1.4	1.6	4.9	7.1	9.4	10.0	13.7	12.0	6.7	2.8	2.2
	PrecMin	21.8	0.0	0.0	0.1	0.0	0.1	2.2	1.8	2.2	2.1	0.7	0.1	0.1
	PrecStd	5.4	0.1	0.3	0.5	1.3	1.8	2.1	2.2	3.1	2.2	1.7	0.6	0.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.4	90.2	91.9	95.0	93.9	90.0	86.9	87.1	85.9	87.5	86.7	86.0
		MCWB	58.8	59.6	61.9	64.4	66.1	67.4	66.6	67.5	68.7	64.7	65.1	64.6
	2%	DB	83.9	87.8	89.6	91.8	91.2	86.1	84.0	84.2	82.7	84.2	84.2	83.8
		MCWB	58.8	59.0	61.0	62.1	65.5	66.7	65.7	65.8	66.7	64.6	62.1	60.2
	5%	DB	81.9	85.6	87.4	89.7	88.2	83.8	82.0	82.3	80.6	81.6	81.5	81.0
		MCWB	57.9	58.7	60.0	61.0	64.1	65.6	65.1	65.0	65.9	63.7	61.6	59.1
	10%	DB	78.9	82.5	84.5	87.5	86.0	81.0	79.2	80.3	78.7	79.0	78.9	78.8
		MCWB	57.3	58.3	60.4	61.2	63.8	64.7	63.7	64.4	64.8	62.8	60.8	58.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.8	73.9	75.4	76.9	78.4	74.6	74.6	72.6	74.2	74.4	74.6	74.3
		MCDB	76.2	80.2	83.5	85.7	86.7	82.9	82.1	82.3	79.7	81.3	80.4	81.6
	2%	WB	63.5	65.9	68.0	70.3	72.1	69.7	69.8	68.5	69.2	69.0	67.3	66.8
		MCDB	74.7	75.7	80.5	82.0	82.7	80.1	79.0	79.3	78.5	78.0	77.0	74.9
	5%	WB	60.3	62.5	64.6	66.5	68.5	67.5	67.0	66.8	67.3	66.3	64.0	62.2
		MCDB	75.8	75.9	77.6	78.8	79.2	78.2	77.2	77.3	76.5	75.8	75.7	73.6
	10%	WB	58.8	60.6	62.6	64.3	66.3	66.1	65.4	65.5	66.0	64.6	62.2	59.9
		MCDB	74.5	75.8	76.5	78.0	77.1	75.9	74.6	75.3	74.3	73.7	73.8	73.5
Mean Daily Temperature Range	5% DB	MDBR	32.0	32.7	31.9	31.6	26.7	21.2	22.3	22.6	20.0	24.3	29.0	31.6
		MCDBR	35.2	35.2	34.8	34.5	29.6	24.5	24.7	25.2	22.5	28.7	32.0	34.3
		MCWBR	16.9	15.7	16.4	15.9	14.3	11.7	13.0	10.9	10.4	14.2	16.7	19.0
	5% WB	MCDBR	32.0	32.0	31.4	30.9	26.4	21.2	22.5	22.7	20.5	23.5	28.7	31.3
MCWBR		19.1	19.2	18.8	19.0	16.0	11.9	13.6	11.1	10.6	14.1	18.0	21.0	
Clear-Sky Solar Irradiance	taub	0.339	0.338	0.400	0.408	0.476	0.414	0.397	0.396	0.396	0.377	0.345	0.327	
	taud	2.444	2.449	2.259	2.270	2.107	2.327	2.401	2.383	2.378	2.434	2.478	2.509	
	Ebn at Noon	301	307	289	285	263	277	282	285	286	290	297	302	
	Edh at Noon	34	36	44	44	51	41	38	39	39	36	33	31	
All-Sky Solar Radiation	RadAvg	1551	1782	1967	2009	1810	1654	1734	1687	1492	1540	1557	1521	
	RadStd	97	98	104	79	119	116	131	120	123	106	101	75	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page