

COMITAN, Mexico

WMO: 768480

Lat: 16.2319N

Lon: 92.1353W

Elev: 5400

StdP: 12.05

Time Zone: -6.00 (MEX)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	48.0	50.1	35.9	37.7	65.9	39.6	43.7	63.4	16.5	61.7	13.7	62.5	2.7	50	0.294

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	18.6	84.4	62.8	82.6	62.8	80.8	62.8	67.8	77.8	66.9	76.8	66.0	75.7	5.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.5	111.5	72.9	63.7	108.1	71.4	62.9	105.2	70.0	35.6	77.9	34.8	77.0	34.0	75.6	79.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.0	11.9	10.0	DB	43.4	89.0	2.7	1.4	41.4	90.0	39.8	90.9	38.3	91.7	36.3	92.7
			WB	38.4	71.4	3.7	2.5	35.7	73.2	33.6	74.7	31.6	76.0	28.9	77.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	66.6	62.3	64.0	66.5	69.9	70.1	68.6	67.9	68.6	68.3	66.3	63.6	62.9
	DBStd	3.94	3.59	3.81	3.83	2.99	2.59	2.16	1.97	1.88	2.05	2.88	3.37	2.91
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	352	96	58	27	3	1	2	2	1	2	20	62	78
	CDD50	6052	381	391	512	597	623	557	555	575	550	505	407	399
	CDD65	927	11	28	74	150	159	108	92	111	102	60	20	12
	CDH74	4147	129	278	625	991	779	267	222	307	232	144	83	90
	CDH80	535	8	36	110	208	124	12	9	16	5	3	1	3
(14) Wind	WSAvg	3.7	3.6	4.1	4.2	4.0	3.5	3.5	4.1	3.9	3.2	3.2	3.9	3.7
(15) Precipitation	PrecAvg	41.1	0.2	0.3	0.6	1.3	4.4	8.4	4.8	7.0	8.3	4.3	1.0	0.4
	PrecMax	57.4	0.6	1.2	1.9	3.7	9.8	14.4	10.8	14.8	14.6	8.5	2.7	2.1
	PrecMin	28.3	0.0	0.0	0.0	0.0	1.3	2.9	1.0	1.9	2.6	0.4	0.0	0.0
	PrecStd	7.9	0.2	0.3	0.5	0.9	2.6	2.7	2.3	3.4	2.6	2.0	0.8	0.4
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	81.3	84.2	86.1	87.4	86.0	81.6	81.2	81.9	80.7	80.3	79.5	80.0
		MCWB	60.8	61.6	61.5	62.8	64.0	66.1	63.3	64.0	66.0	66.5	64.8	61.6
	2%	DB	77.6	80.8	83.2	84.6	83.4	79.2	78.3	79.3	78.7	77.9	76.4	76.8
		MCWB	60.2	60.0	61.3	62.5	64.3	65.6	63.3	63.8	65.6	65.5	62.7	61.1
	5%	DB	74.7	77.9	80.5	82.5	81.1	77.2	76.5	77.3	76.8	75.6	73.8	73.6
		MCWB	58.9	59.6	60.5	62.3	64.3	65.0	63.1	63.7	65.1	64.4	62.0	60.1
	10%	DB	71.6	74.5	77.8	80.0	78.8	75.3	74.7	75.4	74.9	73.3	71.3	70.6
		MCWB	58.2	58.8	60.0	61.9	63.6	64.2	62.8	63.4	64.5	63.5	61.3	58.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.6	64.5	65.4	67.2	68.3	68.4	67.4	68.3	68.6	68.2	66.9	64.3
		MCDB	77.1	79.2	80.0	79.4	80.2	78.6	76.1	77.7	77.6	77.9	76.6	76.7
	2%	WB	61.5	62.4	63.7	65.5	67.0	66.9	65.6	66.5	67.2	66.5	64.7	62.4
		MCDB	74.0	76.3	77.6	77.9	78.7	76.4	74.7	75.3	76.2	75.6	73.6	74.1
	5%	WB	60.3	61.1	62.4	64.5	65.9	65.9	64.4	65.1	66.1	65.3	63.2	60.9
		MCDB	71.2	72.9	75.6	76.9	77.0	74.9	73.5	73.7	74.6	73.5	71.2	70.5
	10%	WB	59.2	59.9	61.3	63.6	64.8	64.9	63.5	64.1	65.0	64.1	61.9	59.7
		MCDB	68.5	70.7	73.5	75.3	75.0	73.1	72.0	72.3	72.7	71.4	69.1	67.9
(35) Mean Daily Temperature Range	5% DB	MDBR	18.5	20.1	21.8	21.8	18.6	14.9	15.1	16.0	15.0	14.8	16.1	16.6
		MCDBR	25.1	27.0	26.8	25.1	21.9	17.4	17.5	18.2	17.3	18.2	20.1	22.1
		MCWBR	11.5	11.3	10.0	8.9	8.3	7.3	6.8	7.2	7.5	8.7	9.9	10.3
	5% WB	MCDBR	21.6	23.5	24.2	22.6	19.3	16.2	15.8	16.6	16.1	16.4	17.8	18.9
		MCWBR	10.3	10.4	9.8	8.9	8.4	7.6	7.0	7.8	8.0	8.6	9.5	9.3
(40) Clear-Sky Solar Irradiance	taub		0.314	0.336	0.382	0.457	0.511	0.408	0.396	0.404	0.395	0.362	0.333	0.315
	taud		2.572	2.494	2.335	2.120	1.996	2.357	2.395	2.351	2.367	2.490	2.533	2.572
	Ebn at Noon		312	308	295	272	254	279	282	283	287	296	302	308
	Edh at Noon		30	34	41	51	57	40	38	40	39	34	31	30
(44) All-Sky Solar Radiation	RadAvg		1419	1654	1857	1900	1696	1644	1808	1791	1591	1453	1424	1398
	RadStd		92	105	98	78	132	97	121	107	117	120	93	89

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page