

TAPACHULA INTL, Mexico

WMO: 769043

Lat: 14.794N

Lon: 92.370W

Elev: 97

StdP: 14.64

Time Zone: -6.00 (MEX)

Period: 08-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	67.8	69.7	62.4	84.6	78.3	64.1	90.0	77.6	15.5	84.9	14.1	85.3	0.3	80	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	15.2	93.2	78.0	91.7	78.4	91.2	78.5	82.6	88.7	81.7	88.2	81.0	87.4	8.8	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.8	160.7	86.8	79.2	152.3	86.1	79.1	151.5	86.0	46.7	88.7	45.5	89.8	44.9	88.6	91.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.1	13.4	12.0	DB	66.5	96.8	3.7	3.4	63.8	99.3	61.6	101.3	59.5	103.2	56.8	105.7	
			WB	61.3	86.6	2.2	3.1	59.8	88.9	58.5	90.7	57.3	92.5	55.7	94.7	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.4	79.8	80.6	81.7	82.9	83.0	81.6	82.0	81.8	81.3	81.0	81.0	80.2
	DBStd	1.88	1.59	1.39	1.51	1.61	1.74	1.96	1.65	1.54	1.68	1.59	1.52	1.61
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11462	923	856	983	988	1022	949	991	986	939	961	929	935
	CDD65	5987	458	436	518	538	557	499	526	521	489	496	479	470
	CDH74	60629	4396	4445	5736	6331	6175	4859	5370	5092	4390	4495	4787	4553
	CDH80	23410	1613	1692	2359	2769	2537	1804	2147	1959	1550	1550	1711	1719
Wind	WSAvg	3.3	3.3	3.7	4.1	4.0	3.5	3.4	3.3	3.4	3.2	2.8	2.7	2.8
Precipitation	PrecAvg	84.2	0.4	0.3	1.2	3.1	9.7	13.2	9.4	11.9	16.3	14.0	3.9	0.7
	PrecMax	124.5	3.1	1.8	4.1	7.6	19.8	21.7	17.2	20.0	30.2	35.8	12.6	2.4
	PrecMin	61.0	0.0	0.0	0.0	0.0	1.1	5.4	1.4	4.8	10.4	2.0	0.0	0.0
	PrecStd	14.7	0.7	0.3	1.1	2.0	4.3	3.6	3.7	3.4	5.0	6.4	3.3	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.4	91.8	93.5	95.1	93.6	91.8	93.0	91.8	91.7	91.2	91.5	91.7
		MCWB	74.6	75.1	75.9	77.3	79.4	80.9	79.9	80.5	80.3	80.7	78.6	76.5
	2%	DB	89.7	90.0	91.7	93.2	91.6	91.1	91.4	91.3	90.0	89.6	89.7	89.9
		MCWB	75.4	75.4	76.2	77.2	79.7	80.6	80.3	80.4	79.6	79.9	78.9	76.9
	5%	DB	88.1	89.4	90.0	91.5	90.0	89.6	89.9	89.7	89.2	88.1	88.1	89.3
		MCWB	75.7	75.4	76.3	77.3	79.1	79.8	79.9	79.8	79.4	79.7	78.8	76.9
	10%	DB	87.4	87.8	89.2	89.8	89.5	88.0	89.3	88.1	87.7	87.5	87.6	87.7
		MCWB	75.7	75.5	76.4	77.2	79.0	79.5	79.8	79.5	79.4	79.5	78.7	77.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.7	79.2	80.3	81.7	83.4	83.7	85.1	82.8	81.9	82.7	82.1	80.8
		MCDB	86.0	85.7	86.5	88.3	88.1	87.5	88.1	88.8	88.2	87.8	87.4	86.5
	2%	WB	78.4	78.0	79.2	80.5	81.7	81.8	82.0	81.7	81.0	81.1	80.8	79.4
		MCDB	85.4	85.7	86.7	87.1	88.4	88.5	88.6	88.4	87.3	86.9	86.6	86.2
	5%	WB	77.4	77.3	78.4	79.6	80.8	80.9	81.1	80.9	80.4	80.5	80.1	78.6
		MCDB	84.7	85.1	86.5	87.0	87.6	87.4	87.8	87.4	86.7	86.4	86.1	85.8
	10%	WB	76.7	76.7	77.7	78.8	79.9	80.0	80.2	80.0	79.6	79.7	79.2	77.7
		MCDB	84.1	84.5	85.8	86.9	86.9	86.4	87.1	86.6	86.0	85.6	85.6	85.1
Mean Daily Temperature Range	5% DB	MDBR	16.3	16.0	15.7	15.2	13.8	13.3	14.4	14.3	13.3	13.1	14.2	16.3
		MCDBR	18.3	19.0	18.1	18.0	15.0	15.6	16.1	16.2	15.5	14.7	15.4	19.1
		MCWBR	8.9	8.4	7.8	6.9	6.7	7.8	8.6	8.3	7.5	7.7	8.2	9.2
	5% WB	MCDBR	15.7	15.8	15.6	15.1	14.4	14.4	15.4	15.1	14.2	14.0	14.6	16.6
		MCWBR	8.5	8.0	7.6	6.8	7.3	8.0	8.9	8.5	7.6	7.9	8.4	8.9
Clear-Sky Solar Irradiance	taub	0.395	0.420	0.485	0.584	0.616	0.482	0.490	0.479	0.474	0.434	0.412	0.396	
	taud	2.469	2.402	2.201	1.931	1.865	2.262	2.248	2.278	2.263	2.414	2.456	2.485	
	Ebn at Noon	285	283	266	239	228	258	257	263	265	275	278	282	
	Edh at Noon	34	38	48	62	65	43	44	43	44	37	34	33	
All-Sky Solar Radiation	RadAvg	1719	1889	2002	1990	1743	1679	1870	1838	1655	1611	1674	1645	
	RadStd	40	63	62	87	115	101	115	104	116	128	63	46	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page