

BERMUDA INTL, Bermuda

WMO: 780160

Lat: 32.367N

Lon: 64.677W

Elev: 4

StdP: 101.28

Time Zone: -4.00 (NAA)

Period: 94-19

WBAN: 13601

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.9	13.8	4.8	5.3	14.5	5.8	5.7	15.0	18.5	16.5	16.5	16.9	8.0	320	0.502

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.0	30.4	25.5	30.0	25.4	29.2	25.0	26.5	29.0	26.1	28.7	25.7	28.4	5.5	210

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.8	21.1	28.3	25.1	20.3	28.0	24.9	20.0	27.9	81.9	29.1	80.2	29.0	78.6	28.3	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.5	12.9	11.5	10.6	31.0	1.5	0.8	9.5	31.6	8.6	32.1	7.7	32.5	6.6	33.1		
(5)			7.5	27.4	1.0	0.9	6.8	28.0	6.2	28.6	5.6	29.0	4.9	29.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	22.3	18.2	18.0	18.0	19.7	22.0	24.9	27.2	27.5	26.7	24.4	21.4	19.5
	DBStd	3.90	2.12	2.01	1.86	1.57	1.64	1.50	1.10	1.15	1.14	1.52	1.76	1.85
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	102	28	28	29	6	1	0	0	0	0	0	1	10
	CDD10.0	4494	255	223	248	289	371	448	532	543	500	446	343	296
	CDD18.3	1555	24	18	19	46	113	198	273	285	250	187	94	47
	CDH23.3	10902	2	1	1	10	196	1257	2794	3117	2379	1008	128	10
	CDH26.7	2114	0	0	0	0	2	128	623	851	454	57	1	0
Wind	WSAvg	5.9	7.0	7.0	7.0	6.1	5.6	5.1	5.1	4.8	5.0	5.7	6.1	6.4
Precipitation	PrecAvg	1472	117	119	113	94	113	96	111	168	159	158	111	114
	PrecMax	1858	235	223	201	214	314	316	220	356	306	273	275	377
	PrecMin	1018	44	38	18	30	23	6	2	38	44	44	42	36
	PrecStd	212	44	52	47	49	72	74	56	85	71	52	56	70
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.7	23.1	23.1	24.2	26.9	29.8	31.2	31.9	30.8	28.9	26.1	24.2
		MCWB	20.6	20.1	19.8	20.0	22.4	24.6	25.5	25.3	25.3	24.3	22.3	21.3
	2%	DB	22.8	22.2	22.1	23.2	26.0	28.9	30.2	30.8	29.9	28.0	25.2	23.3
		MCWB	19.9	19.5	19.3	19.8	22.1	24.3	25.4	25.6	25.1	24.0	22.1	20.7
	5%	DB	22.0	21.7	21.5	22.9	25.1	28.0	29.8	30.1	29.2	27.2	24.8	23.0
		MCWB	19.4	19.2	18.7	19.6	21.7	24.0	25.3	25.6	24.8	23.4	21.9	20.4
	10%	DB	21.2	21.0	20.9	22.1	24.2	27.2	29.1	29.6	28.9	26.8	24.0	22.2
		MCWB	18.7	18.7	18.2	19.1	21.3	23.7	25.0	25.4	24.7	23.2	21.2	19.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.4	21.0	21.2	21.6	23.7	25.7	27.2	27.1	26.7	25.7	24.1	22.5
		MCDB	22.7	22.2	22.3	23.0	25.4	27.7	29.3	29.6	28.8	27.4	25.1	23.7
	2%	WB	20.6	20.3	20.3	21.0	23.0	25.2	26.4	26.6	26.2	25.0	23.3	21.6
		MCDB	22.0	21.6	21.6	22.5	24.7	27.4	28.7	29.3	28.5	26.8	24.6	22.9
	5%	WB	20.1	19.7	19.6	20.5	22.5	24.7	26.0	26.2	25.7	24.5	22.4	20.9
		MCDB	21.5	21.1	21.0	22.1	24.3	26.9	28.4	29.0	28.2	26.4	24.1	22.3
	10%	WB	19.4	19.3	18.8	19.7	21.9	24.4	25.6	25.8	25.3	24.0	21.6	20.2
		MCDB	21.0	20.8	20.4	21.5	23.8	26.6	28.1	28.7	27.9	26.0	23.6	21.9
Mean Daily Temperature Range	5% DB	MDBR	4.0	4.1	4.1	4.0	3.9	3.8	3.8	4.0	3.9	3.7	3.8	3.8
		MCDBR	4.1	4.2	4.4	4.4	4.1	4.3	4.3	4.3	4.2	4.0	4.0	4.2
		MCWBR	3.8	3.9	4.1	3.4	2.7	2.4	2.5	2.4	2.5	2.7	3.3	3.7
	5% WB	MCDBR	4.0	4.0	4.0	4.1	3.8	4.0	3.9	4.1	3.9	3.7	3.8	3.9
		MCWBR	4.4	4.3	4.5	3.5	3.0	2.6	2.6	2.6	2.7	2.8	3.6	4.4
Clear-Sky Solar Irradiance	taub	0.356	0.368	0.373	0.400	0.422	0.419	0.422	0.410	0.400	0.386	0.365	0.358	
	taud	2.538	2.500	2.482	2.398	2.360	2.422	2.474	2.519	2.526	2.552	2.555	2.540	
	Ebn at Noon	863	887	907	892	869	868	863	872	869	857	847	839	
	Edh at Noon	85	97	105	119	125	117	110	104	100	91	83	81	
All-Sky Solar Radiation	RadAvg	2.56	3.30	4.51	5.83	6.42	6.68	6.76	6.13	5.14	3.93	2.97	2.43	
	RadStd	0.16	0.28	0.35	0.31	0.47	0.52	0.40	0.42	0.24	0.24	0.13	0.18	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page