

NASSAU INTL, Bahamas

WMO: 780730

Lat: 25.039N

Lon: 77.466W

Elev: 16

StdP: 14.69

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	58.9	61.7	45.8	45.6	65.6	48.2	50.0	66.2	25.5	68.5	22.7	69.4	4.4	340	0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	11.6	92.9	79.7	91.5	79.4	90.0	78.9	82.0	87.9	81.3	87.5	80.7	87.1	8.9	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.7	159.3	85.4	79.4	152.7	84.9	79.0	150.4	84.7	45.8	89.2	45.0	87.8	44.3	87.3	89.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.7	19.0	17.2	52.9	94.8	3.5	1.9	50.3	96.2	48.3	97.3	46.3	98.4	43.8	99.8		
			50.1	84.7	2.5	2.3	48.3	86.4	46.8	87.7	45.4	89.0	43.6	90.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	78.8	72.1	73.2	74.5	77.0	79.9	83.2	84.6	84.7	83.8	81.3	76.9	74.4
	DBStd	5.51	4.20	4.26	3.99	3.14	2.72	2.45	2.17	2.26	2.16	2.87	3.16	4.06
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	10	5	3	0	0	0	0	0	0	0	0	0	2
	CDD50	10519	686	649	759	810	927	995	1072	1075	1015	970	806	755
	CDD65	5053	225	232	294	360	462	545	607	610	565	505	356	292
	CDH74	48110	888	1135	1684	2509	4306	6343	7653	7680	6725	5214	2453	1520
	CDH80	16285	75	144	283	496	1189	2461	3386	3416	2700	1565	403	167
(14) Wind	WSAvg	8.1	8.5	8.5	8.8	9.2	8.2	7.0	7.3	6.8	6.9	8.2	8.9	8.4
(15) Precipitation	PrecAvg	52.9	1.8	1.7	1.9	2.6	4.9	8.6	5.5	8.2	7.2	6.5	2.8	1.9
	PrecMax	73.1	10.9	9.5	6.6	16.9	16.8	21.9	12.6	20.9	16.7	20.0	13.3	8.8
	PrecMin	28.2	0.0	0.1	0.1	0.0	0.0	0.9	0.8	3.3	2.2	0.6	0.1	0.1
	PrecStd	11.3	1.6	1.5	1.7	3.1	3.3	4.8	3.0	3.6	3.1	3.8	2.5	1.7
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	84.3	86.0	87.7	88.2	91.5	93.3	93.5	94.1	93.5	91.5	87.8	85.8
		MCWB	73.9	73.4	75.3	74.6	76.9	79.1	79.2	80.8	80.3	79.7	76.3	76.8
	2%	DB	82.2	83.8	84.6	86.2	89.2	91.4	91.8	92.7	91.5	89.5	85.7	82.9
		MCWB	73.4	73.1	73.6	74.4	76.0	78.6	79.2	80.5	79.9	79.2	76.1	74.6
	5%	DB	80.5	82.0	82.8	84.4	87.4	89.7	91.0	91.2	89.9	87.9	84.0	82.1
		MCWB	72.5	72.5	72.8	73.4	75.8	78.2	79.1	79.9	79.4	78.7	75.2	74.1
	10%	DB	78.8	80.3	81.0	82.7	85.7	88.2	89.6	89.8	88.9	86.2	82.4	80.5
		MCWB	71.4	71.5	71.7	72.6	75.6	78.0	78.7	79.3	79.2	77.9	74.1	73.1
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.1	76.5	77.7	78.1	80.1	82.3	82.7	83.2	82.7	81.8	79.2	79.0
		MCDB	81.0	81.8	83.4	84.1	85.5	87.4	88.4	89.2	88.6	87.0	83.2	82.5
	2%	WB	75.4	75.1	76.1	76.7	78.9	80.9	81.5	81.9	81.6	80.7	78.1	77.2
		MCDB	79.4	80.1	81.8	82.3	84.6	87.0	87.8	88.1	87.7	86.1	82.5	80.8
	5%	WB	74.1	74.1	74.9	75.6	77.9	80.1	80.7	81.1	80.8	79.9	77.0	75.9
		MCDB	78.1	79.0	80.3	81.3	83.7	86.3	87.3	87.7	87.1	85.2	81.9	79.7
	10%	WB	72.9	73.2	73.8	74.6	77.0	79.4	80.0	80.4	80.1	79.1	76.0	74.7
		MCDB	77.0	77.9	79.2	80.4	82.9	85.7	86.7	87.2	86.3	84.3	80.7	78.7
(35) Mean Daily Temperature Range	5% DB	MDBR	12.4	13.1	12.9	12.3	11.9	11.6	11.4	11.6	11.5	10.7	11.1	11.4
		MCDBR	13.5	14.2	14.3	13.7	14.1	12.7	12.3	12.4	12.4	12.0	12.2	12.0
	5% WB	MCWBR	7.7	7.6	7.6	6.9	6.4	5.9	5.6	5.6	5.8	5.7	6.6	6.7
		MCWBR	12.0	12.6	12.9	12.1	12.3	12.1	11.6	11.7	11.7	11.2	11.1	10.6
(40) Clear-Sky Solar Irradiance	taub	taub	0.363	0.372	0.384	0.398	0.422	0.453	0.462	0.441	0.413	0.404	0.376	0.366
		taud	2.554	2.535	2.491	2.425	2.409	2.382	2.353	2.442	2.506	2.522	2.547	2.569
	Ebn at Noon	Ebn at Noon	284	289	290	286	277	267	264	271	277	275	277	278
		Edh at Noon	29	31	34	37	38	39	40	36	33	31	29	28
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1223	1495	1801	2022	2004	1924	2015	1910	1679	1455	1273	1144
	RadStd	RadStd	83	74	71	74	201	167	103	98	85	112	57	70

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.83	+1.84	N/A	+0.76	+0.77	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page