

NASSAU INTL, Bahamas

WMO: 780730

Lat: 25.039N

Lon: 77.466W

Elev: 5

StdP: 101.27

Time Zone: -5.00 (NAE)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.9	16.5	7.7	6.5	18.7	9.0	7.1	19.0	11.4	20.3	10.2	20.8	2.0	340	0.381

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	33.9	26.5	33.0	26.3	32.2	26.0	27.8	31.1	27.4	30.8	27.0	30.6	4.0	130

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.0	22.8	29.7	26.3	21.8	29.4	26.1	21.5	29.3	88.5	31.8	86.8	31.0	85.2	30.7	32.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.7	8.5	7.7	DB	11.6	34.9	1.9	1.1	10.2	35.7	9.1	36.3	8.0	36.9	6.6	37.7	(4)
(5)			WB	10.0	29.3	1.4	1.3	9.0	30.2	8.2	31.0	7.5	31.7	6.4	32.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.0	22.3	22.9	23.6	25.0	26.6	28.4	29.2	29.3	28.8	27.4	24.9	23.5	(6)	
	DBStd	3.06	2.33	2.37	2.21	1.74	1.51	1.36	1.21	1.25	1.20	1.59	1.75	2.26	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	6	3	2	0	0	0	0	0	0	0	0	0	1	(9)	
	CDD10.0	5844	381	361	422	450	515	553	596	597	564	539	448	419	(10)	
	CDD18.3	2807	125	129	163	200	257	303	337	339	314	281	198	162	(11)	
	CDH23.3	26728	493	631	936	1394	2392	3524	4252	4267	3736	2897	1363	844	(12)	
(13)	CDH26.7	9047	42	80	157	276	661	1367	1881	1898	1500	869	224	93	(13)	
(14)	Wind	WSAvg	3.6	3.8	3.8	3.9	4.1	3.6	3.1	3.3	3.0	3.1	3.7	4.0	3.8	(14)
(15) Precipitation	PrecAvg	1343	45	44	47	66	125	218	139	208	183	165	71	47	(15)	
	PrecMax	1857	278	242	167	430	426	555	319	531	424	507	337	224	(16)	
	PrecMin	716	1	2	2	0	1	22	20	83	56	16	3	2	(17)	
	PrecStd	286	41	38	42	79	85	121	76	91	80	97	64	44	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.1	30.0	31.0	31.2	33.1	34.0	34.2	34.5	34.1	33.1	31.0	29.9	(19)	
		MCWB	23.3	23.0	24.1	23.7	24.9	26.2	26.2	27.1	26.9	26.5	24.6	24.9	(20)	
	2%	DB	27.9	28.8	29.2	30.1	31.8	33.0	33.2	33.7	33.1	32.0	29.9	28.3	(21)	
		MCWB	23.0	22.8	23.1	23.5	24.5	25.9	26.2	26.9	26.6	26.2	24.5	23.7	(22)	
	5%	DB	26.9	27.8	28.2	29.1	30.8	32.1	32.8	32.9	32.2	31.0	28.9	27.8	(23)	
		MCWB	22.5	22.5	22.7	23.0	24.4	25.7	26.2	26.6	26.3	25.9	24.0	23.4	(24)	
	10%	DB	26.0	26.8	27.2	28.2	29.8	31.2	32.0	32.1	31.6	30.1	28.0	26.9	(25)	
		MCWB	21.9	22.0	22.0	22.6	24.2	25.6	25.9	26.3	26.2	25.5	23.4	22.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.0	24.7	25.4	25.6	26.7	28.0	28.2	28.4	28.2	27.7	26.2	26.1	(27)	
		MCDB	27.2	27.7	28.6	28.9	29.7	30.8	31.3	31.8	31.4	30.6	28.5	28.1	(28)	
	2%	WB	24.1	24.0	24.5	24.8	26.1	27.2	27.5	27.7	27.6	27.1	25.6	25.1	(29)	
		MCDB	26.3	26.7	27.7	27.9	29.2	30.5	31.0	31.2	31.0	30.1	28.0	27.1	(30)	
	5%	WB	23.4	23.4	23.8	24.2	25.5	26.7	27.0	27.3	27.1	26.6	25.0	24.4	(31)	
		MCDB	25.6	26.1	26.8	27.4	28.7	30.2	30.7	30.9	30.6	29.6	27.7	26.5	(32)	
	10%	WB	22.7	22.9	23.2	23.7	25.0	26.3	26.6	26.9	26.7	26.2	24.4	23.7	(33)	
		MCDB	25.0	25.5	26.2	26.9	28.3	29.8	30.4	30.7	30.2	29.0	27.0	26.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	7.3	7.1	6.8	6.6	6.4	6.3	6.4	6.4	6.0	6.1	6.4	(35)	
		MCDBR	7.5	7.9	8.0	7.6	7.8	7.0	6.8	6.9	6.9	6.7	6.8	6.7	(36)	
	5% WB	MCWBR	4.3	4.2	4.2	3.9	3.6	3.3	3.1	3.1	3.2	3.2	3.7	3.7	(37)	
		MCWBR	6.7	7.0	7.1	6.7	6.8	6.7	6.4	6.5	6.5	6.2	6.2	5.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.363	0.372	0.384	0.398	0.422	0.453	0.462	0.441	0.413	0.404	0.376	0.366	(40)	
		taud	2.554	2.535	2.491	2.425	2.409	2.382	2.353	2.442	2.506	2.522	2.547	2.569	(41)	
	Ebn at Noon		895	912	915	903	874	841	833	853	874	867	874	877	(42)	
		Edh at Noon	91	99	108	118	120	122	126	115	105	99	91	87	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.86	4.71	5.68	6.37	6.32	6.07	6.35	6.02	5.29	4.59	4.01	3.61	(44)	
	RadStd		0.26	0.23	0.22	0.23	0.63	0.53	0.32	0.31	0.27	0.35	0.18	0.22	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.46	+1.02	N/A	+0.42	+0.43	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page