

JARDINES DEL REY, CubaWMO: **782561**Lat: **22.461N**Lon: **78.328W**Elev: **13**StdP: **14.69**Time Zone: **-5.00 (CUB)**Period: **04-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	59.9	62.8	48.5	50.6	65.4	51.8	57.1	67.4	24.7	73.6	23.0	73.8	4.1	10	0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.0	91.5	78.2	90.0	77.9	89.6	77.9	80.2	87.2	79.9	86.9	79.4	86.5	11.9	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.7	149.2	84.5	77.4	142.5	84.0	77.2	141.6	84.0	44.0	88.3	43.5	87.3	43.0	86.7	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.8	20.0	18.4	55.1	93.9	2.6	1.2	53.2	94.7	51.6	95.4	50.1	96.1	48.2	97.0		
(5)			51.4	81.9	2.1	1.2	49.9	82.8	48.7	83.5	47.6	84.2	46.0	85.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	78.8	73.6	74.6	75.5	78.2	79.5	82.1	83.6	83.5	82.2	80.5	77.0	75.6
	DBStd	4.44	3.99	3.66	3.23	2.71	2.56	2.18	1.76	1.81	1.82	2.11	3.25	3.82
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	6	3	1	0	0	0	0	0	0	0	0	0	2
	CDD50	10526	730	690	792	845	913	962	1040	1038	967	945	811	793
	CDD65	5057	268	271	327	395	448	512	575	573	517	480	361	330
	CDH74	47138	1224	1507	2016	3279	4216	5723	7041	6988	5837	4734	2579	1994
	CDH80	14768	127	222	349	740	1147	2097	2975	2955	2232	1334	364	226
Wind	WSAvg	9.5	10.4	10.5	11.2	10.6	9.3	7.9	8.9	8.5	7.2	8.5	10.6	10.3
Precipitation	PrecAvg	50.7	1.4	1.3	1.5	2.4	6.4	7.0	5.8	6.6	7.5	6.3	2.6	1.7
	PrecMax	64.2	3.0	4.6	3.3	4.6	12.9	14.3	8.5	9.8	13.7	18.9	7.1	8.0
	PrecMin	33.1	0.3	0.3	0.6	0.8	2.4	3.3	3.4	4.3	4.4	2.0	0.3	0.4
	PrecStd	6.9	0.7	0.9	0.6	0.8	3.0	2.6	1.5	1.3	1.9	3.4	1.8	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.6	87.4	89.2	89.6	89.9	91.8	91.8	91.8	91.7	89.7	86.4	85.8
		MCWB	72.3	71.9	73.1	73.7	76.5	77.8	78.4	78.4	78.6	77.4	77.2	74.7
	2%	DB	82.7	84.3	85.8	86.4	88.0	89.9	91.3	91.3	90.0	88.0	84.6	83.9
		MCWB	73.0	72.7	73.3	74.6	76.4	77.8	78.5	78.7	78.4	78.0	76.2	74.9
	5%	DB	81.0	82.5	83.8	85.7	86.3	89.3	89.9	89.9	89.4	87.4	83.8	82.4
		MCWB	72.3	72.6	72.6	74.3	75.6	77.8	78.0	78.3	78.3	77.8	75.6	74.1
	10%	DB	80.2	80.8	82.0	84.1	85.7	87.8	89.4	89.4	87.9	85.9	82.3	80.9
		MCWB	72.0	72.0	71.7	73.6	75.3	77.8	77.8	78.2	78.2	77.1	74.5	73.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.8	76.1	76.4	77.9	79.4	80.9	80.7	81.0	80.9	80.1	79.1	78.2
		MCDB	80.7	81.7	81.9	83.7	86.4	87.5	88.0	88.0	87.3	86.3	84.1	82.4
	2%	WB	74.6	74.7	75.1	76.5	78.3	79.8	80.0	80.1	80.0	79.5	77.8	76.5
		MCDB	79.8	80.1	81.7	83.2	84.8	86.7	87.5	87.4	86.7	85.5	82.8	80.7
	5%	WB	73.8	73.9	74.0	75.5	77.3	79.2	79.5	79.7	79.6	78.8	76.9	75.5
		MCDB	79.1	79.6	80.7	82.7	83.5	86.0	87.1	87.0	86.3	84.6	81.6	80.0
	10%	WB	72.8	72.9	72.8	74.6	76.6	78.6	78.9	79.1	79.0	78.0	75.8	74.5
		MCDB	78.1	78.9	79.8	81.8	82.7	85.4	86.6	86.5	85.8	83.8	80.7	79.4
Mean Daily Temperature Range	5% DB	MDBR	11.3	12.0	12.2	12.2	11.9	12.0	12.0	12.3	12.6	10.6	9.5	10.3
		MCDBR	12.8	14.3	15.3	14.2	13.5	13.8	13.0	12.9	13.8	12.5	10.4	11.0
		MCWBR	6.8	6.9	6.7	6.1	5.7	5.6	5.1	5.3	5.5	5.7	5.4	5.8
	5% WB	MCDBR	12.1	12.4	13.5	12.6	11.7	12.6	12.1	12.5	12.6	11.7	9.1	10.3
		MCWBR	7.0	6.9	6.7	6.0	5.6	5.9	5.4	5.6	5.8	5.9	5.2	5.8
Clear-Sky Solar Irradiance	taub	0.366	0.374	0.390	0.410	0.436	0.471	0.476	0.452	0.422	0.414	0.390	0.389	
	taud	2.560	2.534	2.480	2.415	2.390	2.313	2.286	2.381	2.482	2.493	2.512	2.505	
	Ebn at Noon	287	291	290	284	274	262	261	268	276	274	276	274	
	Edh at Noon	30	32	35	38	39	42	43	39	35	33	31	30	
All-Sky Solar Radiation	RadAvg	1276	1576	1820	2042	1980	1898	2059	1954	1754	1501	1321	1210	
	RadStd	79	66	75	74	160	117	115	77	79	98	77	86	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page