

SANTO DOMINGO, Dominican RepublicWMO: **784860**Lat: **18.4734N**Lon: **69.8705W**Elev: **46**StdP: **14.67**Time Zone: **-4.00 (W04)**Period: **96-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	67.9	69.2	62.0	83.2	72.5	63.9	89.1	73.0	18.3	75.7	14.4	77.2	5.9	0	0.309

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	12.2	90.9	81.0	89.9	80.9	89.1	80.6	83.1	88.6	82.4	88.2	81.7	87.7	6.5	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.6	164.7	87.6	80.7	159.5	87.0	79.9	155.4	86.3	47.0	88.6	46.1	88.4	45.3	87.9	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 14.2	11.8	9.8	DB	65.8	95.4	2.0	2.9	64.4	97.5	63.2	99.3	62.1	100.9	60.7	103.0	(4)
(5)			WB	62.0	84.7	2.1	1.3	60.5	85.7	59.3	86.4	58.1	87.2	56.5	88.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	80.3	77.3	77.4	78.5	79.5	80.7	82.0	82.3	82.6	82.6	81.9	80.2	78.5
	DBStd	2.67	1.70	1.77	1.92	1.87	1.65	1.90	1.68	1.87	1.85	1.82	1.89	2.06
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11062	845	766	885	884	952	960	1002	1009	979	990	906	884
	CDD65	5587	380	346	420	434	487	510	537	544	529	525	456	419
	CDH74	51486	2540	2441	3294	3630	4718	5406	5722	5782	5690	5320	3832	3111
CDH80	16481	569	571	908	1043	1470	1864	2039	2059	2113	1836	1176	833	
Wind	WSAvg	5.4	5.6	5.9	6.0	5.6	5.2	5.1	5.4	5.2	5.3	5.1	5.6	5.5
Precipitation	PrecAvg	52.7	2.6	2.5	2.0	2.6	6.9	4.8	5.7	7.4	7.0	6.6	4.9	3.1
	PrecMax	77.4	8.3	9.7	5.5	10.3	19.2	17.7	13.7	17.8	23.4	24.5	14.9	12.4
	PrecMin	34.3	0.2	0.0	0.2	0.3	0.5	0.3	0.7	2.5	1.8	0.7	0.4	0.7
	PrecStd	11.1	2.0	2.3	1.5	2.2	4.8	3.6	2.7	3.4	4.4	4.4	3.4	2.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.9	86.8	88.0	89.5	89.9	90.8	91.6	92.2	92.4	91.1	89.9	88.1
		MCWB	77.1	76.9	77.7	78.4	81.1	80.9	80.8	81.0	81.7	80.9	79.6	78.5
	2%	DB	85.4	85.5	86.5	87.8	88.4	89.5	90.0	90.3	90.7	89.6	88.4	86.7
		MCWB	76.5	76.7	77.7	78.4	80.4	81.0	80.8	81.1	81.5	80.8	79.4	77.8
	5%	DB	84.4	84.5	85.7	86.5	87.5	88.5	89.0	89.1	89.5	88.6	87.3	85.7
		MCWB	76.0	75.9	77.4	77.9	79.8	80.5	80.5	80.9	81.1	80.4	78.9	77.2
	10%	DB	83.3	83.5	84.7	85.4	86.5	87.4	88.0	88.1	88.4	87.7	86.1	84.5
		MCWB	75.5	75.3	76.6	77.4	79.1	80.0	80.1	80.5	80.6	80.0	78.1	76.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.5	79.7	81.5	81.8	83.8	83.5	83.2	83.6	84.3	83.1	81.9	80.9
		MCDB	84.5	85.0	86.2	86.9	87.9	88.8	88.5	88.7	90.1	88.6	87.5	85.8
	2%	WB	77.9	78.1	79.7	80.4	82.2	82.0	82.1	82.4	82.7	82.0	80.8	79.2
		MCDB	83.7	83.9	85.3	86.0	87.1	87.9	88.1	88.5	89.1	88.0	86.9	85.0
	5%	WB	76.9	77.1	78.4	79.2	80.8	81.1	81.3	81.6	81.8	81.2	79.7	78.2
		MCDB	83.1	83.2	84.4	85.0	86.0	87.2	87.5	87.8	88.2	87.4	85.9	84.2
	10%	WB	76.0	76.1	77.3	78.2	79.7	80.3	80.5	80.8	80.9	80.4	78.8	77.3
		MCDB	82.1	82.2	83.3	84.0	85.0	86.4	86.8	87.2	87.3	86.6	84.9	83.3
Mean Daily Temperature Range	5% DB	MDBR	13.0	13.3	13.2	12.4	11.6	11.3	11.9	11.8	12.2	11.9	12.4	12.7
		MCDBR	14.2	14.1	14.0	13.6	12.7	12.2	13.0	12.9	13.3	13.1	13.7	13.6
		MCWBR	7.5	7.5	7.6	7.1	6.9	6.2	6.5	6.3	6.9	6.5	6.9	6.8
	5% WB	MCDBR	13.3	13.4	13.4	12.5	12.0	11.8	12.2	12.3	12.7	12.4	12.9	13.0
		MCWBR	7.9	8.0	8.6	7.7	7.9	6.6	6.8	6.9	7.3	6.9	7.2	7.6
Clear-Sky Solar Irradiance	taub	0.370	0.384	0.393	0.419	0.442	0.509	0.498	0.475	0.427	0.394	0.389	0.389	
	taud	2.541	2.495	2.461	2.421	2.376	2.132	2.173	2.262	2.428	2.522	2.534	2.503	
	Ebn at Noon	290	291	291	282	272	252	255	263	277	284	281	280	
	Edh at Noon	31	34	36	38	39	50	48	44	37	33	31	31	
All-Sky Solar Radiation	RadAvg	1453	1678	1859	1900	1838	1859	1900	1817	1760	1570	1447	1378	
	RadStd	61	50	74	101	106	118	110	86	119	132	96	56	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	-0.49	N/A	N/A	N/A	N/A

Nomenclature: See separate page