

FLORES MUNDO MAYA INTL, Guatemala

WMO: 786150

Lat: 16.917N

Lon: 89.883W

Elev: 377

StdP: 14.50

Time Zone: -6.00 (W06)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	57.9	60.7	55.5	66.5	63.8	57.6	71.8	66.1	15.0	71.6	12.5	74.3	0.3	90	0.266

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	23.1	100.3	78.6	98.3	78.2	96.4	77.7	81.5	92.1	80.8	91.0	80.1	90.1	5.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	152.8	86.4	78.6	150.4	86.1	77.4	144.3	85.0	45.7	92.5	44.8	91.2	44.1	91.1	90.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.3	11.1	9.5	DB	52.5	103.8	2.0	2.5	51.0	105.6	49.8	107.1	48.7	108.5	47.2	110.3	(4)
			WB	51.9	84.2	1.8	2.0	50.6	85.7	49.6	86.8	48.5	88.0	47.2	89.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	79.5	73.3	75.8	78.8	82.6	84.2	82.7	82.0	81.8	79.8	76.2	74.7		
		DBStd	4.67	3.92	3.61	4.09	3.54	3.04	2.43	1.84	1.74	1.76	2.78	3.56	3.63	(7)
		HDD50	0	0	0	0	0	0	0	0	0	0	0	0		
		HDD65	2	2	0	0	0	0	0	0	0	0	0	0		
		CDD50	10768	724	721	892	979	1059	980	991	993	955	924	786	764	(10)
		CDD65	5296	260	301	427	529	594	530	526	528	505	459	337	300	(11)
		CDH74	47659	1607	2507	4334	6160	6818	4930	4675	4667	4256	3565	2226	1914	(12)
		CDH80	22419	545	1095	2229	3486	3750	2264	2140	2181	1905	1417	759	648	(13)
(14)	Wind	WSAvg	2.9	2.6	3.3	4.3	4.8	4.2	3.0	2.7	2.3	1.8	2.2	2.0	2.0	(14)
(15)	Precipitation	PrecAvg	60.6	2.6	2.3	1.6	1.1	5.3	8.1	7.4	7.4	9.0	8.0	4.4	3.4	(15)
		PrecMax	77.0	5.6	7.2	4.6	3.3	20.9	14.0	12.1	14.5	17.7	15.9	8.3	6.9	(16)
		PrecMin	42.5	0.5	0.2	0.0	0.0	0.0	3.7	2.5	2.6	3.9	3.4	0.7	0.9	(17)
		PrecStd	10.5	1.8	1.8	1.7	1.0	5.0	2.9	2.3	3.1	3.7	3.4	2.3	1.8	(18)
																(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.4	95.2	100.7	103.9	102.5	99.0	96.7	96.7	96.5	95.0	91.8	91.7	(19)
			MCWB	76.7	77.1	78.2	78.6	78.8	79.8	78.6	79.2	79.9	80.4	78.7	77.9	(20)
		2%	DB	88.1	92.8	96.9	100.3	100.3	96.4	94.8	94.7	93.5	92.9	89.6	89.2	(21)
			MCWB	75.5	75.8	76.7	78.2	78.7	79.5	78.3	79.2	80.0	79.8	77.5	77.3	(22)
		5%	DB	86.1	89.8	93.6	97.2	98.3	93.3	92.9	93.0	91.7	90.0	87.5	86.2	(23)
			MCWB	74.7	75.3	75.5	77.1	78.2	79.1	78.5	79.2	79.5	79.0	76.7	76.0	(24)
		10%	DB	82.8	87.6	91.3	95.1	95.2	91.2	90.6	91.0	89.8	87.8	84.5	84.1	(25)
			MCWB	73.8	74.4	74.9	76.4	77.7	78.9	78.5	79.0	79.2	78.5	75.4	75.1	(26)
		0.4%	WB	78.3	78.9	80.0	81.4	81.6	82.3	81.5	81.8	82.0	82.2	80.4	79.9	(27)
			MCDB	87.8	91.3	94.9	97.4	95.5	93.1	90.5	91.8	91.5	91.8	89.0	88.1	(28)
(29)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	76.6	77.3	78.4	79.9	80.5	81.0	80.4	80.7	80.9	80.7	78.9	78.1	(29)
			MCDB	85.9	89.1	93.1	95.0	94.0	90.7	89.7	90.3	90.2	89.6	86.6	86.3	(30)
		5%	WB	75.5	76.3	77.2	78.6	79.7	80.1	79.7	80.0	80.1	79.7	77.7	76.8	(31)
			MCDB	84.2	87.3	90.4	93.3	92.7	89.2	88.8	89.2	89.1	87.7	85.1	84.6	(32)
		10%	WB	74.4	75.1	76.0	77.5	78.8	79.4	79.0	79.3	79.5	78.8	76.5	75.6	(33)
			MCDB	81.7	85.2	88.0	91.1	91.4	88.2	87.9	88.2	88.1	86.2	83.2	82.5	(34)
(35)	Mean Daily Temperature Range	MDBR	18.0	22.0	24.6	25.9	23.1	18.7	19.6	20.0	18.6	16.9	17.9	18.2		
		5% DB	MCDBR	23.8	27.3	29.0	28.8	26.8	21.7	22.5	22.6	20.8	20.5	21.2	22.4	(36)
			MCWBR	11.8	12.4	10.6	9.2	7.8	7.6	8.7	9.2	8.8	9.2	10.3	11.5	(37)
		5% WB	MCDBR	21.2	24.8	26.5	26.6	23.5	19.1	19.8	20.2	19.1	18.0	18.5	20.1	(38)
			MCWBR	11.2	11.9	10.4	9.0	8.0	7.7	8.7	8.9	8.6	8.6	9.6	10.8	(39)
																(39)
(40)	Clear-Sky Solar Irradiance	taub	0.367	0.378	0.417	0.550	0.616	0.497	0.499	0.479	0.444	0.406	0.381	0.382		
		taud	2.531	2.491	2.359	1.976	1.819	2.175	2.150	2.218	2.315	2.456	2.503	2.489		
		Ebn at Noon	293	294	284	247	228	255	255	262	272	281	285	284		
		Edh at Noon	32	34	40	59	69	48	49	46	42	35	32	32		
(44)	All-Sky Solar Radiation	RadAvg	1207	1465	1724	1843	1737	1644	1701	1721	1652	1437	1302	1191		
		RadStd	111	114	105	97	112	121	93	116	84	113	78	94		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page