

FLORES MUNDO MAYA INTL, Guatemala

WMO: 786150

Lat: 16.917N

Lon: 89.883W

Elev: 115

StdP: 99.95

Time Zone: -6.00 (W06)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.4	16.0	13.1	9.5	17.7	14.2	10.3	19.0	6.7	22.0	5.6	23.5	0.1	90	0.266

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.9	38.0	25.9	36.8	25.6	35.8	25.4	27.5	33.4	27.1	32.8	26.7	32.3	2.5	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.8	30.2	25.9	21.5	30.0	25.2	20.6	29.5	88.4	33.6	86.3	32.9	84.7	32.8	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.5	5.0	4.2	11.4	39.9	1.1	1.4	10.6	40.9	9.9	41.7	9.3	42.5	8.4	43.5		
			11.1	29.0	1.0	1.1	10.3	29.8	9.8	30.5	9.2	31.1	8.5	31.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.4	23.0	24.3	26.0	28.1	29.0	28.1	27.8	27.7	26.6	24.6	23.7	(6)	
(7)		DBStd	2.60	2.18	2.01	2.27	1.97	1.69	1.35	1.02	0.97	0.98	1.54	1.98	2.02	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	1	1	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	5982	402	401	496	544	588	544	551	552	531	513	437	424	(10)
(11)		CDD18.3	2942	144	167	237	294	330	294	292	293	281	255	187	167	(11)
(12)		CDH23.3	26477	893	1393	2408	3422	3788	2739	2597	2593	2364	1981	1237	1063	(12)
(13)		CDH26.7	12455	303	608	1238	1937	2083	1258	1189	1212	1058	787	422	360	(13)
(14)	Wind	WSAvg	1.3	1.1	1.5	1.9	2.2	1.9	1.4	1.2	1.0	0.8	1.0	0.9	0.9	(14)
(15)	Precipitation	PrecAvg	1540	65	59	41	29	134	207	187	188	228	204	112	86	(15)
(16)		PrecMax	1956	142	184	117	83	532	356	308	369	449	403	211	176	(16)
(17)		PrecMin	1079	12	4	0	0	0	93	64	67	100	87	19	22	(17)
(18)		PrecStd	266	45	45	44	26	127	74	58	80	94	87	58	46	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.0	35.1	38.2	40.0	39.1	37.2	35.9	36.0	35.9	35.0	33.2	33.2	(19)
(20)			MCWB	24.9	25.1	25.6	25.9	26.0	26.6	25.9	26.2	26.6	26.9	26.0	25.5	(20)
(21)		2%	DB	31.2	33.8	36.1	37.9	38.0	35.8	34.9	34.8	34.2	33.8	32.0	31.8	(21)
(22)			MCWB	24.2	24.3	24.9	25.7	25.9	26.4	25.7	26.2	26.7	26.6	25.3	25.2	(22)
(23)		5%	DB	30.0	32.1	34.2	36.2	36.8	34.1	33.8	33.9	33.1	32.2	30.8	30.1	(23)
(24)			MCWB	23.7	24.1	24.1	25.0	25.7	26.2	25.8	26.2	26.4	26.1	24.8	24.4	(24)
(25)		10%	DB	28.2	30.9	32.9	35.1	35.1	32.9	32.6	32.8	32.1	31.0	29.2	28.9	(25)
(26)			MCWB	23.2	23.6	23.9	24.6	25.4	26.0	25.8	26.1	26.2	25.8	24.1	23.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.7	26.0	26.7	27.5	27.5	28.0	27.5	27.7	27.8	27.9	26.9	26.6	(27)
(28)			MCDWB	31.0	33.0	35.0	36.4	35.3	34.0	32.5	33.2	33.0	33.2	31.7	31.2	(28)
(29)		2%	WB	24.8	25.2	25.8	26.6	26.9	27.2	26.9	27.1	27.2	27.1	26.0	25.6	(29)
(30)			MCDWB	29.9	31.7	33.9	35.0	34.4	32.6	32.0	32.4	32.4	32.0	30.3	30.2	(30)
(31)		5%	WB	24.2	24.6	25.1	25.9	26.5	26.7	26.5	26.6	26.7	26.5	25.4	24.9	(31)
(32)			MCDWB	29.0	30.7	32.4	34.1	33.7	31.8	31.5	31.8	31.7	31.0	29.5	29.2	(32)
(33)		10%	WB	23.5	24.0	24.4	25.3	26.0	26.3	26.1	26.3	26.4	26.0	24.7	24.2	(33)
(34)			MCDWB	27.6	29.6	31.1	32.8	33.0	31.2	31.0	31.2	31.2	30.1	28.4	28.1	(34)
(35)	Mean Daily Temperature Range	MDBR	10.0	12.2	13.7	14.4	12.9	10.4	10.9	11.1	10.3	9.4	9.9	10.1	(35)	
(36)		5% DB	MCDDBR	13.2	15.2	16.1	16.0	14.9	12.1	12.5	12.6	11.5	11.4	11.8	12.4	(36)
(37)			MCWBR	6.6	6.9	5.9	5.1	4.3	4.2	4.9	5.1	4.9	5.1	5.7	6.4	(37)
(38)		5% WB	MCDDBR	11.8	13.8	14.7	14.8	13.0	10.6	11.0	11.2	10.6	10.0	10.3	11.1	(38)
(39)			MCWBR	6.2	6.6	5.8	5.0	4.4	4.3	4.8	4.9	4.8	4.8	5.3	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.367	0.378	0.417	0.550	0.616	0.497	0.499	0.479	0.444	0.406	0.381	0.382	(40)	
(41)		taud	2.531	2.491	2.359	1.976	1.819	2.175	2.150	2.218	2.315	2.456	2.503	2.489	(41)	
(42)		Ebn at Noon	923	927	896	780	720	803	803	827	859	887	900	895	(42)	
(43)		Edh at Noon	100	108	127	187	216	150	154	145	131	111	102	102	(43)	
(44)	All-Sky Solar Radiation	RadAvg	3.80	4.62	5.43	5.81	5.48	5.18	5.36	5.43	5.21	4.53	4.10	3.75	(44)	
(45)		RadStd	0.35	0.36	0.33	0.31	0.35	0.38	0.29	0.37	0.26	0.36	0.24	0.30	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (2 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page