

SAN JOSE, Guatemala

WMO: 786470

Lat: 13.936N

Lon: 90.836W

Elev: 29

StdP: 14.68

Time Zone: -6.00 (W06)

Period: 96-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	64.1	66.0	55.3	65.2	76.4	58.8	74.1	75.5	21.1	89.1	18.1	88.1	0.4	0	0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	19.3	94.8	77.3	93.4	78.2	92.8	78.4	82.3	90.7	81.7	89.9	81.2	89.1	10.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.3	157.2	87.8	79.2	151.6	86.7	79.0	150.8	86.6	46.0	91.3	45.4	90.7	45.0	89.4	
(p)															

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	15.1	12.4	59.0	99.1	2.2	1.2	57.4	100.0	56.1	100.7	54.9	101.4	53.3	102.3		
(5)			56.4	83.4	1.9	0.5	55.1	83.7	53.9	84.0	52.9	84.2	51.5	84.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	81.1	78.5	79.6	81.4	83.1	83.1	82.0	82.0	82.1	81.6	80.7	80.0	78.6
	DBStd	2.40	1.87	1.99	2.10	1.82	1.99	1.71	1.61	1.44	1.55	2.07	2.07	1.91
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11335	884	828	973	994	1025	959	991	995	947	952	901	886
	CDD65	5860	419	408	508	544	560	509	526	530	497	487	451	421
	CDH74	62140	4399	4408	5880	6447	6328	5294	5649	5567	4757	4601	4554	4256
	CDH80	28392	2145	2144	2958	3203	2883	2238	2550	2451	1931	1844	2047	1998
Wind	WSAvg	3.5	3.5	4.2	4.2	4.1	3.5	3.6	3.4	3.4	3.5	3.1	2.6	2.8
Precipitation	PrecAvg	83.3	0.6	0.6	1.1	2.9	9.4	14.1	10.2	11.9	14.5	13.4	3.6	1.0
	PrecMax	104.8	1.6	1.4	2.8	6.9	15.2	20.2	16.0	21.9	22.7	24.9	11.8	2.8
	PrecMin	63.0	0.2	0.1	0.4	0.0	3.0	8.7	4.8	7.0	8.0	2.9	0.6	0.3
	PrecStd	9.6	0.3	0.3	0.6	1.6	2.6	2.7	2.8	3.3	3.1	4.1	3.0	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.7	95.0	95.2	96.8	95.3	93.3	93.4	93.4	92.0	91.8	91.8	92.7
		MCWB	71.0	73.2	75.8	77.7	79.9	80.5	80.5	80.1	80.4	79.9	77.5	76.1
	2%	DB	91.5	91.8	93.5	94.7	93.4	91.6	91.8	91.8	91.3	91.0	91.1	90.0
		MCWB	74.4	75.2	76.7	78.2	80.1	80.3	80.1	80.0	80.1	79.9	77.8	76.5
	5%	DB	89.9	91.2	92.9	93.2	91.8	91.0	91.3	91.2	89.8	89.7	89.8	89.6
		MCWB	75.0	75.5	76.8	78.4	80.0	80.1	80.0	79.9	79.7	79.4	77.6	76.6
	10%	DB	89.3	89.7	91.4	91.7	91.2	89.6	89.8	89.8	88.6	88.2	89.2	88.2
		MCWB	75.1	75.7	76.6	78.4	80.0	79.9	79.6	79.6	79.7	79.4	77.6	76.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.4	80.0	80.9	82.3	82.8	82.8	82.7	82.5	82.1	81.9	81.7	80.3
		MCDB	87.6	88.9	90.8	91.7	91.5	90.5	91.3	90.9	90.4	89.7	89.7	88.4
	2%	WB	78.4	78.8	80.0	81.0	81.9	81.8	81.6	81.6	81.3	81.2	80.7	79.5
		MCDB	87.1	88.2	89.5	90.0	90.3	89.4	89.8	89.7	89.2	88.6	88.2	87.7
	5%	WB	77.4	77.9	79.2	80.4	81.2	81.0	80.9	80.9	80.7	80.5	79.9	78.6
		MCDB	86.6	87.2	88.4	89.2	89.4	88.4	88.7	88.7	88.1	87.7	87.2	87.0
	10%	WB	76.7	77.1	78.5	79.8	80.6	80.3	80.2	80.2	80.0	79.9	79.2	77.4
		MCDB	86.0	86.4	87.5	88.5	88.5	87.4	87.7	87.6	87.0	86.6	86.3	86.1
Mean Daily Temperature Range	5% DB	MDBR	23.3	22.4	21.7	19.3	16.1	15.2	16.4	16.0	14.8	14.9	18.9	21.7
		MCDBR	24.0	23.4	22.4	20.3	17.8	17.0	17.8	17.7	16.5	16.8	19.4	22.1
		MCWBR	11.3	10.5	9.2	7.9	7.3	7.7	8.1	7.9	7.6	7.9	9.3	10.9
	5% WB	MCDBR	22.3	21.5	20.3	18.6	16.5	15.7	16.6	16.2	15.2	15.4	17.3	20.7
		MCWBR	11.1	10.3	8.9	7.9	7.6	7.7	8.3	7.9	7.6	7.8	8.9	11.0
Clear-Sky Solar Irradiance	taub		0.384	0.404	0.449	0.548	0.560	0.466	0.469	0.467	0.452	0.419	0.399	0.381
	taud		2.521	2.464	2.317	2.033	2.020	2.328	2.322	2.320	2.337	2.465	2.498	2.537
	Ebn at Noon		290	288	276	248	241	262	262	266	271	280	283	288
	Edh at Noon		33	36	43	56	56	41	41	42	41	35	33	31
All-Sky Solar Radiation	RadAvg		1776	1934	2039	1971	1716	1710	1910	1865	1687	1612	1715	1706
	RadStd		42	72	84	93	118	106	112	115	125	134	70	44

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page