

SAN JOSE, Guatemala

WMO: 786470

Lat: 13.936N

Lon: 90.836W

Elev: 9

StdP: 101.22

Time Zone: -6.00 (W06)

Period: 96-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.9	18.9	12.9	9.3	24.6	14.9	10.6	24.2	9.4	31.7	8.1	31.2	0.2	0	0.311

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.7	34.9	25.2	34.1	25.7	33.8	25.8	27.9	32.6	27.6	32.2	27.3	31.7	4.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.8	22.5	31.0	26.2	21.7	30.4	26.1	21.5	30.3	89.1	32.9	87.8	32.6	86.7	31.9	29.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.8	5.5	DB	15.0	37.3	1.2	0.7	14.1	37.8	13.4	38.2	12.7	38.5	11.8	39.0	(4)
(5)			WB	13.6	28.5	1.1	0.3	12.8	28.7	12.2	28.9	11.6	29.0	10.8	29.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	25.8	26.4	27.4	28.4	27.8	27.8	27.8	27.5	27.1	26.7	25.9	(6)	
(7)		DBStd	1.33	1.04	1.10	1.17	1.01	1.11	0.95	0.89	0.80	0.86	1.15	1.15	1.06	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6297	491	460	541	552	569	533	551	553	526	529	501	492	(10)
(11)		CDD18.3	3256	233	227	282	302	311	283	292	294	276	271	251	234	(11)
(12)		CDH23.3	34522	2444	2449	3267	3582	3516	2941	3138	3093	2643	2556	2530	2364	(12)
(13)	CDH26.7	15773	1192	1191	1643	1779	1602	1243	1417	1362	1073	1024	1137	1110	(13)	
(14)	Wind	WSAvg	1.6	1.5	1.9	1.9	1.8	1.6	1.5	1.5	1.6	1.4	1.2	1.2	(14)	
(15)	Precipitation	PrecAvg	2116	16	14	29	74	239	358	260	301	369	340	91	25	(15)
(16)		PrecMax	2661	41	35	71	176	386	512	406	557	577	632	299	71	(16)
(17)		PrecMin	1601	4	3	9	0	76	222	122	178	204	73	16	7	(17)
(18)		PrecStd	244	8	8	15	40	67	69	70	83	80	104	76	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.9	35.0	35.1	36.0	35.2	34.0	34.1	34.1	33.3	33.2	33.2	33.7	(19)
(20)			MCWB	21.7	22.9	24.3	25.4	26.6	27.0	26.9	26.7	26.9	26.6	25.3	24.5	(20)
(21)		2%	DB	33.1	33.2	34.2	34.8	34.1	33.1	33.2	33.2	32.9	32.8	32.9	32.2	(21)
(22)			MCWB	23.5	24.0	24.8	25.7	26.7	26.8	26.7	26.6	26.7	26.6	25.4	24.7	(22)
(23)		5%	DB	32.2	32.9	33.8	34.0	33.2	32.8	32.9	32.9	32.1	32.0	32.1	32.0	(23)
(24)			MCWB	23.9	24.2	24.9	25.8	26.7	26.7	26.7	26.6	26.5	26.3	25.4	24.8	(24)
(25)	10%	DB	31.9	32.1	33.0	33.2	32.9	32.0	32.1	32.1	31.4	31.2	31.8	31.2	(25)	
(26)		MCWB	24.0	24.3	24.8	25.8	26.7	26.6	26.4	26.4	26.5	26.4	25.3	24.7	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.3	26.7	27.2	27.9	28.2	28.2	28.1	27.8	27.7	27.6	26.8	(27)	
(28)			MCD B	30.9	31.6	32.7	33.1	33.1	32.5	32.9	32.7	32.4	32.1	32.0	31.4	(28)
(29)		2%	WB	25.8	26.0	26.7	27.2	27.7	27.6	27.6	27.4	27.3	27.0	26.4	(29)	
(30)			MCD B	30.6	31.2	32.0	32.2	32.4	31.9	32.1	32.1	31.8	31.5	31.2	31.0	(30)
(31)		5%	WB	25.2	25.5	26.2	26.9	27.4	27.2	27.2	27.0	26.9	26.6	25.9	(31)	
(32)			MCD B	30.3	30.7	31.4	31.8	31.9	31.3	31.5	31.5	31.2	30.9	30.7	30.6	(32)
(33)		10%	WB	24.8	25.1	25.8	26.5	27.0	26.8	26.8	26.8	26.7	26.6	26.2	25.2	(33)
(34)			MCD B	30.0	30.2	30.8	31.4	31.4	30.8	30.9	30.9	30.6	30.3	30.2	30.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.9	12.4	12.1	10.7	9.0	8.4	9.1	8.9	8.2	8.3	10.5	12.0	(35)
(36)			MCDBR	13.3	13.0	12.4	11.3	9.9	9.5	9.9	9.8	9.2	9.3	10.8	12.3	(36)
(37)			MCWBR	6.3	5.8	5.1	4.4	4.1	4.3	4.5	4.4	4.2	4.4	5.2	6.0	(37)
(38)		5% WB	MCDBR	12.4	12.0	11.3	10.3	9.2	8.7	9.2	9.0	8.5	8.6	9.6	11.5	(38)
(39)			MCWBR	6.2	5.7	5.0	4.4	4.2	4.3	4.6	4.4	4.2	4.3	4.9	6.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.384	0.404	0.449	0.548	0.560	0.466	0.469	0.467	0.452	0.419	0.399	0.381	(40)	
(41)		taud	2.521	2.464	2.317	2.033	2.020	2.328	2.322	2.320	2.337	2.465	2.498	2.537	(41)	
(42)		Ebn at Noon	915	908	871	782	760	827	827	838	855	882	892	908	(42)	
(43)		Edh at Noon	103	113	134	177	176	128	129	131	129	111	104	99	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.60	6.10	6.43	6.21	5.41	5.39	6.02	5.88	5.32	5.08	5.41	5.38	(44)	
(45)		RadStd	0.13	0.23	0.27	0.29	0.37	0.33	0.35	0.36	0.40	0.42	0.22	0.14	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page