

EL SALVADOR INTL, El Salvador

WMO: 786660

Lat: 13.441N

Lon: 89.056W

Elev: 101

StdP: 14.64

Time Zone: -6.00 (W06)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	67.6	68.4	50.1	53.7	81.7	53.4	60.8	81.4	16.0	80.8	13.7	82.1	2.9	60	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	18.0	95.4	73.4	94.7	73.9	93.3	74.7	81.4	88.4	80.7	87.9	80.1	87.2	10.0	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	152.1	84.4	79.0	151.1	84.3	78.7	149.4	84.2	45.1	89.2	44.5	88.1	44.0	88.2	84.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
16.7	14.1	12.1	DB	62.6	99.9	1.5	1.1	61.5	100.7	60.6	101.3	59.8	101.9	58.7	102.7
			WB	57.6	83.1	2.1	1.1	56.1	83.9	54.8	84.5	53.6	85.1	52.1	85.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.0	81.4	81.7	82.8	83.6	83.0	81.9	82.5	82.0	81.1	80.8	81.4	81.3
	DBStd	2.30	2.51	2.52	2.66	2.14	2.19	1.96	1.97	1.83	1.55	1.95	2.01	2.28
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11665	973	888	1016	1008	1022	958	1008	992	934	954	941	971
	CDD65	6190	508	468	551	558	557	508	543	527	484	489	491	506
	CDH74	65053	5185	5005	6292	6651	6247	5273	5915	5537	4591	4440	4834	5083
	CDH80	28783	2437	2419	3047	3157	2665	2132	2673	2365	1764	1655	2099	2370
Wind	WSAvg	5.2	6.8	6.4	6.2	5.5	4.7	4.2	4.6	4.5	4.2	4.4	5.5	5.9
Precipitation	PrecAvg	62.8	0.9	0.7	0.8	1.9	7.0	9.9	8.2	9.7	11.5	8.6	2.4	1.1
	PrecMax	77.2	1.5	1.8	1.7	5.0	12.8	15.0	15.3	17.6	16.3	15.0	6.7	2.8
	PrecMin	51.0	0.6	0.2	0.2	0.2	3.1	4.7	3.5	5.1	6.9	1.9	0.6	0.3
	PrecStd	6.9	0.3	0.4	0.4	1.2	2.1	2.3	2.8	2.7	2.2	2.8	1.6	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	96.6	97.0	98.3	97.2	95.4	94.9	95.3	93.6	91.8	93.0	94.6	95.3
		MCWB	71.5	70.2	70.7	71.7	76.3	76.5	76.7	78.0	79.0	77.3	75.2	73.8
	2%	DB	93.6	94.6	95.0	94.6	93.4	91.7	93.3	91.8	91.0	91.0	91.8	93.3
		MCWB	71.5	71.1	71.5	74.6	77.3	78.6	77.6	78.5	79.0	77.9	74.5	73.1
	5%	DB	91.7	91.8	93.0	93.1	91.6	90.0	91.6	91.2	89.6	89.5	91.2	91.6
		MCWB	71.9	72.1	73.0	75.6	77.9	78.8	78.0	78.6	79.0	78.2	74.6	73.2
	10%	DB	89.9	90.0	91.3	91.5	89.9	89.4	90.0	89.6	88.0	87.9	89.5	89.8
		MCWB	72.4	72.8	74.0	76.0	78.1	78.8	78.2	78.6	79.2	78.5	75.0	73.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.2	78.0	79.9	81.4	81.7	81.8	81.6	81.7	81.7	81.6	80.4	79.0
		MCDB	87.3	87.6	87.5	87.8	88.5	89.3	89.7	89.4	88.2	87.2	87.9	87.4
	2%	WB	76.0	76.5	78.8	80.1	80.7	80.8	80.5	80.7	80.6	80.6	79.3	77.7
		MCDB	86.7	86.5	86.2	87.5	87.7	88.0	88.4	88.2	87.6	87.1	86.6	86.8
	5%	WB	75.2	75.6	77.8	79.2	80.0	80.0	79.8	79.9	79.9	79.8	78.6	76.5
		MCDB	86.3	85.9	85.9	86.8	86.8	86.8	87.6	87.3	86.6	86.0	85.8	86.1
	10%	WB	74.4	74.9	76.8	78.6	79.3	79.3	79.1	79.3	79.2	79.1	77.7	75.6
		MCDB	85.5	85.5	85.6	86.3	86.0	85.8	86.9	86.5	85.7	85.0	84.9	85.1
Mean Daily Temperature Range	5% DB	MDBR	21.3	21.3	20.2	18.0	15.2	15.0	17.2	16.4	14.9	14.9	18.7	21.0
		MCDBR	22.2	22.2	21.5	19.5	17.2	17.0	18.9	18.3	16.9	17.5	20.1	21.7
		MCWBR	8.9	8.8	8.9	8.0	7.0	7.4	7.8	8.1	8.0	8.2	8.8	8.8
	5% WB	MCDBR	21.1	20.7	18.2	16.9	15.2	15.3	17.2	16.5	15.4	15.1	17.3	20.6
MCWBR		9.2	9.1	8.2	7.5	6.9	7.4	8.2	8.1	7.7	7.6	8.3	8.8	
Clear-Sky Solar Irradiance	taub	0.376	0.392	0.431	0.541	0.573	0.462	0.465	0.452	0.447	0.412	0.393	0.375	
	taud	2.542	2.497	2.369	2.042	1.969	2.334	2.322	2.357	2.356	2.492	2.523	2.560	
	Ebn at Noon	293	292	282	250	238	263	263	270	273	282	285	291	
	Edh at Noon	32	35	40	56	59	40	41	40	40	35	32	31	
All-Sky Solar Radiation	RadAvg	1830	1992	2088	1980	1779	1799	2011	1973	1763	1673	1779	1759	
	RadStd	34	61	108	112	134	103	116	134	133	142	64	38	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page