

EL SALVADOR INTL, El Salvador

WMO: 786660

Lat: 13.441N

Lon: 89.056W

Elev: 31

StdP: 100.96

Time Zone: -6.00 (W06)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	19.8	20.2	10.0	7.7	27.6	11.9	8.7	27.4	7.2	27.1	6.1	27.8	1.3	60	0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	10.0	35.2	23.0	34.8	23.3	34.0	23.7	27.4	31.3	27.1	31.1	26.7	30.7	4.5	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	21.7	29.1	26.1	21.6	29.1	25.9	21.3	29.0	87.0	31.8	85.7	31.2	84.4	31.2	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.5	6.3	5.4	DB	17.0	37.7	0.8	0.6	16.4	38.2	15.9	38.5	15.4	38.8	14.8	39.3	(4)
(5)			WB	14.2	28.4	1.2	0.6	13.4	28.8	12.7	29.2	12.0	29.5	11.2	30.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	27.8	27.4	27.6	28.2	28.7	28.3	27.7	28.1	27.8	27.3	27.1	27.4	27.4	(6)
(7)		DBStd	1.28	1.40	1.40	1.48	1.19	1.21	1.09	1.09	1.02	0.86	1.08	1.12	1.27	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6481	541	493	564	560	568	532	560	551	519	530	523	539	(10)
(11)		CDD18.3	3439	282	260	306	310	309	282	302	293	269	272	273	281	(11)
(12)		CDH23.3	36141	2881	2781	3496	3695	3471	2929	3286	3076	2551	2467	2686	2824	(12)
(13)		CDH26.7	15991	1354	1344	1693	1754	1481	1184	1485	1314	980	919	1166	1317	(13)
(14)	Wind	WSAvg	2.3	3.0	2.8	2.8	2.4	2.1	1.9	2.1	2.0	1.9	2.0	2.5	2.7	(14)
(15)	Precipitation	PrecAvg	1596	24	18	20	47	179	252	208	247	292	219	62	27	(15)
(16)		PrecMax	1960	37	45	43	127	324	382	389	448	413	380	169	72	(16)
(17)		PrecMin	1295	14	5	6	5	80	120	90	130	174	48	15	8	(17)
(18)		PrecStd	175	7	9	10	31	53	59	71	69	57	70	40	14	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.9	36.1	36.8	36.2	35.2	35.0	35.2	34.2	33.2	33.9	34.8	35.1	(19)
(20)			MCWB	21.9	21.2	21.5	22.1	24.6	24.7	24.9	25.6	26.1	25.2	24.0	23.2	(20)
(21)		2%	DB	34.2	34.8	35.0	34.8	34.1	33.2	34.1	33.2	32.8	32.8	33.2	34.1	(21)
(22)			MCWB	21.9	21.7	21.9	23.6	25.2	25.9	25.3	25.8	26.1	25.5	23.6	22.8	(22)
(23)		5%	DB	33.2	33.2	33.9	33.9	33.1	32.2	33.1	32.9	32.0	31.9	32.9	33.1	(23)
(24)			MCWB	22.2	22.3	22.8	24.2	25.5	26.0	25.6	25.9	26.1	25.7	23.7	22.9	(24)
(25)		10%	DB	32.2	32.2	33.0	33.1	32.2	31.9	32.2	32.0	31.1	31.0	32.0	32.1	(25)
(26)			MCWB	22.4	22.7	23.3	24.4	25.6	26.0	25.7	25.9	26.2	25.8	23.9	23.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.1	25.6	26.6	27.5	27.6	27.7	27.6	27.6	27.5	26.9	26.1	(27)	
(28)			MADB	30.7	30.9	30.8	31.0	31.4	31.8	32.0	31.9	31.2	30.7	31.0	30.8	(28)
(29)		2%	WB	24.4	24.7	26.0	26.7	27.1	27.1	26.9	27.1	27.0	27.0	26.3	25.4	(29)
(30)			MADB	30.4	30.3	30.1	30.8	30.9	31.1	31.3	31.2	30.9	30.6	30.3	30.5	(30)
(31)		5%	WB	24.0	24.2	25.4	26.2	26.6	26.7	26.6	26.6	26.6	26.5	25.9	24.7	(31)
(32)			MADB	30.2	30.0	29.9	30.4	30.4	30.5	30.9	30.7	30.3	30.0	29.9	30.0	(32)
(33)		10%	WB	23.5	23.8	24.9	25.9	26.3	26.3	26.2	26.3	26.2	26.2	25.4	24.2	(33)
(34)			MADB	29.7	29.7	29.8	30.2	30.0	29.9	30.5	30.3	29.8	29.4	29.4	29.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	11.9	11.9	11.2	10.0	8.4	8.4	9.6	9.1	8.3	8.3	10.4	11.6	(35)
(36)			MCDBR	12.3	12.3	12.0	10.8	9.6	9.4	10.5	10.2	9.4	9.7	11.1	12.1	(36)
(37)			MCWBR	4.9	4.9	4.9	4.5	3.9	4.1	4.3	4.5	4.4	4.5	4.9	4.9	(37)
(38)		5% WB	MCDBR	11.7	11.5	10.1	9.4	8.4	8.5	9.5	9.2	8.6	8.4	9.6	11.4	(38)
(39)			MCWBR	5.1	5.1	4.6	4.2	3.9	4.1	4.5	4.5	4.3	4.2	4.6	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.376	0.392	0.431	0.541	0.573	0.462	0.465	0.452	0.447	0.412	0.393	0.375	(40)	
(41)		taud	2.542	2.497	2.369	2.042	1.969	2.334	2.322	2.357	2.356	2.492	2.523	2.560	(41)	
(42)		Ebn at Noon	924	921	888	789	750	830	830	850	861	890	899	916	(42)	
(43)		Edh at Noon	101	110	127	176	186	127	129	126	127	109	102	97	(43)	
(44)	All-Sky Solar Radiation	RadAvg	5.77	6.28	6.58	6.24	5.61	5.67	6.34	6.22	5.56	5.27	5.61	5.55	(44)	
(45)		RadStd	0.11	0.19	0.34	0.35	0.42	0.32	0.36	0.42	0.42	0.45	0.20	0.12	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page