

SANTA ROSA DE COPAN, Honduras

WMO: 787170

Lat: 14.783N

Lon: 88.783W

Elev: 1079

StdP: 89.02

Time Zone: -6.00 (W06)

Period: 83-16

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.6	11.8	8.4	7.8	17.8	9.8	8.6	17.8	7.4	21.1	6.5	20.8	0.5	0	0.264

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	11.8	31.1	19.8	30.0	19.6	28.9	19.7	22.5	26.0	22.0	25.7	21.6	25.3	3.1	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.4	18.4	23.5	21.1	18.0	23.1	20.7	17.5	22.7	72.0	26.2	70.0	25.5	68.5	25.4	29.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	6.7	5.6	4.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)				N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.0	18.2	19.7	20.6	22.8	22.7	22.6	22.1	22.3	22.2	21.1	19.2	18.2
	DBStd	2.53	2.37	2.50	2.81	2.08	1.71	0.94	1.03	0.80	0.97	1.72	2.29	2.16
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	112	32	14	13	2	0	0	0	0	0	3	18	29
	CDD10.0	4005	254	271	329	384	394	378	374	380	367	343	277	254
	CDD18.3	1074	27	52	83	136	136	128	116	122	117	88	46	25
	CDH23.3	5327	114	347	650	958	874	582	438	467	436	267	113	80
	CDH26.7	993	12	73	189	299	228	69	31	26	39	16	6	6
Wind	WSAvg	1.7	1.7	1.9	2.1	2.1	1.7	1.5	1.8	1.6	1.5	1.5	1.5	1.5
Precipitation	PrecAvg	1636	40	29	27	51	139	275	181	234	261	169	100	54
	PrecMax	2002	66	83	130	167	237	544	480	418	466	389	222	119
	PrecMin	1300	22	4	3	4	63	116	47	83	103	47	56	23
	PrecStd	191	11	15	26	44	47	92	89	89	91	72	43	24
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	28.0	31.1	32.0	32.1	32.2	30.1	28.8	28.2	29.1	28.1	27.2	27.4
		MCWB	18.2	19.5	18.8	20.2	19.4	20.8	19.9	20.7	20.5	21.3	20.4	19.8
	2%	DB	26.0	28.8	30.2	31.0	30.5	28.2	27.2	27.2	27.9	27.0	25.9	25.2
		MCWB	18.1	18.7	18.8	20.0	19.9	20.7	19.8	20.3	20.8	20.7	19.8	18.8
	5%	DB	24.6	27.0	29.0	30.0	29.1	27.5	26.6	26.8	27.0	26.1	24.8	24.0
		MCWB	17.8	18.1	18.7	19.7	19.9	20.6	19.9	20.3	20.7	20.5	19.4	18.5
	10%	DB	23.1	25.2	27.1	28.8	27.9	26.8	25.9	26.0	26.1	25.0	23.6	22.8
		MCWB	17.7	18.0	18.6	19.7	19.8	20.5	20.1	20.3	20.6	20.2	19.2	18.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.1	21.2	21.6	22.7	22.8	23.2	22.5	22.3	22.7	22.4	21.8	21.2
		MCDB	24.0	27.7	26.0	26.2	25.7	26.5	25.7	26.0	26.1	26.4	25.7	25.3
	2%	WB	19.2	20.1	20.7	21.7	21.9	22.2	21.7	21.7	22.0	21.6	20.7	19.8
		MCDB	22.9	25.0	25.0	25.8	25.4	25.9	25.0	25.3	25.5	25.5	23.9	23.3
	5%	WB	18.7	19.4	20.1	21.3	21.4	21.7	21.2	21.3	21.5	21.1	20.1	19.1
		MCDB	22.2	23.9	24.5	25.6	25.2	25.3	24.5	24.9	25.0	24.6	23.1	22.5
	10%	WB	18.2	18.8	19.6	20.7	20.8	21.3	20.7	20.9	21.0	20.6	19.7	18.6
		MCDB	21.5	23.0	24.1	25.2	24.8	24.8	23.8	24.2	24.6	23.7	22.3	21.5
Mean Daily Temperature Range	5% DB	MDBR	8.2	10.5	11.4	11.8	11.0	9.1	8.4	8.5	8.5	7.4	7.1	7.5
		MCDBR	11.7	14.1	14.5	13.7	12.7	10.3	9.3	9.2	9.6	9.0	9.6	10.5
		MCWBR	4.8	5.4	5.1	4.4	4.2	3.9	3.6	3.6	3.9	3.9	4.4	4.7
	5% WB	MCDBR	9.7	12.1	12.6	12.2	11.0	9.1	8.6	8.6	8.8	8.3	8.0	8.9
		MCWBR	4.4	5.1	4.9	4.5	4.0	4.0	3.9	3.8	4.1	3.9	4.0	4.4
Clear-Sky Solar Irradiance	taub	0.325	0.332	0.358	0.412	0.445	0.392	0.394	0.383	0.378	0.366	0.342	0.332	
	taud	2.602	2.586	2.484	2.315	2.259	2.466	2.454	2.472	2.484	2.543	2.588	2.595	
	Ebn at Noon	975	979	955	896	854	891	892	910	922	931	949	957	
	Edh at Noon	94	99	113	134	139	112	113	113	111	103	95	92	
All-Sky Solar Radiation	RadAvg	4.40	5.26	5.82	5.86	5.31	5.33	5.69	5.72	5.22	4.48	4.26	4.22	
	RadStd	0.32	0.32	0.35	0.33	0.36	0.30	0.32	0.31	0.32	0.45	0.26	0.28	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page